

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023					Day : Saturday				Date : 25.02.23				
Probable Maximum Demand : 11100 MW					Probable Maximum Generation : 11525 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 80.38 ft		Today = 80.13 ft		25.02.23		Rule Curve = 93.60 ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.02.23 (Yesterday)		25.02.23 (Today)		24.02.23 (Yesterday)		25.02.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130	50		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	353	345	300	300	15		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0		450	under maint.	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	398	370	370				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	101	96	65	90	114		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	303	260	270	270	75		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	59	104	58				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	0	22	22				
17	Summit Power(Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	45	46	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	28	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	32	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	49	25	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	70	52	70				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	98	48	100				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	147	248	145	245				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	26	72	108				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	0	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	18	17	55				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	32	60	33	60				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	10	9	9	9				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	90	80	76	76				
Dhaka Zone Total					6004	5847	2176	2611	2170	2688	467	1525	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	120	0	0	60		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	18	19	19				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	34	85				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	151	151	75		ST Under maint	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	105	239	100	245				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	50	50				
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	67	68	51	85				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	57	48	72				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15	7		Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	35	50				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	44	44	44				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total					2442	2382	634	945	805	1049	267	405	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	46	47	44	44				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	189	220	200	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	315	275	330	330	85		Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	325	333	350	360	67		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	25	5	5	50			Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	67	140	67	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	28	28	36				
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	100	100	100				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	20	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	115	9	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	72	18	72				
**	Import (Tripura)	India		160	160	122	130	135	153				
Cumilla Zone Total					3309	3285	1407	1645	1461	1766	883	163	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	36	108	100	100	94		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	16	19	19				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	89	68	98				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	37	65	66	56				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	253	284	311	279	94	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.02.23 (Yesterday)		25.02.23 (Today)		24.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42			28	GT-1 & ST-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	42	42	42			48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	51	51	51					
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112			51	ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	61	61					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	86	86	86					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	25	25	135	135			206	Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8		17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	270	310	310					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	414	368	400	400					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0			383	Under maint.	
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	50	50	50					
Sylhet Zone Total						2472	2427	1222	1149	1332	1332	17	1146	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	285	300	315	315		110		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	0	40					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0	70					
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	36	35	35					
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	28	89	85	85					
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	83	0	100	0					
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	66	16	83					
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	0	16					
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	360	0	0	0		617		Coal Shortage	
117	Khulna 330 MW CCPP	Gas/HSD (BFPDB)				0	0	0	0					
**	Bheramara (H/DC)	India		1000	1000	895	763	892	892					
Khulna Zone Total						3005	3001	1719	1379	1443	1536	727	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	96	16	96					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	0	0	0					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	800	1052	1242	1242					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	72	0	0					
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	242	304	306	306					
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0					
Barishal Zone Total						2265	2265	1058	1524	1564	1644	0	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71		Gas Shortage	
125	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100		Gas Shortage	
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	25	32	0	32					
127	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
128	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	17	30	16	30					
129	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	93	50	95					
130	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	39	40	32	40					
131	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	42	42					
132	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	36	26	36					
133	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	157	142	180	185					
134	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220		Gas Shortage	
135	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	152	172	176	180		48		Gas Shortage	
136	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0			414	Under maint.	
137	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22					
138	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
139	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
140	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75					
141	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70					
142	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0					
Adani Power Jharkhanda Ltd								0	0	0	0			
Rajshahi Zone Total						2129	2129	613	764	639	826	439	414	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200		74		Coal Shortage	
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	84	38	92					
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
148	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	54	94	35	113					
150	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0					
151	Teesla Solar Limited	Solar (IPP)				104	0	130	0					
Rangpur Zone Total						830	750	431	378	441	405	159	85	
Sub-total: Plants in operation						23078	22700	9513	10679	10166	11525	3053	3738	
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0					Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0			
Gross Total						23482	22700	9513	10679	10166	11525	3053	3738	
(C) Actual data of 24.02.23 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	10679 MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	10276 MW, at =	19:30 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10679 MW, at =	19:30 hrs			MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	8141 MW, at =	5:00 hrs		Dhaka	3672	3672	0	Mymensingh	936	936	0	
05.	Day-peak Generation (Generation end)	:	9513 MW, at =	12:00 hrs		Chattogram	1032	1032	0	Sylhet	365	365	0	
06.	Evening-peak Generation (Generation end)	:	10679 MW, at =	19:30 hrs		Khulna	1241	1241	0	Barishal	291	291	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs		Rajshahi	1091	1091	0	Rangpur	673	673	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7644 MW, at =	5:00 hrs		Cumilla	976	976	0					
09.	Generation shortfall at evening peak due to :	:								Total	10276	10276	0	
	a) Gas/LF limitation	:	2694 MW		13.	Fuel cost :	(a) Gas =	123585634 Taka		(c) Coal =	241056188 Taka			
	d) Coal supply Limitation	:	159 MW				(b) Oil =	584275710 Taka		Total =	948917532 Taka			
	b) Low water level in Kaptai lake	:	200 MW											
	c) Plants under shut down/ maintenance	:	3738 MW		14.	Maximum Temperature in Dhaka was :		32.4° C						
10.	Total Energy (Generation + India Import)	:	216.94 MKWh		15.	Export through East-West interconnections :								
	By Gas = 112.672 MKWh		By Oil = 43.825 MKWh			At evening peak-hour	:	9513 MW, at	19:30 hrs					
	By Coal = 34.890 MKWh		By Hydro = 0.739 MKWh			Maximum	:	280 MW, at	19:30 hrs					
	By Solar= 2.001 MKWh					Energy	:	0 MKWh						
11. Total Gas Supplied : 889.51 MMCFD														
(D) Forecast of 25.02.23 (Today) Saturday :														
01.	Maximum Demand	:	11100 MW (Generation end)		04.									