

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 27-Feb-23

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour Generation	Energy Generated	Remarks
				Unit No. X Capacity	MW			
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	0	260	0	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	130	0	3117125	
	Ghorasal TPP Unit-5	PDB	1'210	190	180	0	4378500	
3	Ghorasal 365 MW CCPP Unit-7	PDB	2'43+1'122	365	0	0	0	Under maint.
	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	0	
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	0	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	391	9615360	9615360	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	342	7988000	7988000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	8941500	8941500	
9	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	58	849600	849600	Fuel shortage
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	284	6645411	6645411	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	80	891262	891262	Fuel shortage
12	Madanganj-55 MW PPS(Summit)	IPP	3'17.08+1'11.3	55	55	926397	926397	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIIPP, REB	8'2.90	22	22	385668	385668	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	889000	889000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	58	847680	847680	Fuel shortage
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	0	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	58	862848	862848	Fuel shortage
20	Katpotti 52 MW PP (Sirsha)	IPP	7'7.9	0	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	160200	160200	Fuel shortage
22	Kodda 150MW PP	BPDB-RPCL	9'17.08	115	149	1075680	1075680	Fuel shortage
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	297950	297950	Fuel shortage
24	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	306991	306991	Fuel shortage
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	0	
26	Summit Power (Madhabdi-Ashulia)	SIIPP, REB	3'3.67+4'8.73	80	46	1085640	1085640	Engine problem
27	Madona 33 MW PP(Summit)	SIIPP, REB	4'8.73	33	33	626100	626100	
28	Ragun 33 MW PP(Summit)	SIIPP, REB	4'8.73	33	28	683300	683300	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	50	506400	506400	
30	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	245	2571818	2571818	Fuel shortage
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	0	Fuel shortage
33	Bramhanaga 100 MW PP (Aggreko)	IPP	114'9.959	100	0	0	0	Fuel shortage
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	0	Fuel shortage
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	91	1256260	1256260	Fuel shortage
36	Gazipur 100 MW PP	RPCL	6'17.5	105	88	1068499	1068499	Fuel shortage
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	17	427200	427200	Fuel shortage
38	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	91	731520	731520	Fuel shortage
39	Spectro Solar Plant Ltd.	IPP	35	35	0	186073	186073	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	17	430560	430560	Fuel shortage
Dhaka area Total				5847	3034	57944142		
41	Chattoagram TPP-1	PDB	1'210	180	0	0	0	
42	Chattoagram TPP-2	PDB	1'210	180	0	0	0	Gas shortage
43	Racozan 25 MW PP	RPCL	3'8.9	25	25	279975	279975	
44	Teknaf 20MW PP (Solaritech)	IPP	2'40	20	0	137970	137970	
45	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	19	463680	463680	Fuel shortage
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	30	723480	723480	Low water level
47	Sikalbaha 225MW	PDB	1'150+1'75	225	227	5024542	5024542	
48	Sikalbaha Peaking GT	PDB	1'150	150	0	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	51	729309	729309	Fuel shortage
50	Hathazari 100 MW peaking PP	PDB	11'8.9	98	69	568944	568944	Engine problem
51	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	85	635944	635944	Engine problem
52	Juldah 100 MW Unit-1 (Accom)	NENP	8'13.45	100	61	999690	999690	Fuel shortage
53	Juldah 100 MW PP Unit-3 (Accom)	IPP	8'13.5	100	100	1264320	1264320	
54	Barabkunda 22 MW PP (Regent)	SIIPP, PDB	8'2.90	22	12	304560	304560	Gas shortage
55	Malancha, Ctr. EPZ Unit-2 (ECVP)	IPP	5'8.73+9'3.4	0	0	22680	22680	
56	Chattoagram 108 MW PP (ECVP)	IPP	16'7	108	0	0	0	Fuel shortage
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	26879	26879	
58	Anwara 300 MW PP (United)	IPP	17'17+24	300	238	2629527	2629527	Fuel shortage
59	Jodiac Power	IPP	3'18.55+1'3.6	54	17	452685	452685	Fuel shortage
60	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	54	1326467	1326467	Fuel shortage
61	Juldah unit-2 (Accom)	IPP	8'13.6	100	90	1186500	1186500	Fuel shortage
62	Anilima Energy Ltd.	IPP	8'21.2	116	107	2565545	2565545	Engine problem
63	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	0	0	0	On test.
Chattoagram area Total				2382	1185	19339427		
64	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	0	Contract Expired
65	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	0	Contract Expired
66	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	0	Gas shortage
67	Ashuganj 225 MW CCPP	APSCL	1'142+1'75	221	182	4561000	4561000	FGMO
68	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	280	7434900	7434900	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	0	0	0	Under maint.
70	Ashuganj 420 MW CCPP(East)	APSCL	284'1+116'1	400	401	8300200	8300200	
71	Ashuganj 50 MW PP	APSCL	14'3.968	45	20	868248	868248	Gas shortage
72	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	5	287040	287040	Gas shortage
73	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	8	234181	234181	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1035327	1035327	
75	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	150	1659345	1659345	
76	Titas 50 MW Peaking PP	PDB	6'8.92	52	34	282192	282192	Engine problem
77	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	0	Under maint.
78	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	100	1147680	1147680	Fuel shortage
79	Feni 22MW PP (Doreen)	SIIPP, PDB	8'2.90	22	15	399708	399708	Engine problem
80	Feni 11 MW PP (Doreen)	SIIPP, REB	4'2.90	11	9	243720	243720	Engine problem
**	Import (Tripura)	Imported power	0	160	110	2529600	2529600	
81	Jangalia 33MW PP (Summit)	SIIPP, PDB	4'8.73	33	33	785400	785400	
82	Jangalia 52 MW PP (Lakshnavi)	IPP	6'8.92	52	8	78235	78235	Fuel shortage
83	Cumilla 25 MW PP (Summit)	SIIPP, REB	3'3.67+2'6.97	25	21	479260	479260	Engine problem
84	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	0	Fuel shortage
85	Feni Lanka Power	IPP	7'18.415+1'9.78	114	80	660600	660600	Fuel shortage
86	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	87	708960	708960	Fuel shortage
87	Bharob 54.5 MW	IPP	3'18.2	54	0	251640	251640	Engine problem
88	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	72	827520	827520	Fuel shortage
Cumilla Area Total				3285	1666	32792416		
89	RPCL 210MW CCPP	IPP	4'35+1'70	202	49	1249920	1249920	Gas shortage
90	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8'2.90	22	19	413856	413856	Engine problem
91	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	0	Under maint.
92	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	12650	12650	
93	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	97	1699200	1699200	Fuel shortage
94	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	56	584400	584400	Fuel shortage
95	Sutiakhali 50 MW Solar PP	IPP	50	50	0	320020	320020	
96	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	6	124080	124080	Engine problem
Mymensingh Area Total				614	227	4404126		
97	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	42	1000000	1000000	Machine problem
98	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	42	770400	770400	Machine problem
99	Kushara 163 MW CCPP (KP)	IPP	1'109+1'54	163	112	2425963	2425963	ST under maint.
100	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	0	Under maint.
101	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	39	851400	851400	Gas shortage
102	Fenchuganj 44MW PP (Energyprima)	NENP	12'3.3+5'2	50	40	953496	953496	Gas shortage
103	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4'2.90	11	8	192384	192384	Engine problem
104	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	62	1321344	1321344	
105	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	86	1741440	1741440	
106	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	0	Under maint.
107	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	211	5159170	5159170	Machine problem
108	Sylhet 20 MW GTTP	PDB	1'20	20	18	440000	440000	
109	Sylhet 50MW PP (EPL)	NENP	2'72	0	0	0	0	Gas shortage
110	Shajibahanulla 25 MW PP	SIIPP, REB	3'9.34	25	8	173856	173856	Gas shortage
111	Bitiyana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	300	7030000	7030000	FGMO
112	Bitiyana-III 400 MW CCPP	PDB	285'1+134'1	400	368	8954000	8954000	FGMO
113	Sylhet 10MW PP (Desh)	RPP	6'11					