

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Monday				Date : 06.03.23				
Probable Maximum Demand : 12500 MW					Probable Maximum Generation : 12936 MW					Rule Curve = 92.20 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 79.03 ft		Today = 78.91 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.03.23 (Yesterday)		06.03.23 (Today)		05.03.23 (Yesterday)		06.03.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	124	130	130				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	336	333	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	369	378	395	395				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	158	195	120	120	15		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under Maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	268	275	270	270	60		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	4	40	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	67	67	24	64				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
17	Summit Power(Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	45	49	48	51				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	30	30				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	49	25	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	55	95	52	95				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	98	32	98				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	34	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	250	285	285				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	113	141	90	135				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	17	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	74	55	72				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	144	17	144				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	18	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	37	60	40	60				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	32	61	60	60				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	30	67	67				
Dhaka Zone Total					6004	5847	2785	3304	2891	3358	288	1075	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	21	25	17	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	20	20				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	225	227	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	116	257	120	260				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	75	100	50	100				
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	62	51	68				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	30	61	40	60				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	12	15	15	10		Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	47	54	54	54				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	30	100	100	100				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	55	72	55	72				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	89	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total					2442	2382	856	1178	960	1206	390	330	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	47	44	44				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	216	197	190	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	285	280	360	360				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	300	318	350	350				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	40	53	50	50				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	40	150	40	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	24	28	30				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	173	100	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	19	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	9	0	16				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+60x1.015+10x1.08	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	80	17	80				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	105	9	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	20	68	18	72				
**	Import (Tripura)	India		160	160	128	140	135	153				
Cumilla Zone Total					3309	3285	1376	1797	1502	1989	681	163	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	48	80	50	100	122		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	19	19				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	79	40	75				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	77	115	68	115				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	242	300	235	315	122	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.03.23 (Yesterday)		06.03.23 (Today)		05.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)						
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	6	43	43	43		27	GT-1 & ST-1 Under maint.					
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	30	30		59	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	30	50								
91	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	80	80		54	ST Under maint.					
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8								
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	64	64	64								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	209	210	215	215								
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	0	0								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8								
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	300	300								
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	368	369	366	367								
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	0	0	0								
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	45	49	30	50								
Sylhet Zone Total						2472	2427	1634	1297	1268	1309	0	570				
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	175	130	150	150		280	Gas Shortage					
107	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38								
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75								
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0								
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	30	56	56	56								
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100								
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0								
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	49	97	49	99								
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	8	40								
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	370	518	370	400								
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				0	0	0	0								
**	Bheramara (H/DC)	India		1000	1000	889	769	892	892								
Khulna Zone Total						3005	3001	1605	1610	1625	1850	280	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	22	15	22								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	176	158	180	185								
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	740	760	790	790								
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0								
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	151	150	150	200								
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	218	220	220								
Barisal Zone Total						2265	2265	1305	1308	1355	1417	0	0				
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage					
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	30	32	0	30								
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	25	18	20								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	63	82	62	82								
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	32	40								
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	16	42	42								
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	27	27	26	35								
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage					
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	130	130		220	Gas Shortage					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	141	126	0	94			Gas Shortage					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	315	245	400	400		169	Gas Shortage					
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	21	22	22								
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8								
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	75	113	77	113								
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	70	95	50	94								
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0								
Adani Power Jharkhanda Ltd								0	0	0	0						
Rajshahi Zone Total						2129	2129	795	833	884	1027	864	0				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24	Coal Shortage					
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	68	100	50	100								
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0								
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	75	35	115								
149	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0								
	Teesha Solar Limited	Solar (IPP)				111	0	130	0								
Rangpur Zone Total						830	750	498	425	503	465	109	85				
Sub-total: Plants in operation						23078	22700	11096.0	12052	11223	12936	2734	2223				
(B) Plants under long term maintenance/ contract expired																	
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0								
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0						
Gross Total						23482	22700	11096	12052	11223	12936	2734	2223				
(C) Actual data of 05.03.23 (Yesterday) Sunday :																	
01.	Max. Demand at eve. peak (Generation end)	:	12308 MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	11869 MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed					
03.	Highest Generation (Generation end)	:	12052 MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW					
04.	Minimum Generation (Generation end)	:	8502 MW, at =	5:00 hrs	Dhaka	4381	4352	29	Mymensingh	1074	954	120					
05.	Day-peak Generation (Generation end)	:	11096 MW, at =	12:00 hrs	Chattogram	1074	1074	0	Sylhet	428	419	9					
06.	Evening-peak Generation (Generation end)	:	12052 MW, at =	19:00 hrs	Khulna	1466	1466	0	Barisal	303	303	0					
07.	Evening Peak Load-shed (Sub-station end)	:	236 MW, at =	19:00 hrs	Rajshahi	1253	1175	78	Rangpur	778	778	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8777 MW, at =	5:00 hrs	Cumilla	1112	1112	0									
09.	Generation shortfall at evening peak due to :	:			Total					11869	11633	236					
a)	Gas/LF limitation	:	2425 MW		(a) Gas = 150944048 Taka				(c) Coal = 213520109 Taka								
d)	Coal supply Limitation	:	109 MW		(b) Oil = 591587008 Taka				Total = 956051166 Taka								
b)	Low water level in Kaptai lake	:	200 MW														
c)	Plants under shut down/ maintenance	:	2223 MW														
10.	Total Energy (Generation + India Import)	:	254.91 MKWh		Maximum Temperature in Dhaka was : 34.0° C												
	By Gas = 140.180 MKWh		By Oil = 44.999 MKWh		Export through East-West interconnections :												
	By Coal = 43.017 MKWh		By Hydro = 0.698 MKWh		At evening peak-hour												
	By Solar = 2.157 MKWh				Maximum												
					Energy												
11.	Total Gas Supplied	:	1074.93 MMCFD														
(D) Forecast of 06.03.23 (Today) Monday :																	
01.	Maximum Demand	:	12500 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)											
02.	Maximum Generation	:	12936 MW (Generation end)		05.	Total Generation : 264.39 MKWh											
03.	Reserve / Shortage	:	436 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 35.5° C											