

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Wednesday				Date : 08.03.23				
Probable Maximum Demand : 12000 MW					Probable Maximum Generation : 13507 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 78.79 ft		Today = 78.67 ft		Rule Curve = 91.88 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.03.23 (Yesterday)		08.03.23 (Today)		07.03.23 (Yesterday)		08.03.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	53	53	52	52	55		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	282	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	225	250	450		225	Under Maint.	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	307	352	350	400				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	157	76	100	100	134		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under Maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335	Under Maint.	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	66	24	65				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	15	22				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	48	43	49	49				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	49	25	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	105	52	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	98	32	98				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	294	225	295	300				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	82	117	90	135				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	55	55	55				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	17	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	65	40	65				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	48	72	50	72				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	85	70	85	80				
Dhaka Zone Total			6004	5847	2785	2669	2423	3183	294	1635			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	140	140	140	40		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	17	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	227	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	124	223	120	260				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	51	76	80	80				
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	82	51	82				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	48	6	40	65				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12	10		Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	5	5				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	28	36	17	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	78	88	80	80				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	54	70	55	72				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	89	89	89				
**	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total			2442	2382	997	1206	1088	1303	255	330			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	43	45	44	44				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	195	220	220	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	285	300	330				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	350	300	330	330				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	40	40	40	40	15		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	123	135	40	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	22	0	28	30				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	166	155	100	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	3	0	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	80	17	80				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	105	9	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	72	18	72				
**	Importo (Tripura)	India		160	160	140	146	135	153				
Cumilla Zone Total			3309	3285	1593	1733	1428	1917	696	163			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	48	98	100	100	104		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	84	94	40	94				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	163	155	150	150				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	50	0	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total			622	614	369	367	364	366	104	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.03.23 (Yesterday)		08.03.23 (Today)		07.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44		26	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	28	28	11	28				
91	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	80	112		54	ST Under maint.	
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	40	64	64				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	89	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	206	210	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	6	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	270	300	300				
101	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	366	366	370				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	260	400		383	Under maint.	
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	45	50	10	50				
Sylhet Zone Total						2472	2427	1325	1255	1515	1748	0	941
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	170	240	320	320		170	Gas Shortage	
107	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	55	56	56				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	86	0	100	0				
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	49	96	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	24	32	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	371	500	370	400				
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	879	805	895	895				
Khulna Zone Total						3005	3001	1615	1743	1815	2023	170	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	20	20	20				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	174	179	185	185				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	780	790	750	800				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	142	142	150	200				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	219	172	200	220				
Barishal Zone Total						2265	2265	1332	1303	1305	1425	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	33				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	64	85	50	85				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	30	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	8	42	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	34	26	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	170	175	150	175		45	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	368	279	380	380		135	Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	21	21	21				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	75	95	77	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	62	50	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Adani Power Jharkhanda Ltd								0	0				
Raishahi Zone Total						2129	2129	860	816	871	1077	781	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	98	50	100				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	63	35	115				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
Teesta Solar Limited								150	0	130	0		
Rangpur Zone Total						830	750	474	411	503	465	109	85
Sub-total: Plants in operation						23078	22700	11350.0	11503	11312	13507	2409	3154
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0				
Gross Total						23482	22700	11350	11503	11312	13507	2409	3154
(C) Actual data of 07.03.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	11568	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11148	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11553	MW, at =	13:00 hrs	Dhaka	3868	3868	0	Mymensingh	1066	1006	60
04.	Minimum Generation (Generation end)	:	8854	MW, at =	5:00 hrs	Chattogram	1052	1052	0	Sylhet	416	416	0
05.	Day-peak Generation (Generation end)	:	11350	MW, at =	12:00 hrs	Khulna	1375	1375	0	Barishal	310	310	0
06.	Evening-peak Generation (Generation end)	:	11503	MW, at =	19:00 hrs	Rajshahi	1228	1228	0	Rangpur	769	769	0
07.	Evening Peak Load-shed (Sub-station end)	:	60	MW, at =	19:00 hrs	Cumilla	1064	1064	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7839	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :												
	a) Gas/LF limitation	:	2095	MW		13.	Fuel cost :	(a) Gas = 149873758 Taka	(c) Coal = 214565500 Taka				
	d) Coal supply Limitation	:	109	MW			b) Oil = 643169076 Taka	Total = 1007608334 Taka					
	b) Low water level in Kaptai lake	:	205	MW									
	c) Plants under shut down/ maintenance	:	3154	MW		14.	Maximum Temperature in Dhaka was : 34.4° C						
10.	Total Energy (Generation + India Import)												
	By Gas = 135.920 MKWh	By Oil = 48.845 MKWh			15.	Export through East-West interconnections :							
	By Coal = 38.911 MKWh	By Hydro = 0.652 MKWh				At evening peak-hour : 11350 MW, at 19:00 hrs							
	By Solar= 2.673 MKWh					Maximum : 326 MW, at 22:00 hrs							
						Energy : 0 MKWh							
11.	Total Gas Supplied : 1052.83 MMCFD												
(D) Forecast of 08.03.23 (Today) Wednesday :													
01.	Maximum Demand	:	12000	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	13507	MW (Generation end)	05.	Total Generation : 260.57 MKWh							
03.	Reserve / Shortage	:	1507	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 34.2° C							