

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Friday					Date : 10.03.23				
Probable Maximum Demand : 11500 MW					Probable Maximum Generation : 14059 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 78.55 ft		Today = 78.31 ft		Rule Curve = 91.56 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.03.23 (Yesterday)		10.03.23 (Today)		09.03.23 (Yesterday)		10.03.23 (Today)			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date			
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	44	52	44	52	56		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	345	352	352	352					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	365	394	400	400					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	120	182	100	100	28		Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under Maint.		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	290	280	150	150	55		was under Maint.		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	65	16	65					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	19					
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	51	53	53					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	24	25	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	52	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	64	98	133					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	148	280	300					
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	114	142	90	142					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	0 25x1.4	300	300	0	0	0	0					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	73	55	72					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	24	60	40	65					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	8	53	50	68					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	27	57	85	85					
Dhaka Zone Total					6004	5847	2591	3291	2888	3416	189	1130		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	140	140	140	140	40		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0					
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	17	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	224	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	150	120	260					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	100	80	80					
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	45	68	51	82					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	45	47	40	65					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	12	12	12	10		Gas Shortage		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	2	2					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	17	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	55	54	54					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	29	87	80	80					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	70	44	44					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test		
Chattogram Zone Total					2442	2382	951	1198	1092	1308	255	330		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	46	44	44	44					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	215	177	200	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	280	300	300					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	320	320	330	350					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	54	54	54					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	43	43					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	40	150					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	28	30					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	84	126	100	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	11	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	22	0	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+60x1.015+10x1.08	200	200	0	0	0	0					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	17	80					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	86	9	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	44	72	18	72					
**	Import (Tripura)	India		160	160	146	150	135	153					
Cumilla Zone Total					3309	3285	1305	1469	1422	1901	681	163		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	148	108	130	130	94		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	16	16					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	85	94	95	94					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	136	155	150	150					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0					
87	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	6	6	6					
Mymensingh Zone Total					622	614	435	380	449	396	94	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.03.23 (Yesterday)		10.03.23 (Today)		09.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	44	44		26	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	25	25	25				
91	Kushihara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	80	112		54	ST Under maint.	
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	67	64	64				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	86	86	86				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	205	210	210	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	300	300				
101	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	368	366	366				
102	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	388	370	260	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	43	46	20	20				
Sylhet Zone Total						2472	2427	1637	1702	1539	1711	17	558
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	250	380	410	410	30		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75				
109	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	40	56	56				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	49	0	100	0				
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	16	83	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	373	369	370	370				
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	879	736	890	890				
Khulna Zone Total						3005	3001	1603	1616	1900	2046	30	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	21	20	20				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	160	172	185	185				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	580	820	750	800				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	142	142	150	150				
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	194	221	220	220				
Barishal Zone Total						2265	2265	1090	1376	1325	1375	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	39	18	33				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	41	51	50	85				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	25	42	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	20	33	26	35				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	201	200	200	19		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	423	0	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	21	21				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	77	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	113	50	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Adani Power Jharkhanda Ltd							0	350	350				
Rajshahi Zone Total						2129	2129	736	676	1281	1481	620	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	78	100	50	100				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	88	35	115				
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
	Teesha Solar Limited	Solar (IPP)				141	0	130	0				
Rangpur Zone Total						830	750	494	388	453	415	159	85
Sub-total: Plants in operation						23078	22700	10842.0	12096	12359	14059	2045	2266
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PPI(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0				
Gross Total						23482	22700	10842	12096	12359	14059	2045	2266
(C) Actual data of 09.03.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	12284	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11928	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12096	MW, at =	19:00 hrs	Dhaka	4375	4375	0	Mymensingh	1098	943	155
04.	Minimum Generation (Generation end)	:	8274	MW, at =	5:00 hrs	Chattogram	1142	1142	0	Sylhet	440	440	0
05.	Day-peak Generation (Generation end)	:	10842	MW, at =	12:00 hrs	Khulna	1387	1387	0	Barishal	302	302	0
06.	Evening-peak Generation (Generation end)	:	12096	MW, at =	19:00 hrs	Rajshahi	1308	1308	0	Rangpur	829	829	0
07.	Evening Peak Load-shed (Sub-station end)	:	155	MW, at =	19:00 hrs	Cumilla	1047	1047	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8757	MW, at =	5:00 hrs	Total				11928	11773	155	
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost : (a) Gas = 165668107 Taka (b) Oil = 440600473 Taka				(c) Coal = 18964526 Taka Total = 795933106 Taka			
a) Gas/LF limitation	:	1681	MW										
d) Coal supply Limitation	:	159	MW										
b) Low water level in Kaptai lake	:	205	MW										
c) Plants under shut down/ maintenance	:	2266	MW										
10.	Total Energy (Generation + India Import)	:	249.02	MKWh		14. Maximum Temperature in Dhaka was : 33.5° C							
	By Gas = 152.874 MKWh			By Oil = 33.605 MKWh		15. Export through East-West interconnections : At evening peak-hour : 10842 MW, at 19:00 hrs Maximum : 22 MW, at 18:30 hrs Energy : 0 MKWh							
	By Coal = 35.824 MKWh			By Hydro = 0.604 MKWh									
	By Solar = 2.383 MKWh												
11.	Total Gas Supplied	:	1169.05	MMCFD									
(D) Forecast of 10.03.23 (Today) Friday :													
01.	Maximum Demand	:	11500	MW (Generation end)		04.	Maximum Load-shed	:	0	MW At evening peak (Sub-station end)			
02.	Maximum Generation	:	14059	MW (Generation end)		05.	Total Generation	:	236.75	MKWh			
03.	Reserve / Shortage	:	2559	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.8° C				