

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Monday				Date : 13.03.23			
Probable Maximum Demand : 12900 MW					Probable Maximum Generation : 13158 MW				Rule Curve = 91.08 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 78.04 ft				Today = 77.85 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.03.23 (Yesterday)		13.03.23 (Today)		12.03.23 (Yesterday)		13.03.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date	
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	63	61	52	61	47		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	245	322	300	322			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	386	380	386			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	62	97	80	97	113		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	220	170	170	170			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	288	279	290	280			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	67	75	40	75			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	22			
17	Summit Power(Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	41	48	48	48			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	28	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	49	25	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	90	52	90			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	98	98	98			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	173	275	270	275			
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	115	147	90	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	73	55	73			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	50	162	17	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	90	90	40	90			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	71	74	50	74			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	50	80	80			
Dhaka Zone Total					6004	5847	3108	3586	3118	3625	265	740
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	140	140	140	140	40		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	17	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	221	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	123	225	120	230			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	100	80	100			
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	85			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	62	40	62			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	7	7	7	15		Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	35	17	35			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	65	54	65			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	76	83	60	83			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	53	44	53			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	106	89	89	89			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	923	1268	1047	1277	260	330
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	43	46	44	46			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	217	191	180	190			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	275	305	280	305			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	300	300	320	320			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	20	20	20	20			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	55	115	40	130			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	3	0	20			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	100	100	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	16	0	16			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	51	98	17	98			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	110	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	26	72	18	72			
**	Import (Tripura)	India		160	160	154	164	135	153			
Cumilla Zone Total					3309	3285	1376	1669	1310	1730	681	163
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	100	94	100	102		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	16	16	16			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	84	94	95	94			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	134	153	150	153			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	6	6			
Mymensingh Zone Total					622	614	319	369	413	369	102	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.03.23 (Yesterday)		13.03.23 (Today)		12.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	44	44		27	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	53	53				
91	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	89	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	198	191	200	200				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	8	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	270	300				
101	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	368	366	368				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	44	49	50	50				
Sylhet Zone Total						2472	2427	1691	1711	1688	1720	17	601
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	35				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	25	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	26	55	55				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	86	0	100	0				
114	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	32	85	66	85				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	32	8	32				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	374	497	400	400				
	Khulna 330 MW CCPP	Gas/HSD (BFPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	882	788	899	899				
Khulna Zone Total						3005	3001	1391	1503	1528	1681	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	19	15	20				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	171	164	171	170				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	820	860	800	900				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	171	189	171	190				
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barisal Zone Total						2265	2265	1177	1232	1157	1280	0	220
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	18	30				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	32	86	50	86				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	8	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	23	29	26	30				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	161	190	180	190	30		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	423	430	400	414				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	21	22	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	2	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	113	109	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	94	80	94	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Rajshahi Zone Total						2129	2129	893	1046	964	1112	631	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	69	92	70	92				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	35	72				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
	Teesa Solar Limited	Solar (IPP)				144	0	130	0				
Rangpur Zone Total						830	750	454	364	473	364	159	85
Sub-total: Plants in operation						23078	22700	11332.0	12748	11698	13158	2525	2139
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0				Contract Expired on 11/01/2022
Gross Total						23482	22700	11332	12748	11698	13158	2525	2139
(C) Actual data of 12.03.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	12829	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12459	MW, at =	19:00 hrs								
03.	Highest Generation (Generation end)	:	12748	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
04.	Minimum Generation (Generation end)	:	8688	MW, at =	5:00 hrs	Dhaka	4618	4618	0	Mymensingh	1090	1015	75
05.	Day-peak Generation (Generation end)	:	11332	MW, at =	12:00 hrs	Chattogram	1208	1208	0	Sylhet	463	463	0
06.	Evening-peak Generation (Generation end)	:	12748	MW, at =	19:00 hrs	Khulna	1416	1416	0	Barisal	333	333	0
07.	Evening Peak Load-shed (Sub-station end)	:	75	MW, at =	19:00 hrs	Rajshahi	1351	1351	0	Rangpur	847	847	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9159	MW, at =	5:00 hrs	Cumilla	1133	1133	0				
09.	Generation shortfall at evening peak due to :	:				Total				12459	12384	75	
	a) Gas/LF limitation	:	2161	MW		13. Fuel cost : (a) Gas = 159529055 Taka (c) Coal = 220702783 Taka (b) Oil = 61558715 Taka Total = 995790554 Taka							
	d) Coal supply Limitation	:	159	MW									
	b) Low water level in Kaptai lake	:	205	MW		14. Maximum Temperature in Dhaka was : 34.9° C							
	c) Plants under shut down/ maintenance	:	2139	MW									
10.	Total Energy (Generation + India Import)	:	260.83	MKWh		15. Export through East-West interconnections : At evening peak-hour : 11332 MW, at 19:00 hrs Maximum : 100 MW, at 18:00 hrs Energy : 0 MKWh							
	By Gas = 146.111 MKWh			By Oil = 47.029 MKWh									
	By Coal = 40.377 MKWh			By Hydro = 0.615 MKWh									
	By Solar= 2.565 MKWh												
11.	Total Gas Supplied	:	1126.79	MMCFD									
(D) Forecast of 13.03.23 (Today) Monday :													
01.	Maximum Demand	:	12900	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13158	MW	(Generation end)	05.	Total Generation	:	263.94	MKWh			
03.	Reserve / Shortage	:	258	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	36.1° C				