

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023				Day : Tuesday				Date : 14.03.23				
Probable Maximum Demand : 13200 MW				Probable Maximum Generation : 13336 MW				Rule Curve = 90.92 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 77.85 ft		Today = 77.69 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.03.23 (Yesterday)		14.03.23 (Today)		13.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	328	325	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	404	381	380	386			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	98	92	92	97	118		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	215	220	230	230			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	271	265	270	270			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	75	75	75	75			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	48	48	48			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	30	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	90	52	90			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	115	82	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	210	300	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	115	135	118	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	72	55	73			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	126	90	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	68	89	90	90			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	40	62	50	62			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	80	80	80			
Dhaka Zone Total					6004	5847	3320	3578	3388	3664	319	740
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	140	140	140	140	40		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	0	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	18	25	17	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	34	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	223	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	120	225	120	230			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	80	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	44	85	51	85			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	54	42	40	62			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	7	7	17		Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	35	17	35			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	72	54	72			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	61	81	60	83			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	65	44	53			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	90	90	90			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	1014	1283	1048	1302	262	330
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	44	44	44			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	178	180	180	180			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	305	305	280	305			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	80	320	320			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	35	52	20	20			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	75	120	8	120	75		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	46	132	40	130			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	23	0	20			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	97	100	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	16			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	51	52	17	98			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	113	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	54	17	54			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	72	18	72			
**	Import (Tripura)	India		160	160	158	154	135	153			
Cumilla Zone Total					3309	3285	1141	1600	1310	1867	569	163
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	59	60	100	143		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	16	16	16			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	84	94	95	94			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	144	155	150	155			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total					622	614	329	330	373	371	143	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.03.23 (Yesterday)		14.03.23 (Today)		13.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening								
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	44	44		28	GT-1 & ST-1 Under maint.					
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	53	53								
91	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.					
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	64	65	65								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	86	86								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	151	140	82	82								
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	8	8	8								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	290	270	300								
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	369	368	366	368								
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	400	400	400								
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	46	47	50	50								
Sylhet Zone Total						2472	2427	1621	1626	1552	1584	17	602				
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage					
107	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	20	0	35								
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	0	75								
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0								
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	45	55	55								
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	105	0	100								
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	88	0	100	0								
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	16	88	66	85								
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	8	32								
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	367	495	400	400								
	Khulna 330 MW CCPP	Gas/HSD (BIFD)				0	0	0	0								
**	Bheramara (H/VC)	India		1000	1000	885	861	902	902								
Khulna Zone Total						3005	3001	1356	1668	1531	1684	410	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	0								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	22	15	20								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	171	171	171	170								
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	850	830	900	900								
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	9	0	0								
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	288	280	280								
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.					
Barisal Zone Total						2265	2265	1289	1336	1366	1370	0	220				
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32								
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	33	18	30								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	84	50	86								
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	32	40								
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	8	42								
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	26	30								
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage					
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	212	194	180	190	26		Gas Shortage					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	390	429	400	414								
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	21	22	22								
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11								
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8								
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	15	113	109	113								
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	87	94	94								
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0								
Adani Power Jharkhanda Ltd							249	0	0	0							
Rajshahi Zone Total						2129	2129	934	1111	964	1112	627	0				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	210	200	210	64		Coal Shortage					
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	106	70	100								
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0								
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	73	35	72								
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0								
Teesta Solar Limited							136	0	130	0							
Rangpur Zone Total						830	750	471	389	473	382	149	85				
Sub-total: Plants in operation						23078	22700	11475.0	12921	12005	13336	2496	2140				
(B) Plants under long term maintenance/ contract expired																	
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0								
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0							
Gross Total						23482	22700	11475	12921	12005	13336	2496	2140				
(C) Actual data of 13.03.23 (Yesterday) Monday :																	
01.	Max. Demand at eve. peak (Generation end)	:	13046	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	12606	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	12921	MW, at =	19:00 hrs	Dhaka	4580	4570	10	Mymensingh	1127	1022	105				
04.	Minimum Generation (Generation end)	:	9159	MW, at =	5:00 hrs	Chattogram	1175	1175	0	Sylhet	485	485	0				
05.	Day-peak Generation (Generation end)	:	11475	MW, at =	12:00 hrs	Khulna	1465	1465	0	Barisal	330	330	0				
06.	Evening-peak Generation (Generation end)	:	12921	MW, at =	19:00 hrs	Rajshahi	1376	1376	0	Rangpur	910	910	0				
07.	Evening Peak Load-shed (Sub-station end)	:	115	MW, at =	19:00 hrs	Cumilla	1160	1160	0								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9283	MW, at =	5:00 hrs												
09.	Generation shortfall at evening peak due to :	:				Total				12606	12491	115					
	a) Gas/LF limitation	:	2142	MW		13. Fuel cost : (a) Gas = 158851498 Taka (b) Oil = 658081848 Taka				(c) Coal = 223264580 Taka Total = 1040197926 Taka							
	d) Coal supply Limitation	:	149	MW													
	b) Low water level in Kaptai lake	:	205	MW		14. Maximum Temperature in Dhaka was : 34.8° C											
	c) Plants under shut down/ maintenance	:	2140	MW													
10.	Total Energy (Generation + India Import)	:	265.16	MKWh		15. Export through East-West interconnections : At evening peak-hour : 11475 MW, at 19:00 hrs Maximum : 100 MW, at 18:00 hrs Energy : 0 MKWh											
	By Gas = 142.406 MKWh																
	By Coal = 45.237 MKWh																
	By Solar= 2.421 MKWh																
11.	Total Gas Supplied	:	1111.37	MMCFD													
(D) Forecast of 14.03.23 (Today) Tuesday :																	
01.	Maximum Demand	:	13200	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	13336	MW (Generation end)		05.	Total Generation	:	270.88	MKWh							
03.	Reserve / Shortage	:	136	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :		35.9° C								