

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	125	1318187	Gas shortage
3	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
4	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
5	Ghorasal 108MW PP (Regent)	IPP	34.3 35	108	14	550954	Gas shortage
6	Haripur GTPP	SBU, PDB	232	0	0	0	Under maint.
7	Haripur 412 MW CCGP	EGCB	1273+1139	412	411	9281530	
8	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	337	7516000	Gas shortage
9	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	450	9894250	
10	Meghnaghat 100 MW(IEI)	NENP	12*9	100	90	1713600	Fuel shortage
11	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	295	6803316	FGMO
12	Madanaghat 102 PP(Summit)	NENP	6*17	102	80	1445332	Engine problem
13	Madanaghat-55 MW PPS(Summit)	IPP	3*17.08+11*1.3	55	55	1242650	
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	339516	
16	210 MW Siddhirganj TPP	PDB	1210	115	0	0	Under maint.
17	Siddhirganj 2120 MW GTPP	EGCB	2105	210	101	1314000	Gas shortage
18	Siddhirganj 100 PP(Dutch) Bangla	NENP	12*8	100	89	1362010	Engine problem
19	Siddhirganj 335 MW CCGP	EGCB	1217+118	335	229	5200093	ST U/M
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	92	1501632	Engine problem
21	Katipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	324360	
23	Kodda 150 MW PP	BPDB-RPCL	9*17.08	115	149	1336160	Fuel shortage
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	470868	Fuel shortage
25	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	473471	Fuel shortage
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	42	1001820	Engine problem
28	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	782800	
29	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*8.73	30	30	751800	
30	Gazipur 52 MW PP	RPCL	6*8.9	52	41	814080	Engine problem
31	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	288	2704800	Engine problem
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Fuel shortage
34	Bramhanaga 100 MW PP (Aggreko)	IPP	11*19.959	100	0	0	Fuel shortage
35	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Fuel shortage
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	121	1114272	Fuel shortage
37	Gazipur 100 MW PP	RPCL	6*17.5	105	100	1508160	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	73	1508160	Fuel shortage
39	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	2183040	
40	Spectro Solar Plant Ltd.	IPP	35	35	0	129683	
41	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	17	109440	Fuel shortage
Dhaka area Total				5847	3698	70619664	
41	Chattoagram TPP-1	PDB	1210	180	135	320000	Gas shortage
42	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
43	Raazon 25 MW PP	RPCL	3*8.9	25	15	416169	
44	Tafal 20MW PP (Sadarlech)	IPP	20	20	0	107055	
45	Palenga 50MW PP (Baraka)	IPP	8*6.98	50	19	461760	Fuel shortage
46	Kapila Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	25	604200	Low water level
47	Sikalbaha 225MW	PDB	1*150+1*75	225	227	5355990	
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	45	1081345	Fuel shortage
50	Hathazari 100 MW peaking PP	PDB	11*9.9	102	98	425328	Engine problem
51	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	85	998576	Engine problem
52	Jullaha 100 MW Unit-1 (Accom)	NENP	8*13.45	100	65	1264440	Fuel shortage
53	Jullaha 100 MW PP Unit-3 (Accom)	IPP	8*13.5	100	100	1838400	
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	6*2.90	22	5	103776	Gas shortage
55	Manarcho. Ch. EPZ Unit-1	IPP	5*8.73+9.34	0	0	36000	
56	Chattoagram 108 MW PP (ECPV)	PDB	16*7	108	0	0	Fuel shortage
57	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	21359	
58	Anwara 300 MW PP (United)	IPP	17*17+24	300	223	3226200	Fuel shortage
59	Jodiach Power	IPP	3*18.55+1*3.6	54	35	681459	Fuel shortage
60	Kanaphuli Power Ltd.	IPP	18.45*6+8.5	110	90	1665193	Fuel shortage
61	Jullaha unit-2 (Accom)	IPP	8*13.6	100	54	1460160	Engine problem
62	Anlima Energy Ltd.	IPP	6*21.2	116	108	2354782	Fuel shortage
63	Minshahi 150 MW	BPDB-RPCL	18.5*9	0	0	0	On test.
Chattoagram area Total				2382	1267	25265192	
61	Ashuganj TPP Unit- 3	APSCL	1150	0	0	0	Contract Expired
62	Ashuganj TPP Unit- 4	APSCL	1150	0	0	0	Contract Expired
63	Ashuganj TPP Unit- 5	APSCL	1150	134	0	0	Gas shortage
64	Ashuganj 225 MW CCGP	APSCL	11142+1175	221	168	4581000	Gas shortage
65	Ashuganj 450 MW CCGP(North)	APSCL	1360	360	290	7245700	Gas shortage
66	Ashuganj 450 MW CCGP(South)	APSCL	1360	360	0	0	Under maint.
67	Ashuganj 420 MW CCGP(East)	APSCL	284*1+116*1	400	330	7629500	Gas shortage
68	Ashuganj 50 MW PP	APSCL	14*3.968	45	50	1128944	
69	Ashuganj 45 MW PP (Precision)	QRPP	15*4	55	35	6922320	Gas shortage
70	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	200727	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	841550	Engine problem
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	130	1446909	Fuel shortage
73	Titas 50 MW Peaking PP	PDB	6*8.92	52	21	232368	Engine problem
74	Chandpur 150 MW CCGP	PDB	11*106+1*57	163	0	0	Under maint.
75	Chandpur 200MW (Desh energy)	IPP	12*12.4	200	100	974880	Fuel shortage
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	483876	
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	237240	
78	Import (Tripura)	Imported power	0	160	154	3101760	
79	Jangjala 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	808900	
80	Jangjala 50 MW PP (Lakshmi)	IPP	8*6.982	52	8	53237	
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	15	303740	Fuel shortage
82	Daudkandi 200 MW PP (B.Trac)	IPP	15*1.4	200	0	0	Fuel shortage
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	197220	Fuel shortage
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	83	693840	Engine problem
85	Bharob 54.5 MW	IPP	3*18.2	54	17	242280	Engine problem
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	94	1358360	Fuel shortage
Cumilla Area Total				3285	1627	32653351	
87	RPCL 210MW CCGP	IPP	4*35+1*70	202	46	1254720	Gas shortage
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	437544	Engine problem
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	9150	
91	Mymensingh 200 MW PP (United)	IPP	9*78*21	150	200	2323200	
92	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	113	1617000	Fuel shortage
93	Suliakhali 50 MW Solar PP	IPP	50	50	0	190200	
94	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	5	23760	Engine problem
Mymensingh Area Total				614	333	5856174	
91	Fenchuganj CCGP Phase-1	PDB	2*32+1*33	70	44	1026000	Machine problem
92	Fenchuganj CCGP Phase-2	PDB	2*35+1*35	90	43	693040	Machine problem
93	Kushara 183 MW CCGP (KP)	IPP	1100+1154	163	112	2250654	ST U/M
94	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakattullah)	RPP	19*2.90	51	51	1203600	
96	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5.2	50	47	1151208	
97	Haldiganj 1 MW PP (Confidence-E)	SIPP, REB	4*2.90	11	8	139300	Engine problem
98	Shahjibazar GTTP Unit- 3 & 9	PDB	2*35	86	84	1487120	
99	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	89	2012160	
100	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
101	Sylhet 225 MW CCGP	PDB	1142+1189	231	140	3369380	Machine problem
102	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Engine problem
103	Sylhet 50MW PP (EPZ)	NENP	2*7	0	0	0	Gas shortage
104	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	186940	Gas shortage
105	Bitiana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	290	6776500	FGMO
106	Bitiyana-III 400 MW CCGP	PDB	285*1+134*1	400	368	8888000	FGMO
107	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	8	194400	Engine problem
108	Bitiyana South 400 MW	PDB	400 MW	383	400	9249200	
Sylhet Area Total				2427	1672	38928202	
107	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
108	Bheramara (HVDC)	Imported power	2*500	1000	897	21687272	
109	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	93	1634880	Fuel shortage
110	Fardpur 50 MW Peaking PP	PDB	6*6.89	54	26	162720	
111	Khulna 225 MW CCGP	NWPGCL	1150+1175	230	0	0	Gas conservation
112	Casapara 100 MW Peaking PP	PDB	16*9.98	100	60	113792	Fuel shortage
113	Bheramara 410 MW CCGP	NWPGCL	1278+1132	410	0	0	Gas shortage
114	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	40	206250	
115	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve.
116	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	53	585120	Fuel shortage
117	Madhumati 100 MW PP	NWPGCL	6*18	105	67	656256	Transformer OIL
118	Mongia Orion 100 MW Solar PP	IPP	100	100	0	453600	
119	Khulna 330 MW CCGP (DIL)	BPDB	1220+1110	0	0	7276	On test.
120	Rampal 1320 MW (BIFPCL)	NTPCB&BPDB	660*2	617	0	5069091	Machine problem
121	Kulna 225 MW CCGP (GAS)	NWPGCL	0	0	85	2473920	
Khulna Area Total				3001	1321	32958977	
117	Baisaal 110 MW PP (Summit)	IPP	7*17.076	110	48	353964	Line OIL
118	Bhola 33 MW PP (Venture)	NENP	1*34.50	22	40	440440	Engine problem
119	Bhola 225 MW CCGP	PDB	2*63+1*68	194	154	41	