

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Saturday				Date : 18.03.23			
Probable Maximum Demand : 12000 MW					Probable Maximum Generation : 13034 MW				Rule Curve = 90.28 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 77.26 ft				Today = 77.10 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.03.23 (Yesterday)		18.03.23 (Today)		17.03.23 (Yesterday)		18.03.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date	
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	180	100	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	88	12	75	78	96		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	353	352	300	300			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	350	400	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	375	320	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	41	39	50	60	171		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	226	180	220	220			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	310	282	280	290			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	8	75	90			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	22	22			
17	Summit Power(Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	51	49	51			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	25	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	52	100			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	0	82	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	0	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	0	280	300			
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	91	115	36	115			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x1.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	17	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	55	73			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	72	90	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	10	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	16	8	90	90			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	0	80	80			
Dhaka Zone Total					6004	5847	2453	2495	3168	3638	372	740
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	135	130	135	135	50		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	3	0	5	0	0			
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	34	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	225	227	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	15	65	120	225			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	100	50	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	65			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	40			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5	17		Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	35	17	35			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	74	72	54	72			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	60	60	90			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	45	33	55	65			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	766	989	1048	1285	272	330
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	44	47	45	50			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	200	182	180	182			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	290	290	290			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	293	315	280	330			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	55	35	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	41	135	40	135			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	100	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	17	15	17			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	104	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	54			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	94	36	94			
**	Import (Tripura)	India		160	160	118	140	135	153			
Cumilla Zone Total					3309	3285	1263	1553	1314	1748	681	163
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	63	34	65	139		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	113	113	90	90			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	117	85	140	155			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	30	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total					622	614	312	286	335	335	139	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.03.23 (Yesterday)		18.03.23 (Today)		17.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	44	44	44		26	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	51	51	51				
91	Kushlara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	80	112		54	ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	40	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	8	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	255	300	300				
101	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	387	368	366	368				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	10	47	50	50				
Sylhet Zone Total						2472	2427	1564	1581	1649	1683	17	557
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	65				
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	125	130	130			Commissioning with Gas	
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	35	35				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	65	0	100	0				
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	16	16	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BFPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	900	775	917	917				
Khulna Zone Total						3005	3001	998	933	1256	1426	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	21	15	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	170	170	171	170				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	950	1150	1000	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	307	147	307				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	1286	1664	1333	1747	0	220
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	32				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	86				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	38	0	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	0	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	26	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	233	236	300	300				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	20	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	0	0	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	113	70	70	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	70	70	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Rajshahi Zone Total						2129	2129	580	398	645	815	821	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	42	85	70	85				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	36	0	72				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	31	0	30	0				
	Teesla Solar Limited	Solar (IPP)				137	0	130	0				
Rangpur Zone Total						830	750	415	321	438	357	159	85
Sub-total: Plants in operation						23078	22700	9637.0	10220	11186	13034	2871	2095
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Rimul 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0				
Gross Total						23482	22700	9637	10220	11186	13034	2871	2095
(C) Actual data of 17.03.23 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	10220 MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9731 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	10220 MW, at =	19:30 hrs	Dhaka	3564	3564	0	Mymensingh	634	634	0	
04.	Minimum Generation (Generation end)	:	7806 MW, at =	5:00 hrs	Chattogram	1149	1149	0	Sylhet	354	354	0	
05.	Day-peak Generation (Generation end)	:	9637 MW, at =	12:00 hrs	Khulna	1158	1158	0	Barishal	302	302	0	
06.	Evening-peak Generation (Generation end)	:	10220 MW, at =	19:30 hrs	Rajshahi	931	931	0	Rangpur	645	645	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs	Cumilla	994	994	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8023 MW, at =	5:00 hrs					Total	9731	9731	0	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 143856801 Taka (b) Oil = 398080585 Taka		(c) Coal = 251389777 Taka Total = 793327164 Taka				
a) Gas/LF limitation	:	2507 MW			14.	Maximum Temperature in Dhaka was : 28.5° C							
d) Coal supply Limitation	:	159 MW			15.	Export through East-West interconnections :							
b) Low water level in Kaptai lake	:	205 MW				At evening peak-hour	:	9637 MW, at	19:30 hrs				
c) Plants under shut down/ maintenance	:	2095 MW				Maximum	:	-124 MW, at	20:00 hrs				
10.	Total Energy (Generation + India Import)	:	226.44 MKWh			Energy	:	0 MKWh					
	By Gas = 134.429 MKWh		By Oil = 31.129 MKWh										
	By Coal = 34.810 MKWh		By Hydro = 0.603 MKWh										
	By Solar = 1.643 MKWh												
11.	Total Gas Supplied	:	1048.81 MMCFD										
(D) Forecast of 18.03.23 (Today) Saturday :													
01.	Maximum Demand	:	12000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	13034 MW (Generation end)		05.	Total Generation	:	265.88 MKWh					
03.	Reserve / Shortage	:	1034 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :		33.5° C					