

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Monday				Date : 20.03.23				
Probable Maximum Demand : 11500 MW					Probable Maximum Generation : 13735 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 76.98 ft		Today = 76.87 ft		Rule Curve = 89.96 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.03.23 (Yesterday)		20.03.23 (Today)		19.03.23 (Yesterday)		20.03.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	90	100	100				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	0	0	96		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	307	277	300	300				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	360	320	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	344	352	400	400				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	102	0	50	60	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	140	150	220	220				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	310	285	310	310				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	15	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	8	75	92				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	22	22				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	23	43	49	51				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	16	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	33	50	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	52	52	100				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	82	115				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	40	0	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	15	280	300				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	23	82	36	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	12	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	2	17	35				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	30	55	90				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	75	90	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	1	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	15	35	17	17				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	14	90	90				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	4	0	0				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	47	85	85				
Dhaka Zone Total			6004	5847	2220	2286	3178	3608	411	740			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	0	0	25	25	230		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	135	135	135	135	45		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	0	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	9	19	19	19				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	34	51				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	212	222	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	15	15	120	225				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	100	50	100				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	65				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	8	40	40				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5	17		Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	1	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	26	35	17	35				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	43	92	54	92				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	23	12	60	90				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	44	54	54				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	57	89	90	90				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total			2442	2382	636	887	1029	1276	292	330			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	51	48	50	50				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	200	182	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	315	330	330				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	330	280	330	330				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	35	55	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	102	102	8	8	93		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	39	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	40	80	40	135				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	51	100	100				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	11	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+40x1.515+15x1.09	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	17				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	24	9	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	54				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	95	36	94				
**	Import (Tripura)	India		160	160	124	102	135	153				
Cumilla Zone Total			3309	3285	1024	1444	1459	1820	587	163			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	57	44	65	145		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	17	19	19				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	104	90	104				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	10	45	165	180				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
86	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	13	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	0	6				
Mymensingh Zone Total			622	614	114	229	370	374	145	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.03.23 (Yesterday)		20.03.23 (Today)		19.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	44	44		27	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	43	43		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	50	51	51				
91	Kushihara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	80	112		54	ST Under maint.	
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	66	65	65				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	86	86	86				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	79	80	80	80				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	250	300	300				
101	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	353	354	366	368				
102	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	360	325	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12x3.4+5x2	50	50	30	47	47	47				
Sylhet Zone Total						2472	2427	1480	1447	1586	1620	17	559
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	230	250	300	300	160		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	65				
109	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			Commissioning with Gas	
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	1	35	40				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	74	0	100	0				
114	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	0	16	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BFPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	893	869	916	916				
Khulna Zone Total						3005	3001	1197	1136	1425	1600	160	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	11	15	22				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	159	170	171	170				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	630	900	1000	1230				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	162	161	152	307				
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	965	1242	1338	1777	0	220
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	32				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	34	50	85				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	26	35				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	185	170	150	150	40		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	268	308	300	360				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	20	20				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	0	70	70	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	38	70	70	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Adani Power Jharkhanda Ltd							238	0	260	260			
Rajshahi Zone Total						2129	2129	763	721	1055	1282	651	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	169	170	200	200	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	35	78	70	106				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6x20	115	115	0	35	0	72				
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	7	0	30	0				
Teesta Solar Limited							74	0	130	0			
Rangpur Zone Total						830	750	285	283	438	378	189	85
Sub-total: Plants in operation						23078	22700	8684.0	9675	11878	13735	2452	2097
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0				
Gross Total						23482	22700	8684	9675	11878	13735	2452	2097
(C) Actual data of 19.03.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	9675 MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9230 MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	9848 MW, at =	1:00 hrs	Dhaka	3433	3433	0	Mymensingh	769	769	0	
04.	Minimum Generation (Generation end)	:	7822 MW, at =	9:00 hrs	Chattogram	1163	1163	0	Sylhet	350	350	0	
05.	Day-peak Generation (Generation end)	:	8684 MW, at =	12:00 hrs	Khulna	969	969	0	Barishal	166	166	0	
06.	Evening-peak Generation (Generation end)	:	9675 MW, at =	19:00 hrs	Rajshahi	1024	1024	0	Rangpur	704	704	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:00 hrs	Cumilla	653	653	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6507 MW, at =	5:00 hrs					Total	9230	9230	0	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 151377964 Taka (b) Oil = 269930149 Taka		(c) Coal = 205693617 Taka Total = 627001730 Taka				
	a) Gas/LF limitation	:	2033 MW		14.	Maximum Temperature in Dhaka was : 24.7° C							
	d) Coal supply Limitation	:	189 MW		15.	Export through East-West interconnections :							
	b) Low water level in Kaptai lake	:	230 MW			At evening peak-hour : 8684 MW, at 19:00 hrs							
	c) Plants under shut down/ maintenance	:	2097 MW			Maximum : -92 MW, at 8:00 hrs							
10.	Total Energy (Generation + India Import)	:	216.95 MWh			Energy : 0.0495 MWh							
	By Gas = 139.434 MKWH		By Oil = 21.120 MKWH										
	By Coal = 31.758 MKWH		By Hydro = 0.267 MKWH										
	By Solar = 0.914 MKWH												
11.	Total Gas Supplied	:	1062.75 MMCFD										
(D) Forecast of 20.03.23 (Today) Monday :													
01.	Maximum Demand	:	11500 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	13735 MW (Generation end)		05.	Total Generation : 253.34 MKWh							
03.	Reserve / Shortage	:	2235 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 28.8° C							