

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023				Day : Tuesday				Date : 21.03.23				
Probable Maximum Demand : 11000 MW				Probable Maximum Generation : 14093 MW				Rule Curve = 89.80 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 76.87 ft				Today = 76.85 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.03.23 (Yesterday)		21.03.23 (Today)		20.03.23 (Yesterday)		21.03.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening	MW		MW	
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	304	346	300	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	360	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	377	393	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	40	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	222	234	220	220			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	279	273	310	310			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	24	92	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22			
17	Summit Power (Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	46	47	46	46			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	0	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	42	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	52	52	100			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	16	82	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	0	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	280	300			
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	35	149	36	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	17	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	68	55	90			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	90	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	6	35	17	35			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	8	92	92			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	17	0	0			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	20	85	85			
Dhaka Zone Total					6004	5847	2237	2655	3156	3605	411	740
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	0	0	25	25	230		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	135	140	140	140	40		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	1	0	5	0	0			
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	68	51	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	226	227	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	49	65	120	225			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	63	90	50	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	51	65			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	40			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5	17		Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	7	15			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	36	17	35			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	46	72	54	92			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	90	60	90			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	54	54	54			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	838	990	1075	1313	287	330
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	47	51	50	50			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	181	182	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	285	310	330	330			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	350	358	330	350			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	35	35	35			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	10	51	43	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	10	40	135			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	100	100	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	2	11	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	15	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	105	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	54			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	94	36	94			
**	Import (Tripura)	India		160	160	110	104	135	153			
Cumilla Zone Total					3309	3285	1171	1481	1439	1828	681	163
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	45	89	44	85	113		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	19	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	77	90	104			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	45	16	165	180			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total					622	614	185	207	376	394	113	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.03.23 (Yesterday)		21.03.23 (Today)		20.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	44	44		27	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	43	43		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	28	53	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	80	112		54	ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	3	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	65	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	89	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	75	0	0	0				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	20	20				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	25	25	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	260	300	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	407	382	366	368				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	395	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	30	47	47	47				
Sylhet Zone Total						2472	2427	1540	1507	1548	1582	17	559
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	300	300	300	110		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	65				
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			Commissioning with Gas	
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	55	55				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	19	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	898	782	921	921				
Khulna Zone Total						3005	3001	1217	1082	1450	1620	110	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	23	22	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	170	160	171	170				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	550	620	1000	1230				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	151	153	300	307				
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	890	956	1493	1777	0	220
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	32				
128	Chapainawabgarj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	85				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	36	0	26	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	143	214	214	214				
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	322	370	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	20	20				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	0	70	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	70	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				416	545	500	500				
Rajshahi Zone Total						2129	2129	954	1161	1459	1626	611	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170		104	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	0	70	106				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	115	0	72				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	4	0	30	0				
	Teesha Solar Limited	Solar (IPP)				128	0	130	0				
Rangpur Zone Total						830	750	304	285	408	348	189	85
Sub-total: Plants in operation						23078	22700	9336.0	10324	12404	14093	2419	2097
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Rimulua 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0		Contract Expired on 11/01/2022
Gross Total						23482	22700	9336	10324	12404	14093	2419	2097
(C) Actual data of 20.03.23 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	10324 MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9953 MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10324 MW, at =	19:30 hrs	Dhaka	4053	4053	0	Mymensingh	600	600	0	
04.	Minimum Generation (Generation end)	:	6507 MW, at =	5:00 hrs	Chattogram	1025	1025	0	Sylhet	334	334	0	
05.	Day-peak Generation (Generation end)	:	9336 MW, at =	12:00 hrs	Khulna	1121	1121	0	Barisal	280	280	0	
06.	Evening-peak Generation (Generation end)	:	10324 MW, at =	19:30 hrs	Rajshahi	986	986	0	Rangpur	651	651	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs	Cumilla	904	904	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6793 MW, at =	5:00 hrs					Total	9953	9953	0	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 148539323 Taka (b) Oil = 226682765 Taka		(c) Coal = 156570756 Taka Total = 531792844 Taka				
	a) Gas/LF limitation	:	2000 MW		14.	Maximum Temperature in Dhaka was : 28.2° C							
	d) Coal supply Limitation	:	189 MW		15.	Export through East-West interconnections :							
	b) Low water level in Kaptai lake	:	230 MW			At evening peak-hour	:	9336 MW, at	19:30 hrs				
	c) Plants under shut down/ maintenance	:	2097 MW			Maximum	:	360 MW, at	19:30 hrs				
10.	Total Energy (Generation + India Import)	:	210.62 MKWh			Energy	:	0 MKWh					
	By Gas = 138.568 MKWh			By Oil = 17.562 MKWh									
	By Coal = 30.466 MKWh			By Hydro = 0.000 MKWh									
	By Solar= 1.514 MKWh												
11.	Total Gas Supplied	:	1058.30 MMCFD										
(D) Forecast of 21.03.23 (Today) Tuesday :													
01.	Maximum Demand	:	11000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14093 MW (Generation end)		05.	Total Generation	:	224.41 MKWh					
03.	Reserve / Shortage	:	3093 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	30.9° C						