

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Wednesday					Date : 22.03.23				
Probable Maximum Demand : 11600 MW					Probable Maximum Generation : 13252 MW					Rule Curve = 89.64 ft.				
Water Level of Kaptai Lake at 06:00 AM					Today = 76.86 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.03.23 (Yesterday)		22.03.23 (Today)		21.03.23 (Yesterday)		22.03.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	0	0					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	11	12	12	90	96			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	280	300	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	360	320	360	360					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	355	355	355					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	184	139	100	140					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	277	238	270	270					
14	Madanganj-55 MW PP (Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	40	92	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	24	27	45	45					
18	Maona 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	10	25	25					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	52	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	70	52	100					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	64	98	150					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	40	54	0	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	2	130	280	300					
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	130	36	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	0 25x11.4	300	300	0	0	0	0					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	17	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	35					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	35	55	90					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	90	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	25	35	17	35					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	5	24	92	92					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	5	9	0	0					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	3	51	80	80					
Dhaka Zone Total				6004	5847	2153	2714	2760	3346	411	740			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	0	0	25	25	230			Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	140	140	140	140	40			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	0	0	5	0	0					
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	8	19	19	19					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	10	17	51	51					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	228	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	80	120	225					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	63	76	50	76					
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	51	65					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	8	40	40					
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5	17			Gas Shortage	
*	Malancha, Ctg EP2 (United)	Gas	5x8.73+3x9.34	108	108	10	29	5	15					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	10	17	17	35					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	19	54	54	92					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	60	90					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	44	44	44					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	70	107	107	107					
**	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test	
Chattogram Zone Total				2442	2382	723	941	1063	1279	287	330			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	46	51	50	50					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	178	180	190	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360			Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	280	310	310					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	401	352	330	350					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	47	53	40	50					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	25	35	43					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	135	40	135					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	29	17	100	100					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	21	15	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	17					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	5	26	9	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	54					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	71	34	36	94					
**	Import (Tripura)	India		160	160	98	114	135	153					
Cumilla Zone Total				3309	3285	1289	1371	1396	1815	681	163			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	68	44	85	134			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	16	16	16					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	109	90	109					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	101	165	170					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
86	Sutiakshi 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total				622	614	204	300	373	386	134	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.03.23 (Yesterday)		22.03.23 (Today)		21.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	43	43		27	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	64	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	25	25	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	260	270	290				
101	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	409	319	366	368				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	380	380	380				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	43	47	47	47				
Sylhet Zone Total						2472	2427	1560	1427	1505	1527	17	790
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	260	330	330	150		Gas Shortage	
107	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	65				
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			Commissioning with Gas	
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	55	55				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	70	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	903	762	752	752				
Khulna Zone Total						3005	3001	1153	1055	1311	1481	150	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	9	22	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	159	167	171	170				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	610	830	700	900				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	152	152	152	152				
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	939	1158	1045	1292	0	220
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	32				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	1	8	50	85				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	26	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	214	214	214				
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	343	371	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	22	22	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	70	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	70	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
Adani Power Jharkhanda Ltd							511	544	650	650			
Rajshahi Zone Total						2129	2129	881	1205	1611	1778	611	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	0	70	106				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	0	72				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	13	0	30	0				
	Teesha Solar Limited	Solar (IPP)				167	0	130	0				
Rangpur Zone Total						830	750	357	205	408	348	189	85
Sub-total: Plants in operation						23078	22700	9259.0	10376	11472	13252	2480	2328
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(LCLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Rimul 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0				
Gross Total						23482	22700	9259	10376	11472	13252	2480	2328
(C) Actual data of 21.03.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10376	MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9977	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10376	MW, at =	19:30 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	6793	MW, at =	5:00 hrs	Dhaka	4020	4020	0	Mymensingh	832	832	0
05.	Day-peak Generation (Generation end)	:	9259	MW, at =	12:00 hrs	Chattogram	1035	1035	0	Sylhet	368	368	0
06.	Evening-peak Generation (Generation end)	:	10376	MW, at =	19:30 hrs	Khulna	1155	1155	0	Barishal	239	239	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:30 hrs	Rajshahi	1016	1016	0	Rangpur	654	654	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7464	MW, at =	5:00 hrs	Cumilla	659	659	0				
09.	Generation shortfall at evening peak due to :	:								Total	9977	9977	0
a)	Gas/LF limitation	:	2061	MW		13.	Fuel cost :	(a) Gas = 142169318		(c) Coal = 173834363		Taka	
d)	Coal supply Limitation	:	189	MW				(b) Oil = 260899730	Taka	Total = 576903411		Taka	
b)	Low water level in Kaptai lake	:	230	MW									
c)	Plants under shut down/ maintenance	:	2328	MW		14.	Maximum Temperature in Dhaka was : 30.0° C						
10.	Total Energy (Generation + India Import)	:	212.52	MKWh		15.	Export through East-West interconnections :						
	By Gas = 130.696 MKWh			By Oil = 20.483 MKWh			At evening peak-hour	:	9259	MW, at	19:30 hrs		
	By Coal = 36.890 MKWh			By Hydro = 0.012 MKWh			Maximum	:	360	MW, at	19:30 hrs		
	By Solar= 2.411 MKWh						Energy	:	0	MKWh			
11.	Total Gas Supplied	:	1029.57	MMCFD									
(D) Forecast of 22.03.23 (Today) Wednesday :													
01.	Maximum Demand	:	11600	MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	13252	MW (Generation end)		05.	Total Generation : 237.58 MKWh						
03.	Reserve / Shortage	:	1652	MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 29.7° C						