

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Thursday				Date : 23.03.23			
Probable Maximum Demand : 11800 MW					Probable Maximum Generation : 13770 MW				Rule Curve = 89.48 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 76.86 ft. Today = 76.87 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.03.23 (Yesterday)		23.03.23 (Today)		22.03.23 (Yesterday)		23.03.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	16	81	80	81	27		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	308	304	300	305			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	360	360	360	360			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	373	355	373			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	90	90	140	140			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	265	259	250	260			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	8	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	92	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	22			
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	41	39	44	44			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	52	50	52			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	100	52	100			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	82	98	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	35	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	8	15	280	300			
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	35	135	36	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	20	72	55	90			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	34	90	90	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	35	17	35			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	92	92			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	7	9	30	90			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	10	51	80	80			
Dhaka Zone Total			6004	5847	2202	2622	2912	3400	342	740		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	135	140	140	140	40		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	227	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	15	130	120	225			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	74	76	50	76			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	20	0	65			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	40			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5	17		Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	28	5	22			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	35	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	52	54	54	54			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	16	75	60	90			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	55	44	55			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	89	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total			2442	2382	781	1028	955	1224	262	330		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	46	47	50	50			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	179	188	190	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	300	285	300	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	394	300	330	350			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	47	50	40	50			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	35	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	40	130	40	130			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	100	100	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	20	15	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	100			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	93	102	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	54			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	95	115	36	115			
**	Import (Tripura)	India		160	160	122	136	135	153			
Cumilla Zone Total			3309	3285	1454	1600	1386	1911	681	163		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	50	44	60	152		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	16	18			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	107	90	110			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	28	130	130	160			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	12	6	12			
Mymensingh Zone Total			622	614	224	317	338	360	152	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.03.23 (Yesterday)		23.03.23 (Today)		22.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	43	44		26	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	45	51	51				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	112	112		54	ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	40	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	8	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	25	25	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	255	270	280				
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	368	366	368				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	380	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12*3.4+5*2	50	50	44	47	47	47				
Sylhet Zone Total						2472	2427	1522	1431	1505	1538	17	558
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	345	265	250	280	145		Gas Shortage	
107	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	65				
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			Commissioning with Gas	
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	10	55	55				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	100	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	370	400				
117	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	737	621	752	752				
Khulna Zone Total						3005	3001	1182	946	1601	1831	145	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	10	17	22	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	170	146	171	170				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	580	1150	700	800				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	281	152	305				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	910	1594	1045	1345	0	220
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
125	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
127	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
128	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	32				
129	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	8	8	50	85				
130	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	40				
131	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42				
132	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	26	35				
133	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	130	195	190	190				
134	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
136	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	312	377	400	400				
137	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
138	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
139	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
140	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	70	70	113				
141	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	110	70	110				
142	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Adani Power Jharkhanda Ltd						647	659	650	650				
Rajshahi Zone Total						2129	2129	1130	1448	1587	1770	611	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	68	70	106				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	0	115				
150	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0				
Teesta Solar Limited						147	0	130	0				
Rangpur Zone Total						830	750	353	273	408	391	189	85
Sub-total: Plants in operation						23078	22700	9758.0	11259	11737	13770	2399	2096
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0				
Gross Total						23482	22700	9758	11259	11737	13770	2399	2096
(C) Actual data of 22.03.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	11259 MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10650 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	11259 MW, at =	19:30 hrs	Dhaka	4282	4282	0	Mymensingh	872	872	0	
04.	Minimum Generation (Generation end)	:	7464 MW, at =	5:00 hrs	Chattogram	1031	1031	0	Sylhet	380	380	0	
05.	Day-peak Generation (Generation end)	:	9758 MW, at =	12:00 hrs	Khulna	1311	1311	0	Barishal	288	288	0	
06.	Evening-peak Generation (Generation end)	:	11259 MW, at =	19:30 hrs	Rajshahi	1081	1081	0	Rangpur	690	690	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs	Cumilla	915	915	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7985 MW, at =	5:00 hrs					Total	10850	10850	0	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 146828246 Taka (b) Oil = 327383332 Taka		(c) Coal = 197513241 Taka Total = 671724820 Taka				
a)	Gas/LF limitation	:	2005 MW		14.	Maximum Temperature in Dhaka was : 31.3° C							
d)	Coal supply Limitation	:	189 MW		15.	Export through East-West interconnections :							
b)	Low water level in Kaptai lake	:	205 MW			At evening peak-hour							
c)	Plants under shut down/ maintenance	:	2096 MW			Maximum							
10.	Total Energy (Generation + India Import)	:	228.88 MMCFD			Energy							
	By Gas = 136.357 MKWH		By Oil = 25.198 MKWH			: 0 MKWh							
	By Coal = 44.212 MKWH		By Hydro = 0.596 MKWH										
	By Solar = 2.679 MKWH												
11. Total Gas Supplied						:	1038.51	MMCFD					
(D) Forecast of 23.03.23 (Today) Thursday :													
01.	Maximum Demand	:	11800 MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	13770 MW	(Generation end)	05.	Total Generation : 239.88 MKWh							
03.	Reserve / Shortage	:	1970 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 33.6° C							