

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Saturday				Date : 25.03.23			
Probable Maximum Demand : 11500 MW					Probable Maximum Generation : 13917 MW				Rule Curve = 89.16 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 76.91 ft				Today = 76.94 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.03.23 (Yesterday)		25.03.23 (Today)		24.03.23 (Yesterday)		25.03.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW		Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	75	78	78	33		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	291	273	270	300			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	370	370	370			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	352	399	350	400			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	80	145	145	145			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	255	240	260	280			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	24	92	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	16	19	22			
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	45	44	44			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	30	30			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	31	25	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	52	52	100			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	98	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	280	300			
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	35	71	36	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	35	17	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	17	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	1	34	55	90			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	4	90	90	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	16	0	17	35			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	9	92	92			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	8	30	90			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	34	80	80			
Dhaka Zone Total			6004	5847	1918	2352	2905	3437	348	740		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	130	130	130	130	50		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	19	20	20			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	34	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	226	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	10	15	120	225			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	97	60	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	0	64			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	40			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5	17		Gas Shortage
*	Malancha, Ctg EP2 (United)	Gas	5x8.73+3x9.34			24	42	7	15			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	14	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	51	54	54			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	11	25	50	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	55	44	55			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
**	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total			2442	2382	698	882	948	1258	272	330		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	48	50	50	50			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	214	184	190	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	130	330	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	285	310	300	330			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	401	340	330	350			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	51	54	40	50			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	35	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	15	100	40	149			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	37	100	100	180			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	19	19			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	3	16	0	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	15	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	5	45	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	54			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	37	92	36	115			
**	Importo (Tripura)	India		160	160	110	130	135	153			
Cumilla Zone Total			3309	3285	1339	1563	1514	2418	681	163		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	48	102	51	102	100		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	99	115	90	115			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	46	80	130	160			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	18	6	18			
Mymensingh Zone Total			622	614	285	334	348	414	100	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.03.23 (Yesterday)		25.03.23 (Today)		24.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	41	44	44		29	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51				
91	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	65	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	280	290	280				
101	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	341	367	366	368				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	380	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	49	50	50	50				
Sylhet Zone Total						2472	2427	1505	1531	1520	1532	9	561
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	230	320	230	320	90		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	65				
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	55	55				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	96	0	100	0				
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	49	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	374	371	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BFPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	909	734	781	783				
Khulna Zone Total						3005	3001	1609	1531	1240	1502	90	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	27	22	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	170	170	171	170				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	530	870	700	900				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	151	151	152	152				
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	869	1218	1045	1292	0	220
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	32				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	85				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	26	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	135	165	190	190				
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	306	387	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	70	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	70	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				500	480	500	550				
Rajshahi Zone Total						2129	2129	979	1170	1437	1673	611	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	169	170	170	105		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	70	70	106				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	0	115				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	27	0	30	0				
	Teesha Solar Limited	Solar (IPP)				149	0	130	0				
Rangpur Zone Total						830	750	341	311	408	391	190	85
Sub-total: Plants in operation						23078	22700	9543.0	10892	11365	13917	2301	2099
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Rimul 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
	Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0				Contract Expired on 11/01/2022
Gross Total						23482	22700	9543	10892	11365	13917	2301	2099
(C) Actual data of 24.03.23 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	10892 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10476 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	10892 MW, at =	21:00 hrs	Dhaka	3687	3687	0	Mymensingh	903	903	0	
04.	Minimum Generation (Generation end)	:	7613 MW, at =	7:00 hrs	Chattogram	1109	1109	0	Sylhet	383	383	0	
05.	Day-peak Generation (Generation end)	:	9543 MW, at =	12:00 hrs	Khulna	1410	1410	0	Barishal	332	332	0	
06.	Evening-peak Generation (Generation end)	:	10892 MW, at =	21:00 hrs	Rajshahi	1116	1116	0	Rangpur	651	651	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Cumilla	886	886	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7813 MW, at =	5:00 hrs					Total	10476	10476	0	
09.	Generation shortfall at evening peak due to :				13.	Fuel cost :	(a) Gas = 144647500 Taka (b) Oil = 318876927 Taka		(c) Coal = 180879343 Taka Total = 644403770 Taka				
	a) Gas/LF limitation	:	1906 MW		14.	Maximum Temperature in Dhaka was : 32.7° C							
	d) Coal supply Limitation	:	190 MW		15.	Export through East-West interconnections :							
	b) Low water level in Kaptai lake	:	205 MW			At evening peak-hour : 9543 MW, at 21:00 hrs							
	c) Plants under shut down/ maintenance	:	2099 MW			Maximum : 270 MW, at 20:00 hrs							
10.	Total Energy (Generation + India Import)	:	230.28 MKWh			Energy : 0 MKWh							
	By Gas = 132.442 MKWh			By Oil = 24.579 MKWh									
	By Coal = 46.246 MKWh			By Hydro = 0.600 MKWh									
	By Solar = 2.761 MKWh												
11.	Total Gas Supplied	:	1015.30 MMCFD										
(D) Forecast of 25.03.23 (Today) Saturday :													
01.	Maximum Demand	:	11500 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	13917 MW (Generation end)		05.	Total Generation : 243.13 MKWh							
03.	Reserve / Shortage	:	2417 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 34.9° C							