

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Thursday				Date : 30.03.23			
Probable Maximum Demand : 12500 MW					Probable Maximum Generation : 13971 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 76.28 ft				Today = 76.14 ft			
					Rule Curve = 88.34 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.03.23 (Yesterday)		30.03.23 (Today)		29.03.23 (Yesterday)		30.03.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW		Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	81	75	81	27		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	292	332	300	330			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	360	400	400	400			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	381	385	400	400			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	142	190	200	200			
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	260	284	300	285			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	40	102	102			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	0	19	22			
17	Summit Power(Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	39	51	53			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	26	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	25	25	51			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	35	70	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	64	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	35	35	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	45	280	300			
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	70	105	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	34	72	72	72			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	83	54	162	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	16	42	92	92			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	31	75	90			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	51	90	90			
Dhaka Zone Total					6004	5847	2352	2655	3267	3594	342	740
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	0	25	25	230		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	0	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	8	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	20	20			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	224	218	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	122	65	300	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	88	100			
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	65	68	0	85			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	48			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5	17		Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	22	10	25			
52	Chattogram 108 MW PP (IECPV)	HFO (IPP)	16x7.00	108	108	5	12	5	12			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	2	54	51	54			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	62	100	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	77	55	75			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	89	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	826	870	1075	1277	427	330
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	46	50	47	50			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	182	193	210	210			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	130	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	280	320	330	330			
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	0	318	325	325			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	45	20	51	51			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	26	135	25	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35			
69	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	133	85	160	180			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	20			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	16	0	16			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	21	18	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.015+10x1.08	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	0	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	36	36			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	94	95	94	94			
**	Import (Tripura)	India		160	160	94	124	135	153			
Cumilla Zone Total					3309	3285	1156	1516	1668	1889	681	163
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	47	93	51	100	109		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	76	99	95	99			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	140	150	180			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0			
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	18	12	12			
Mymensingh Zone Total					622	614	255	369	379	410	109	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.03.23 (Yesterday)		30.03.23 (Today)		29.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance									
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/ Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date							
						Day	Evening	Day	Evening												
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	41	41	41		29	GT-1 & ST-1 Under maint.									
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.									
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51												
91	Kushihara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112		54	ST Under maint.									
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8												
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	64	65	65												
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.									
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86												
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	140	140												
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19												
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10												
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16	9		Gas Shortage									
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	280	280												
101	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	366	369	400	400												
102	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	360	400	400	400												
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work									
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	43	50	50	50												
Sylhet Zone Total						2472	2427	1450	1552	1720	1720	9	561								
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0												
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	155	145	170	170	265		Gas Shortage									
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	40	50												
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	65												
109	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0												
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0												
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	37	53	53												
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100												
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0												
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	16	32	66	83												
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	8	40												
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	370	372	0	0												
	Khulna 330 MW CAPP	Gas/HSD (BFPDB)				0	30	0	0												
**	Bheramara (H/DC)	India		1000	1000	893	784	919	919												
Khulna Zone Total						3005	3001	1535	1400	1396	1480	265	0								
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	48												
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	24	22	22												
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	171	171	170	170												
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	790	902	850	950												
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0												
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	151	152	250	250												
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.									
Barishal Zone Total						2265	2265	1134	1249	1340	1440	0	220								
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage									
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage									
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32												
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0												
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	40												
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	100												
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	40												
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42												
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	10	0	26	36												
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	141	165	160	150	45		Gas Shortage									
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage									
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage									
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	287	236	300	270	178		Gas Shortage									
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22												
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11												
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	34												
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	50	113	95	113												
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	113												
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0												
Adani Power Jharkhanda Ltd							586	582	760	760											
Raishahi Zone Total						2129	2129	1154	1223	1572	1763	834	0								
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage									
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling									
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage									
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0												
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	113	35	113												
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0												
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0												
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	36	50	115												
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	36	0	30	0												
Teesta Solar Limited							158	0	130	0											
Rangpur Zone Total						830	750	440	319	423	398	189	85								
Sub-total: Plants in operation						23078	22700	10302.0	11153	12840	13971	2856	2099								
(B) Plants under long term maintenance/ contract expired																					
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0												
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0												
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0												
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0												
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0												
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0											
Gross Total						23482	22700	10302	11153	12840	13971	2856	2099								
(C) Actual data of 29.03.23 (Yesterday) Wednesday :																					
01.	Max. Demand at eve. peak (Generation end)	:	11153	MW, at =	21:00 hrs																
02.	Max. Demand at eve. peak (Sub-station end)	:	10794	MW, at =	21:00 hrs																
03.	Highest Generation (Generation end)	:	11153	MW, at =	21:00 hrs																
04.	Minimum Generation (Generation end)	:	8622	MW, at =	6:00 hrs																
05.	Day-peak Generation (Generation end)	:	10302	MW, at =	12:00 hrs																
06.	Evening-peak Generation (Generation end)	:	11153	MW, at =	21:00 hrs																
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs																
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8357	MW, at =	5:00 hrs																
09.	Generation shortfall at evening peak due to :	:																			
	a) Gas/LF limitation	:	2437	MW																	
	d) Coal supply Limitation	:	189	MW																	
	b) Low water level in Kaptai lake	:	230	MW																	
	c) Plants under shut down/ maintenance	:	2099	MW																	
10.	Total Energy (Generation + India Import)	:	251.39	MKWh																	
	By Gas = 125.440 MKWh	By Oil =	47.179 MKWh																		
	By Coal = 52.075 MKWh	By Hydro =	0.500 MKWh																		
	By Solar= 2.565 MKWh																				
11.	Total Gas Supplied	:	985.77	MMCFD																	
(D) Forecast of 30.03.23 (Today) Thursday :																					
01.	Maximum Demand	:	12500	MW	(Generation end)																
02.	Maximum Generation	:	13971	MW	(Generation end)																
03.	Reserve / Shortage	:	1471	MW	(Generation end)																
04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)																
05.	Total Generation	:	281.76	MKWh																	
06.	Probable Max. Temperature in Dhaka :	:	32.0° C																		