

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 3-Apr-23

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
	Ghorasal 78.5 MW PP (MAX)	QRPP	2'40	0	0	0	
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	81	1587000	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	400	9287680	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	343	7722000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	9559500	
9	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	50	327360	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	247	6737076	FGMO
11	Madanganj 102 PP(Summit)	NENP	6'17	102	64	412443	Low demand
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	45	523012	Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIIPP, REB	8'2.90	22	0	289188	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	50	317770	Low demand
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	200	4622166	ST U/M.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	605664	
20	Kalaboti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	259560	Engine problem
22	Kodda 150 MW PP	BPDB-RPCL	9'17.08	149	82	86640	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	550008	Engine problem
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	589524	
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIIPP REB	3'3.67+4'8.73	80	48	976620	Engine problem
27	SIPP REB	SIIPP REB	4'8.73	33	33	628900	
28	Rugonj 33 MW PP(Summit)	SIIPP REB	4'8.73	33	16	368800	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	50	759840	0.00
30	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	145	722617	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Fuel shortage
33	Bramhanaga 100 MW PP (Aggreko)	IPP	114'9.959	100	0	0	Fuel shortage
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Fuel shortage
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	2011680	
36	Gazipur 100 MW PP	RPCL	6'17.5	105	70	706195	Low demand
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	72	641280	Engine problem
38	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	1287360	
39	Spectro Solar Plant Ltd.	IPP	35	35	0	261459	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	35	862200	Engine problem
Dhaka area Total				5847	3199	58080542	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Gas shortage
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Racoon 25 MW PP	RPCL	3'8.9	25	8	68895	Low demand
44	Tekani 20MW PP (Solaritech)	IPP	20	20	0	76545	
45	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	6	85920	Fuel shortage
46	Kapata Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	277620	Low Water level
47	Sikalbaha 225MW	PDB	1'150+1'75	225	214	4788633	
48	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	17	441600	Fuel shortage
50	Halizhari 100 MW peaking PP	PDB	11'8.9	98	0	0	Reserve.
51	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	51	578918	Low demand
52	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	55	1063680	Engine problem
53	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	100	2006400	
54	Barabkundia 22 MW PP (Regent)	SIIPP, PDB	8'2.90	22	8	183840	Gas shortage
55	Malancha, Ch. EPZ Unit-1	IPP	5'8.73+9.34	0	38	628600	
56	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	0	0	Fuel shortage
57	Kapata 7 MW Solar PP	PDB	7.4 MW	7	0	27594	
58	Anwara 300 MW PP (United)	IPP	17'17+24	300	120	1417636	Low demand
59	Jodiach Power	IPP	3'18.55+1'3.6	54	36	467380	Engine problem
60	Kanaphuli Power Ltd.	IPP	18.415'6+8.5	110	54	1251195	Engine problem
61	Juldah unit-2 (Accorn)	IPP	8'13.6	100	90	1247040	
62	Anilima Energy Ltd.	IPP	8'21.2	116	107	2484000	Engine problem
63	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	0	36800	On test.
Chattogram area Total				2382	929	17132496	
64	Ashuganj TPP Unit- 3	APSCl	1'150	0	0	0	Contract Expired
65	Ashuganj TPP Unit- 4	APSCl	1'150	0	0	0	Contract Expired
66	Ashuganj TPP Unit- 5	APSCl	1'150	0	0	0	Contract Expired
67	Ashuganj 225 MW CCPP	APSCl	1'142+1'75	221	200	4681000	Contract Expired
68	Ashuganj 450 MW CCPP(North)	APSCl	1'360	360	280	7331000	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCl	1'360	360	0	0	Gas shortage
70	Ashuganj 420 MW CCPP(East)	APSCl	284'1+116'1	400	323	7924800	FGMO
71	Ashuganj 50 MW PP	APSCl	14'3.968	45	49	965232	
72	Ashuganj 55 MW PP (Precision)	QRPP	15'14	55	15	271120	Gas shortage
73	Ashuganj 195MW PP (APSCl-United)	IPP	20'9.73+1'16	195	8	200727	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	43	878276	Engine problem
75	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	129	1681090	Engine problem
76	Titas 50 MW Peaking PP	PDB	6'8.92	52	6	8384	
77	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
78	Chandpur 200MW (Desh energy)	IPP	12'14.4	200	200	3406080	
79	Feni 22MW PP (Doreen)	SIIPP, PDB	8'2.90	22	18	419976	Engine problem
80	Feni 11 MW PP (Doreen)	SIIPP, REB	4'2.90	11	11	232560	
81	Import (Tripura)	Imported power	0	160	150	3143040	
82	Jangalia 33MW PP (Summit)	SIIPP, PDB	4'8.73	33	33	733500	
83	Jangalia 52 MW PP (Laksharavi)	IPP	8'9.92	52	64	864109	
84	Qumilla 25 MW PP (Summit)	SIIPP, REB	3'3.67+2'6.97	25	21	477830	Engine problem
85	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Fuel shortage
86	Feni Lanka Power	IPP	7'18.415+1'9.78	114	52	220020	Low demand
87	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	9	237720	Fuel shortage
88	Bharob 54.5 MW	IPP	3'18.2	54	17	317880	Engine problem
89	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	115	1384320	
Qumilla Area Total				3285	1731	35180664	
90	RPCL 210MW CCPP	IPP	4'35+1'70	202	60	1405440	Gas shortage
91	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8'2.90	22	19	200952	Engine problem
92	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
93	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	13650	
94	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	164	2280000	Fuel shortage
95	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	109	1722000	
96	Sutakhali 50 MW Solar PP	IPP	50	50	0	369920	
97	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	19	341040	Engine problem
Mymensingh Area Total				614	371	6333002	
98	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	40	931000	Machine problem
99	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	42	969640	Machine problem
100	Kushara 163 MW CCPP (KP)	IPP	1'109+1'54	163	112	2196945	ST U/M.
101	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
102	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1018200	
103	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	50	1042056	
104	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4'2.90	11	8	110976	Engine problem
105	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	64	1314432	
106	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	86	1422720	
107	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
108	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	210	5237500	
109	Sylhet 20 MW GTTP	PDB	1'20	20	19	431000	
110	Sylhet 50MW PP (EP)	NENP	2'72	0	0	0	Contract Expired
111	Shahjahanulla 25 MW PP	SIIPP, REB	3'9.34	25	16	387888	Engine problem
112	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	6692500	FGMO
113	Bibiyana-III 400 MW CCPP	PDB	285'1+134'1	400	366	8420000	FGMO
114	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	9	203760	
115	Bibiyana South 400 MW	PDB	400 MW	383	394	9452100	
Sylhet Area Total				2427	1739	39823617	
116	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
117	Bheramara (HVDC)	Imported power	2'500	1000	784	20804363	
118	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	99	506880	Engine problem
119	Fardipur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Reserve.
120	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation
121	Gosairhat 100 MW Peaking PP	PDB	16'8.98	100	0	0	Reserve.
122	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	140	4375008	Gas shortage
123	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	8	57375	Low demand
124	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Reserve.
125	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	55	394560	Fuel shortage
126	Madhumati 100 MW PP	NWPGCL	6'18	105	32	223488	Transformer OIL
127	Mongia Orion 100 MW Solar PP	IPP	100	100	0	747360	
128	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
129	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	660'2	617</			