

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023					Day : Tuesday				Date : 04.04.23			
Probable Maximum Demand : 12800 MW					Probable Maximum Generation : 14131 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 76.01 ft				Today = 76.04 ft			
					Rule Curve = 87.40 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.04.23 (Yesterday)		04.04.23 (Today)		03.04.23 (Yesterday)		04.04.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	77	81	77	81	27		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	343	340	340			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	400	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	170	200	220	220			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	275	247	280	280			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	45	48	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	102	102	102			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	22	22			
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	41	48	48	49			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	50	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	25	70	70	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	82	64	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	5	145	280	300			
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x18.97	149	149	80	149	115	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	35	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	72	72	72			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	162	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	36	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	35	35	35			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	12	50	92	92			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	50	75	90			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	64	68	90			
Dhaka Zone Total					6004	5847	2458	3199	3398	3665	707	375
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	3	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	15	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	6			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	213	214	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	65	120	120	230			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	48				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	5	5	14		Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	38	7	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	36	0	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	90	100	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	55	44	55			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	709	929	860	1122	399	330
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	42	49	45	45			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	190	200	200	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	280	280			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	320	323	320	300			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	15	15	15	15	40		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	93	129	100	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	6	0	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	52	30	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	52	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	10	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.510+2x25.428	115	115	36	115	36	115			
**	Import (Tripura)	India		160	160	136	150	135	153			
Cumilla Zone Total					3309	3285	1477	1731	1635	1819	721	163
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	60	40	60	142		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	16	16			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	109	115	115			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	144	164	150	190			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	19	12	18			
Mymensingh Zone Total					622	614	340	371	385	399	142	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.04.23 (Yesterday)		04.04.23 (Today)		03.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)						
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	39	40	41	41		30	GT-1 & ST-1 Under maint.					
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51								
91	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	80	112		54	ST Under maint.					
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8								
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	65	65								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	209	210	210	210								
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	18	18								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	9	9								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	260	270	280	280								
101	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	365	366	366	366								
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	394	400	400								
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	50	50	50	50								
Sylhet Zone Total						2472	2427	1693	1739	1722	1754	9	562				
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	155	140	170	200	270		Gas Shortage					
107	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	40	50								
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	65								
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0								
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	55	53	53								
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	32	0	100								
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	102	0	100	0								
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	99	66	99								
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	40								
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	67	370	370								
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				0	0	0	0								
**	Bheramara (H/DC)	India		1000	1000	891	784	911	911								
Khulna Zone Total						3005	3001	1148	1185	1758	1888	270	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	48								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	25	20	25								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	171	160	170	170								
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1212	900	900								
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0								
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	149	150	150	180								
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.					
Barishal Zone Total						2265	2265	1195	1547	1288	1323	0	220				
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32								
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	100								
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40								
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	0	42								
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	36	0	28	36								
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	179	163	180	180								
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	264	227	290	300	187		Gas Shortage					
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22								
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	25	0	34								
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	50	113								
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	95	50	113								
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0								
Adani Power Jharkhanda Ltd							610	660	600	700							
Rajshahi Zone Total						2129	2129	1123	1324	1287	1763	798	0				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling					
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage					
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	50	113								
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0								
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	55	50	115								
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0								
Teesta Solar Limited							202	0	130	0							
Rangpur Zone Total						830	750	379	338	438	398	189	85				
Sub-total: Plants in operation						23078	22700	10522.0	12363	12771	14131	3235	1735				
(B) Plants under long term maintenance/ contract expired																	
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	3	0	0	0								
Sub-Total: Plants under long term maintenance/ contract expired						404	0	3	0	0	0						
Gross Total						23482	22700	10525	12363	12771	14131	3235	1735				
(C) Actual data of 03.04.23 (Yesterday) Monday :																	
01.	Max. Demand at eve. peak (Generation end)	:	12363	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	11765	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	12363	MW, at =	21:00 hrs		MW	MW	MW		MW	MW	MW				
04.	Minimum Generation (Generation end)	:	8001	MW, at =	6:00 hrs	Dhaka	4312	4312	0	Mymensingh	964	964	0				
05.	Day-peak Generation (Generation end)	:	10525	MW, at =	12:00 hrs	Chattogram	1163	1163	0	Sylhet	391	391	0				
06.	Evening-peak Generation (Generation end)	:	12363	MW, at =	21:00 hrs	Khulna	1507	1507	0	Barishal	367	367	0				
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs	Rajshahi	1292	1292	0	Rangpur	699	699	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8871	MW, at =	5:00 hrs	Cumilla	1069	1069	0								
09.	Generation shortfall at evening peak due to :	:				Total				11765	11765	0					
	a) Gas/LF limitation	:	2841	MW		(a) Gas = 146198780 Taka				(c) Coal = 249210880 Taka							
	d) Coal supply Limitation	:	189	MW		(b) Oil = 512893293 Taka				Total = 908302953 Taka							
	b) Low water level in Kaptai lake	:	205	MW													
	c) Plants under shut down/ maintenance	:	1735	MW													
10.	Total Energy (Generation + India Import)	:	253.00	MKWh		14. Maximum Temperature in Dhaka was : 32.0° C											
	By Gas = 137.980 MKWh			By Oil = 39.363 MKWh		15. Export through East-West interconnections :											
	By Coal = 48.098 MKWh			By Hydro = 0.278 MKWh		At evening peak-hour : 10525 MW, at 21:00 hrs											
	By Solar = 3.331 MKWh					Maximum : 56 MW, at 20:00 hrs											
						Energy : 0.033 MKWh											
11. Total Gas Supplied : 1028.70 MMCFD																	
(D) Forecast of 04.04.23 (Today) Tuesday :																	
01.	Maximum Demand	:	12800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	14131	MW	(Generation end)	05.	Total Generation	:	261.94	MKWh							
03.	Reserve / Shortage	:	1331	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	34.3° C									