

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 4-Apr-23

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
	Ghorasal 78.5 MW PP (MAX)	QRPP	2'40	0	0	0	
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	81	1567136	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	400	9105410	
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	347	7534000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	9447000	
9	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	77	737280	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	245	6832756	FGMO
11	Madanganj 102 PP(Summit)	NENP	6'11	102	95	1152710	Engine problem
12	Madanganj-25 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	921519	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	469260	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	90	798027	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	192	4554838	ST U/M.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1183968	
20	Kaipoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	259920	Engine problem
22	Kodda 150 MW PP	BPDB-RRCL	9'17.08	150	150	1947360	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	648499	Engine problem
24	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	670184	Engine problem
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIPP REB	3'3.67+4'8.73	80	47	992820	Engine problem
27	Madona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	622900	
28	Ruganaj 33 MW PP(Summit)	SIPP, REB	4'8.73	32	32	685700	
29	Gazipur 52 MW PP	RPCL	6'8.9	52	49	935040	0.00
30	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	296	3199089	
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Fuel shortage
33	Bramhanaga 100 MW PP (Aggreko)	IPP	114'9.959	100	0	0	Fuel shortage
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Fuel shortage
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	2714832	
36	Gazipur 100 MW PP	RPCL	6'17.5	105	88	1462493	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	71	973440	Fuel shortage
38	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	1330560	
39	Spectro Solar Plant Ltd.	IPP	35	35	0	224394	
40	Kanchan Furibachal Power Generation Ltd.	IPP	18.4'3	55	35	845280	Engine problem
Dhaka area Total				5847	3553	86364415	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Gas shortage
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3'8.9	25	8	141291	Low demand
44	Takani 20MW PP (Solaritech)	IPP	20	20	19	108945	
45	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	19	216480	Fuel shortage
46	Kapata Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	327720	Low Water level
47	Sikalbaha 225MW	PDB	1'150+1'75	225	214	4869769	
48	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	34	544472	Fuel shortage
50	Hajharani 100 MW peaking PP	PDB	11'8.9	98	40	402624	Engine problem
51	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	85	1065058	Engine problem
52	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	66	1245480	Engine problem
53	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	88	1661760	Engine problem
54	Barabkundia 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	10	170352	Gas shortage
55	Malancha, Cto. EPZ Unit-1	IPP	5'8.73+9.34	36	36	595200	
56	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	0	169920	Fuel shortage
57	Kapata 7 MW Solar PP	PDB	7.4 MW	7	0	26641	
58	Anwara 300 MW PP (United)	IPP	17'17+24	300	230	2604436	Fuel shortage
59	Jodiac Power	IPP	3'18.55+1'3.6	54	54	491171	
60	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	54	1336500	Fuel shortage
61	Juldah unit-2 (Accorn)	IPP	8'13.6	100	90	2007360	Engine problem
62	Anilima Energy Ltd.	IPP	8'21.2	116	107	2566800	Engine problem
63	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	0	13381	On test.
Chattogram area Total				2382	1160	20565360	
64	Ashuganj TPP Unit- 3	APSCl	1'150	0	0	0	Contract Expired
65	Ashuganj TPP Unit- 4	APSCl	1'150	0	0	0	Contract Expired
66	Ashuganj TPP Unit- 5	APSCl	1'150	0	0	0	Contract Expired
67	Ashuganj 225 MW CCPP	APSCl	1'142+1'75	221	217	4877000	Contract Expired
68	Ashuganj 450 MW CCPP(North)	APSCl	1'360	360	290	7494100	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCl	1'360	360	0	0	Gas shortage
70	Ashuganj 420 MW CCPP(East)	APSCl	284'1+116'1	400	250	7312400	FGMO
71	Ashuganj 50 MW PP	APSCl	14'3.068	45	49	948816	
72	Ashuganj 55 MW PP (Precision)	QRPP	15'14	55	40	499200	Gas shortage
73	Ashuganj 195MW PP (APSCl-United)	IPP	20'9.73+1'16	195	0	184000	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	43	892502	Engine problem
75	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	147	1915272	
76	Titae 50 MW Peaking PP	PDB	6'8.92	52	24	182752	
77	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
78	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	179	3995240	Engine problem
79	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	416988	Engine problem
80	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	227340	
81	Import (Tripura)	Imported power	0	160	164	3357120	
82	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	814100	
83	Jangalia 52 MW PP (Laksharavi)	IPP	8'9.92	52	52	513730	
84	Qumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	482140	Engine problem
85	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Fuel shortage
86	Feni Lanka Power	IPP	7'18.415+1'9.78	114	88	963300	Engine problem
87	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	31	343560	Fuel shortage
88	Bharob 54.5 MW	IPP	3'18.2	54	17	347040	Engine problem
89	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	115	1403640	
Qumilla Area Total				3285	1789	37076240	
90	RPCL 210MW CCPP	IPP	4'35+1'70	202	100	1387200	Gas shortage
91	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	19	428184	Engine problem
92	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
93	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	11600	
94	Mymensingh 200 MW PP (United)	IPP	9'78'21	173	200	2390400	Fuel shortage
95	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	115	1816800	
96	Sutiakhali 50 MW Solar PP	IPP	50	50	0	324130	
97	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	19	463440	Engine problem
Mymensingh Area Total				614	426	6821754	
98	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	40	933000	Machine problem
99	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	43	962640	Machine problem
100	Kushara 163 MW CCPP (KP)	IPP	1'109+1'54	163	80	2229554	ST U/M.
101	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
102	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1001400	
103	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	50	985824	
104	Haldiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	126504	Engine problem
105	Shahjibazar GTTP Unit- 3 & 9	PDB	2'35	66	62	1247328	
106	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	84	1558080	
107	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
108	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	208	5191320	Machine problem
109	Sylhet 20 MW GTTP	PDB	1'20	20	0	124000	
110	Sylhet 50MW PP (EP)	NENP	2'7.2	0	0	0	Contract Expired
111	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	341952	Engine problem
112	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	260	6636000	FGMO
113	Bibiyana-III 400 MW CCPP	PDB	285'1+134'1	400	330	8712000	FGMO
114	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	9	200700	
115	Bibiyana South 400 MW	PDB	400 MW	385	400	9178500	
Sylhet Area Total				2427	1627	39432202	
116	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
117	Bheramara (HVDC)	Imported power	2'500	1000	799	21256727	
118	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	77	721920	Engine problem
119	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Reserve.
120	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation
121	Gosairhat 100 MW Peaking PP	PDB	16'8.98	100	0	0	Reserve.
122	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	150	3734208	Gas shortage
123	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	24	138750	Engine problem
124	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Reserve.
125	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	55	555840	Fuel shortage
126	Madhumati 105 MW PP	NWPGCL	6'18	105	50	211536	Transformer OIL
127	Mongia Orion 100 MW Solar PP	IPP	100	100	0	701280	
128	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
129	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	660'2	617	364	8909091	On test.
130	Kulna 225 MW CCPP (GAS)	NWPGCL	0	0	0	0	
Khulna Area Total				3001	1519	36229352	
131	Bairaal 110 MW PP (Summit)	IPP	7'17.076	110	16	81896	Line O/L
132	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	27	539800	Engine problem
133	Bhola 225 MW CCPP	PDB	2'63+1'68	194	163	4101299	Machine problem
134	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	0	0	0	Contract Expired
135	Payra 1320 MW	BCPCL	2'622	1244	932	20981800	Line O/L
136	Bhola Nutan Biddut BD LTD	IPP	220	200	0	0	Under maint.
137	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Line O/L
138	Bairaal 307 MW	BCPCL	307'1	307	283	5040000	On test.
Bairaal Area Total				2265	1401	30714395	
139	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
140	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
141	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	32	69521	Engine problem
142	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	0	Reserve.
143	Annuar 50 MW PP(Sinha)	QRPP	7'7.79	0	0	23280	Contract Expired
144	Katakhali 50 MW PP (Northern)	QRPP	6'8.9	50	8	34157	Low demand
145	Katakhali 50 MW Peaking PP	PDB	6'8.7	50	40	186241	Engine problem
146	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'75	210	135	3843055	Gas shortage
147	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'75	220	0	0	
148	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	0	0	Gas shortage
149	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1'282+1'132	414	262	6075345	Gas shortage
150	Santahar 50 MW Peaking PP	PDB	6'8.7	50	33	484404	Engine problem