

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 9-Apr-23

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT	PDB	0	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	0	1210	180	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	78	1880772	Gas shortage
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	398	9394180	
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	323	7422000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	10087500	
9	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	92	1739520	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	304	7085004	FGMO
11	Madanganj 102 PP(Summit)	NENP	6'17	102	49	1567982	Engine problem
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1227471	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIIPP, REB	8'2.90	22	16	360792	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	1001000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	86	1555200	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	215	4787348	ST U/M.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1794960	
20	Kalabotti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	55	262800	Fuel shortage
22	Kodda 150 MW PP	BPDB-RPCL	9'17.06	149	150	2044320	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	687790	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	666720	
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIIPP REB	3'3.67+4'8.73	80	48	969780	Engine problem
27	Madona 33 MW PP(Summit)	SIIPP REB	4'8.73	33	33	783100	
28	Ruganaj 33 MW PP(Summit)	SIIPP REB	4'8.73	33	32	746200	
29	Gazipur 52 MW PP	RPCL	6'8.9	52	42	789120	Engine problem
30	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	278	6127200	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	103	977733	Low Demand
33	Bramhanagar 100 MW PP (Aggreko)	IPP	114'9.959	100	85	610835	Engine problem
34	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	530184	Low Demand
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	139	3070368	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2233843	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	90	1714560	Fuel shortage
38	Manikganj 162MW PP(MPGL)	IPP	9'18	162	126	1293120	Engine problem
39	Spectro Solar Plant Ltd.	IPP	0	35	0	224054	
40	Kanchan Furibachal Power Generation Ltd.	IPP	18.4'3	55	35	637720	Fuel shortage
Dhaka area Total				5847	3809	78819976	
41	Chattoagram TPP-1	PDB	1'210	180	0	0	Gas shortage
42	Chattoagram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Racozan 25 MW PP	RPCL	3'8.9	25	25	565516	
44	Teknaf 20MW PP (Solaritech)	IPP	0	20	0	139050	
45	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	19	202560	Fuel shortage
46	Kapila Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	308760	Low Water level
47	Sikalbaha 225MW	PDB	1'150+1'75	225	175	4326813	Gas shortage
48	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	68	710072	Fuel shortage
50	Halflahazi 100 MW peaking PP	PDB	11'8.9	98	32	469920	Engine problem
51	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	85	1201183	Engine problem
52	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	77	1214640	Fuel shortage
53	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	100	1457280	
54	Barabkundia 22 MW PP (Regent)	SIIPP, PDB	8'2.90	22	11	265344	Gas shortage
55	Malancha, Cto. EPZ Unit-1	IPP	5'8.73+9'9.34	0	32	572160	
56	Chattoagram 108 MW PP (ECPV)	PDB	16'7	108	84	1236480	Fuel shortage
57	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	30602	
58	Anwara 300 MW PP (United)	IPP	17'17+24	300	232	3821345	Fuel shortage
59	Jodiach Power	IPP	3'18.55+1'3.6	54	54	486374	
60	Kanaphuli Power Ltd.	IPP	18.415'6+8.5	110	54	1401744	Fuel shortage
61	Juldah unit-2 (Accorn)	IPP	8'13.6	100	76	1488960	Engine problem
62	Anilima Energy Ltd.	IPP	8'21.2	116	107	2412491	Engine problem
63	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	0	0	On test.
Chattoagram area Total				2382	1256	22361294	
64	Ashuganj TPP Unit- 3	APSCl	1'150	0	0	0	Contract Expired
65	Ashuganj TPP Unit- 4	APSCl	1'150	0	0	0	Contract Expired
66	Ashuganj TPP Unit- 5	APSCl	1'150	134	0	0	Contract Expired
67	Ashuganj 225 MW CCPP	APSCl	1'142+1'75	221	210	5098000	Gas shortage
68	Ashuganj 450 MW CCPP(North)	APSCl	1'360	360	300	7632000	Gas shortage
69	Ashuganj 450 MW CCPP(South)	APSCl	1'360	360	320	4300800	Gas shortage
70	Ashuganj 420 MW CCPP(East)	APSCl	284'1+116'1	400	0	0	Under maint.
71	Ashuganj 50 MW PP	APSCl	14'3.968	45	43	1039464	
72	Ashuganj 55 MW PP (Precision)	QRPP	55	0	0	0	Gas shortage
73	Ashuganj 195MW PP (APSCl-United)	IPP	20'9.73+1'16	195	55	2391999	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	43	976633	Engine problem
75	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	139	1604145	Engine problem
76	Titas 50 MW Peaking PP	PDB	6'8.92	52	37	530912	Engine problem
77	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
78	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	190	4538400	Engine problem
79	Feni 22MW PP (Doreen)	SIIPP, PDB	8'2.90	22	13	390744	Engine problem
80	Feni 11 MW PP (Doreen)	SIIPP, REB	4'2.90	11	8	167760	Engine problem
81	Import (Tripura)	Imported power	0	160	120	2560320	
82	Jangalia 33MW PP (Summit)	SIIPP, PDB	4'8.73	33	33	799000	
83	Jangalia 52 MW PP (Laksharavi)	IPP	8'9.92	52	10	1048186	
84	Qumilla 25 MW PP (Summit)	SIIPP, REB	3'3.67+2'6.97	25	21	432220	Engine problem
85	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	10	280704	Low Demand
86	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	2066820	
87	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	107	707280	Engine problem
88	Bharob 54.5 MW	IPP	3'18.2	54	36	851400	Engine problem
89	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	115	1386240	
Qumilla Area Total				3285	1966	36803027	
90	RPCL 210MW CCPP	IPP	4'35+1'70	202	82	1224000	Gas shortage
91	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8'2.90	22	19	442764	Engine problem
92	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
93	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	15200	
94	Mymensingh 200 MW PP (United)	IPP	9'78'21	154	200	2448000	Fuel shortage
95	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	99	1831200	Engine problem
96	Sutakhali 50 MW Solar PP	IPP	50	50	0	355080	
97	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	19	451920	Engine problem
Mymensingh Area Total				614	373	6768164	
98	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	37	897000	Machine problem
99	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	42	947460	Machine problem
100	Kushibara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Machine problem
101	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
102	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1256400	
103	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	49	1112184	
104	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4'2.90	11	8	176400	Engine problem
105	Shahjibazar GTTP Unit- 3 & 9	PDB	2'35	96	61	1448216	
106	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	89	2098560	
107	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
108	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	202	5135670	Machine problem
109	Sylhet 20 MW GTTP	PDB	1'20	20	18	396000	
110	Sylhet 50MW PP (EP)	NENP	2'7.2	0	0	0	Contract Expired
111	Shahjahanulla 25 MW PP	SIIPP, REB	3'9.34	25	16	379344	Engine problem
112	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	280	6522000	FGMO
113	Bibiyana-III 400 MW CCPP	PDB	285'1+134'1	400	373	8877000	FGMO
114	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	8	211680	
115	Bibiyana South 400 MW	PDB	400 MW	383	400	9228300	
Sylhet Area Total				2427	1636	38689214	
116	Bheramara GTTP Unit-3	PDB	0	120	0	0	Fuel shortage
117	Bheramara (HVDC)	Imported power	2'500	1000	804	21314181	
118	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	96	1740480	Engine problem
119	Fardipur 50 MW Peaking PP	PDB	8'6.89	54	38	400800	Engine problem
120	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation
121	Gosairganj 100 MW Peaking PP	PDB	16'8.98	109	58	539264	Engine problem
122	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	165	4822848	Gas shortage
123	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	32	703500	Engine problem
124	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	191040	Fuel shortage
125	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	11	66720	Fuel shortage
126	Madhumati 160 MW PP	NWPGCL	6'18	105	105	1861632	
127	Mongia Orion 100 MW Solar PP	IPP	100	100	0	699600	
128	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110				