

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		12-Apr-23				Page -2	
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	79	1827454	Gas shortage
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	407	968620	
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	333	778000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	10093000	
9	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	91	1478400	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	280	7143215	FGMO
11	Madanganj 102 PP(Summit)	NENP	6'11.7	102	93	1737960	Engine problem
12	Madanganj-25 MW PPSummit)	IPP	3'17.08+1'11.3	55	30	1062890	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIIPP, REB	8'2.90	22	22	419796	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	85	1517760	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	213	5149911	ST U/M.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1637712	
20	Kaipoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	265480	Fuel shortage
22	Kodda 150 MW PP	BPDB-RRCL	9'17.08	127	127	2216160	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	665298	
24	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	666203	
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi-Ashulia)	SIIPP REB	3'3.67+4'8.73	80	51	1072200	Engine problem
27	Madona 33 MW PP(Summit)	SIIPP REB	4'8.73	33	33	743500	
28	Ruguna 33 MW PP(Summit)	SIIPP REB	4'8.73	33	31	725900	
29	Gazipur 52 MW PP	RPCL	6'8.9	52	50	981120	0.00
30	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	270	4900252	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	90	1650700	Low Demand
33	Bramhanaga 100 MW PP (Aggreko)	IPP	114'9.959	83	100	749632	Engine problem
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	87	782167	Engine problem
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	113	2112912	Fuel shortage
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2353123	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	72	1590720	Fuel shortage
38	Manikganj 162MW PP(MPGL)	IPP	9'18	162	144	1260160	Fuel shortage
39	Spectro Solar Plant Ltd.	IPP	35	0	0	228676	
40	Kanchan Furibachal Power Generation Ltd.	IPP	18.4'3	55	54	945440	
Dhaka area Total				5847	3820	77919961	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Gas shortage
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Racoon 25 MW PP	RPCL	3'8.9	25	25	468927	
44	Takraf 20MW PP (Solaritech)	IPP	0	20	0	138915	
45	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	19	300960	Fuel shortage
46	Kapila Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	300000	Low Water level
47	Sikalbaha 225MW	PDB	1'150+1'75	225	162	4130595	Gas shortage
48	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	68	1002799	Fuel shortage
50	Hajharan 100 MW peaking PP	PDB	11'8.9	98	47	851712	Engine problem
51	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	85	1942513	Engine problem
52	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	66	1163280	Fuel shortage
53	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	100	1460160	
54	Barakkunda 22 MW PP (Regent)	SIIPP, PDB	8'2.90	22	14	328560	Gas shortage
55	Malancha, Ctr. EPZ Unit-1	IPP	5'8.73+3'9.34	31	0	335120	
56	Chattogram 108 MW PP (ECVP)	IPP	16'7	108	49	362980	Fuel shortage
57	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	30961	
58	Anwara 300 MW PP (United)	IPP	17'17+24	300	231	3143891	Engine problem
59	Jodiac Power	IPP	3'18.55+1'3.6	54	54	513506	
60	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	71	1448575	Fuel shortage
61	Juldah unit-2 (Accorn)	IPP	8'13.6	100	90	1453440	
62	Anilima Energy Ltd.	IPP	8'21.2	116	107	2580600	Engine problem
63	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	17	8854	On test.
Chattogram area Total				2382	1261	22246048	
64	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
65	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
66	Ashuganj TPP Unit- 5	APSCL	1'150	0	0	0	Contract Expired
67	Ashuganj 225 MW CCPP	APSCL	1'142+1'75	221	212	5059000	FGMO
68	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	360	7901000	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	240	6578000	FGMO
70	Ashuganj 420 MW CCPP(East)	APSCL	284'1+116'1	400	0	0	Under maint.
71	Ashuganj 50 MW PP	APSCL	14'3.968	45	43	1019552	
72	Ashuganj 55 MW PP (Precision)	QRPP	55	0	0	0	Gas shortage
73	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	175	2341818	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	43	1000760	Engine problem
75	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	118	1294690	Engine problem
76	Titas 50 MW Peaking PP	PDB	6'8.92	52	42	916576	Engine problem
77	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
78	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	174	4159240	Engine problem
79	Feni 22MW PP (Doreen)	SIIPP, PDB	8'2.90	22	17	406548	Engine problem
80	Feni 11 MW PP (Doreen)	SIIPP, REB	4'2.90	11	8	177840	Engine problem
81	Import (Tripura)	Imported power	0	160	116	2941440	
82	Jangalia 33MW PP (Summit)	SIIPP, PDB	4'8.73	33	33	598000	
83	Jangalia 52 MW PP (Lakshmi)	IPP	8'9.9.92	0	0	139493	Engine problem
84	Cumilla 25 MW PP (Summit)	SIIPP, REB	3'3.67+2'6.97	25	21	449940	Engine problem
85	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	714240	Fuel shortage
86	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	1736640	
87	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	115	904680	
88	Bharob 54.5 MW	IPP	3'18.2	54	35	887400	Engine problem
89	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	73	1396800	Fuel shortage
Cumilla Area Total				3285	1939	40626057	
90	RPCL 210MW CCPP	IPP	4'35+1'70	202	96	1246080	Gas shortage
91	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8'2.90	22	19	428292	Engine problem
92	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
93	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	14700	
94	Mymensingh 200 MW PP (United)	IPP	9'78'21	173	200	2577600	Fuel shortage
95	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	108	1832400	Engine problem
96	Sutiakhali 50 MW Solar PP	IPP	50	50	0	366310	
97	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	19	454320	Engine problem
Mymensingh Area Total				614	415	6919702	
98	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	36	887000	Machine problem
99	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	41	916680	Machine problem
100	Kushara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Machine problem
101	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
102	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1201800	
103	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	48	1052136	
104	Hidiganj 11MW PP Confidence-E	SIIPP, REB	4'2.90	11	9	192384	Engine problem
105	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	62	148686	
106	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	86	2022720	
107	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
108	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	203	5094010	Machine problem
109	Sylhet 20 MW GTTP	PDB	1'20	20	0	0	
110	Sylhet 50MW PP (EP)	NENP	2'72	0	0	0	Contract Expired
111	Shahjahanulla 25 MW PP	SIIPP, REB	3'9.34	25	16	378384	Engine problem
112	Bitiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	6565500	FGMO
113	Bitiyana-III 400 MW CCPP	PDB	285'1+134'1	400	410	8974000	
114	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	9	191880	
115	Bitiyana South 400 MW	PDB	400 MW	383	400	9260900	
Sylhet Area Total				2427	1642	38146290	
116	Bheramara GTTP Unit- 3	PDB	1'20	16	0	0	Fuel shortage
117	Bheramara (HVDC)	Imported power	2'500	1000	826	21672727	
118	Kulna 115 PP MW (KPCL-2)	NENP	7'17	115	66	1324800	Engine problem
119	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	34	326400	Engine problem
120	Kulna 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation
121	Gosairganj 100 MW Peaking PP	PDB	16'8.98	100	67	653184	Engine problem
122	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	180	4583232	Gas shortage
123	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	32	536625	Engine problem
124	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	2	24960	Low Demand
125	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	55	1112160	Fuel shortage
126	Madhumati 105 MW PP	NWPGCL	6'18	105	105	1918368	
127	Mongia Orion 100 MW Solar PP	IPP	100	100	0	707760	
128	Kulna 330 MW CCPP (DIL)	BPDB	1'220+1'110	0	228	186938	On test.
129	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	660'2	617	403	9527273	On test.
130	Kulna 225 MW CCPP (GAS)	NWPGCL	0	0	0	0	
Kulna Area Total				3001	1988	44258427	
131	Bairaal 110 MW PP (Summit)	IPP	7'17.076	110	48	624288	Line O/L
132	Bhola 33 MW PP (Venture)	NENP	1'34.50	34	40	630302	Engine problem
133	Bhola 225 MW CCPP	PDB	2'63+1'68	194	157	4030446	Machine problem
134	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	0	0	0	Contract Expired
135	Payra 1320 MW	BCPCL	2'622	1244	1244	30803200	
136	Bhola Nutan Biddut BD LTD	IPP	220	220	0	0	Under maint.
137	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	150	2006400	
138	Bairaal 307 MW	BCPCL	307'1	0	0	0	On test.
Bairaal Area Total				2265	7633	38156336	
139	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
140	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
141	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	31	493584	Engine problem
142	Bera 70 MW Peaking PP	PDB	9'8.29	71	35	544967	Engine problem
143	Annuar 50 MW PP(Sinha)	QRPP	717.79	18	10	404630	Contract Expired
144	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	34	547232	Engine problem
145	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	40	829100	Engine problem
146	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'75	210	179	4531327	Gas shortage
147	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'75	220	0	0	
148	Sirajgonj Unit-3 225MW	NWPGCL	1'141.1	220	0	0	Gas shortage
149	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1'282+1'132	414	362	8398763	Gas shortage