

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month April, 2023				Day : Thursday				Date : 13.04.23				
Probable Maximum Demand : 15200 MW				Probable Maximum Generation : 15303 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 76.23 ft		Today = 76.14 ft		13.04.23		Rule Curve = 85.60 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.04.23 (Yesterday)		13.04.23 (Today)		12.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Gas Shortage	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	79	81	81	29	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	318	333	335	335			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	407	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	202	213	200	210	122	ST Under maint.	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	298	280	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	30	15	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	92	102	102	102			
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	19	22			
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	34	51	47	47			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	31	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	50	42	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	95	127	32	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	291	270	195	295			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	95	113	149	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	105	90	300	300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	83	90	90			
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	87	87	90	90			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	72	54	72			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	144	54	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	54	35	54			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	80	85	60	85			
36	Meghnaghat 100 MW(IEU)	HFO (NENP)	12x8.9	100	100	81	91	65	92			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	92	93	95	95			
Dhaka Zone Total			6004	5847	3609	3820	3661	4181	709	497		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	0	0	205	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	14	19	6	18			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	68	51	85			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	176	162	180	180			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	121	231	120	230			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	50	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	80	85	80	84			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	47	46	47			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	14	14	8	Gas Shortage	
*	Malancha, Ctp EP2 (United)	Gas	5x8.73+3x9.34		2	31	5	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	49	6	50			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	0	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	71	72	92			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	90	63	90			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	55	66	45	66			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	17	0	0		on test	
Chattogram Zone Total			2442	2382	919	1261	895	1262	393	330		
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	41	43	44	44			
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	205	212	200	210			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	240	250	305			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	295	360	320	330			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55	Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	63	175	175	45	20	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	42	118	20	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	42	40	41			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	159	174	175	175			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	0	0	8			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	21	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	50	0	100	150			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	0	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	37	115	9	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	50	73	72	92			
**	limport (Tripura)	India		160	160	132	116	135	153			
Cumilla Zone Total			3159	3151	1549	1939	1697	2095	75	563		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	96	32	90	106	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	19	19			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	108	98	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	135	173	150	165			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	50	0	0			
86	Tangail 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	18	19	19	19			
Mymensingh Zone Total			622	614	342	415	370	408	106	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.04.23 (Yesterday)		13.04.23 (Today)		12.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)						
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	36	36	36	36		34	GT-1 & ST-1 Under maint.					
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	42		49	GT-4 Under maint.					
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51								
90	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.					
91	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	62	62	62								
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86								
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	200	203	208	208								
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0								
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	8	9								
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	270	280	280								
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	368	410	368	368								
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	400	400	400								
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	41	48	49	49								
Sylhet Zone Total						2472	2427	1573	1642	1614	1615	9	567				
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	180	180	180	230		Gas Shortage					
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	40								
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	57	0	65								
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	2	0	0								
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	55	35	55								
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	105	50	105								
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0								
113	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	49	66	99	99								
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	32	8	40								
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	402	403	400	400								
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				29	228	0	0								
**	Bheramara (H/DC)	India		1000	1000	925	826	940	940								
Khulna Zone Total						3005	3001	1773	1988	1812	1924	230	0				
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	16	16								
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	28	34	20	33								
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	170	157	170	170								
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1202	1244	1200	1244								
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	54	150	17	150								
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0								
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.					
Barishal Zone Total						2265	2265	1470	1633	1423	1613	0	220				
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage					
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage					
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	29	31	0	30								
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	10	35	0	43								
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	44	90	54	90								
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	40	40								
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	34	0	42								
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	34	35	35								
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	185	179	170	170	31		Gas Shortage					
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage					
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage					
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	331	362	330	350	52		Gas Shortage					
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	21	21	21								
136	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	0	8								
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	95	0	95								
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	0	70								
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0								
Adani Power Jharkhanda Ltd							747	755	755	755							
Rajshahi Zone Total						2129	2129	1470	1765	1422	1760	694	0				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	240	240	240	34		Coal Shortage					
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	15	15	0	0								
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	113	34	113								
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	8	10	0	0								
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0								
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	73	0	72								
148	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0								
Teesta Solar Limited							184	0	130	0							
Rangpur Zone Total						830	750	516	451	442	425	119	85				
Sub-total: Plants in operation						22928	22566	13221.0	14914	13336	15283	2335	2262				
(B) Plants under long term maintenance/ contract expired																	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
151	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
153	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	21	18	20	20								
Sub-Total: Plants under long term maintenance/ contract expired						404	0	21	18	20	20						
Gross Total						23332	22566	13242	14932	13356	15303	2335	2262				
(C) Actual data of 12.04.23 (Yesterday) Wednesday :																	
01.	Max. Demand at eve. peak (Generation end)	:	15154	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	14624	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	14932	MW, at =	21:00 hrs	Dhaka	5144	5102	42	Mymensingh	1206	1083	123				
04.	Minimum Generation (Generation end)	:	10887	MW, at =	7:00 hrs	Chattogram	1482	1482	0	Sylhet	583	583	0				
05.	Day-peak Generation (Generation end)	:	13242	MW, at =	12:00 hrs	Khulna	1784	1784	0	Barishal	467	467	0				
06.	Evening-peak Generation (Generation end)	:	14932	MW, at =	21:00 hrs	Rajshahi	1644	1644	0	Rangpur	893	893	0				
07.	Evening Peak Load-shed (Sub-station end)	:	205	MW, at =	21:00 hrs	Cumilla	1420	1380	40								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10941	MW, at =	5:00 hrs					Total	14624	14419	205				
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :		(a) Gas = 159731405 Taka	(c) Coal = 302786712 Taka								
	a) Gas/LF limitation	:	2011	MW				(b) Oil = 1101213416 Taka	Total = 1563725533 Taka								
	d) Coal supply Limitation	:	119	MW		14. Maximum Temperature in Dhaka was : 38.9° C											
	b) Low water level in Kaptai lake	:	205	MW		15. Export through East-West interconnections :											
	c) Plants under shut down/ maintenance	:	2262	MW		At evening peak-hour : 13242 MW, at 21:00 hrs											
10.	Total Energy (Generation + India Import)	:	314.92	MKWh		Maximum : 480 MW, at 20:00 hrs											
	By Gas = 142.295 MKWh			By Oil = 81.376 MKWh		Energy : 0 MKWh											
	By Coal = 63.228 MKWh			By Hydro = 0.300 MKWh													
	By Solar = 3.105 MKWh																
11.	Total Gas Supplied	:	1056.29	MMCFD													
(D) Forecast of 13.04.23 (Today) Thursday :																	
01.	Maximum Demand	:	15200	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	15303	MW	(Generation end)	05.	Total Generation	:	320.57	MKWh							
03.	Reserve / Shortage	:	103	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	40.8° C								