

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		15-Apr-23				Page -2	
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Gas shortage
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4268250	
4	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
5	Ghorashal 78.5 MW PP (MAX)	QRPP	2'40	0	240	0	
6	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	70	1787727	Gas shortage
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	404	9728000	
9	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	324	7664000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	10023500	
11	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	65	1276800	Engine problem
12	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	280	7173993	FGMO
13	Madaniganj 102 PP(Summit)	NENP	6'17	102	93	1902946	Engine problem
14	Madaniganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	548965	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIIPP, REB	8'2.90	22	19	372960	
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	95	2456000	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	80	1681920	Engine problem
20	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	0	903691	Under maint.
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	100	1725552	
22	Kaipoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	259920	Fuel shortage
24	Kodda 150 MW PP	BPDB-RPCL	9'17.08	149	144	1859520	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	671448	
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	666031	
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIIPP, REB	3'3.67+4'8.73	80	33	1075440	Engine problem
29	Maona 33 MW PP(Summit)	SIIPP, REB	4'8.73	33	25	677520	
30	Rupganj 33 MW PP(Summit)	SIIPP, REB	4'8.73	33	30	537400	
31	Gazipur 52 MW PP	RPCL	6'8.9	52	49	1109760	
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	278	4586618	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	227	5741447	Low Demand
35	Bramhangao 100 MW PP (Aggreko)	IPP	114'9.959	100	77	1794111	Engine problem
36	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	85	1899814	Engine problem
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	2077344	
38	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2537520	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	72	1432320	Fuel shortage
40	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	1281600	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	196529	
42	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	50	924120	
Dhaka area Total				5847	3846	80842766	
43	Chattoigram TPP-1	PDB	1'210	180	0	800000	Gas shortage
44	Chattoigram TPP-2	PDB	1'210	180	0	0	Gas shortage
45	Racoon 25 MW PP	RPCL	3'8.9	25	25	525857	
46	Teknaf 20MW PP (Solaritech)	IPP	20	20	0	132975	
47	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	19	270720	Fuel shortage
48	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	324780	Low Water level
49	Sikalbaha 225MW	PDB	1'150+1'75	225	360	8227000	Under maint.
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	85	973527	Engine problem
52	Hathazari 100 MW peaking PP	PDB	11'8.9	98	64	937008	Engine problem
53	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	82	1569494	Engine problem
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	66	906240	Engine problem
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	88	1283520	Engine problem
56	Barabkundia 22 MW PP (Regent)	SIIPP, PDB	8'2.90	22	11	279744	Gas shortage
57	Malancha, Ctr. EPZ (United)	IPP	5'8.73+3'9.34	0	20	443040	
58	Chattoigram 108 MW PP (ECPV)	IPP	16'7	108	4	166080	Fuel shortage
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	29055	
60	Anwara 300 MW PP (United)	IPP	17'17+24	300	222	2892982	Fuel shortage
61	Jodiac Power	IPP	3'18.55+1'3.6	54	54	491819	
62	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	83	1482866	Fuel shortage
63	Juldah unit-2 (Accorn)	IPP	8'13.6	100	90	1302720	
64	Anilima Energy Ltd.	IPP	8'21.2	116	84	2112655	Engine problem
65	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	0	225828	On test.
Chattoigram area Total				2382	1022	18386502	
66	Ashuganj TPP Unit- 3	APSCl	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit- 4	APSCl	1'150	0	0	0	Contract Expired
68	Ashuganj TPP Unit- 5	APSCl	1'150	134	0	0	Contract Expired
69	Ashuganj 225 MW CCPP	APSCl	1'142+1'75	221	210	5047000	FGMO
70	Ashuganj 450 MW CCPP(North)	APSCl	1'360	360	0	0	FGMO
71	Ashuganj 450 MW CCPP(South)	APSCl	1'360	360	360	8227000	FGMO
72	Ashuganj 420 MW CCPP(East)	APSCl	284'1+116'1	400	0	0	Under maint.
73	Ashuganj 50 MW PP	APSCl	14'3.968	45	38	901440	
74	Ashuganj 55 MW PP (Precision)	QRPP	55	0	15'4	0	Gas shortage
75	Ashuganj 195MW PP (APSCl-United)	IPP	20'9.73+1'16	195	195	4650181	
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1009087	
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	112	1239490	Engine problem
78	Titas 50 MW Peaking PP	PDB	6'8.92	52	42	893200	Engine problem
79	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
80	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	192	4054080	Engine problem
81	Feni 22MW PP (Doreen)	SIIPP, PDB	8'2.90	22	16	24696	Engine problem
82	Feni 11 MW PP (Doreen)	SIIPP, REB	4'2.90	11	9	180540	Engine problem
83	** Import (Tripura)	Imported power	0	160	114	2894400	
84	Jangalia 33MW PP (Summit)	SIIPP, PDB	4'8.73	33	32	786400	
85	Jangalia 52 MW PP (Lakshmi)	IPP	6'8.92	52	52	626933	
86	Cumilla 25 MW PP (Summit)	SIIPP, REB	3'3.67+2'6.97	25	20	459890	Engine problem
87	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	10	1251648	Fuel shortage
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	1564080	
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	111	758520	
90	Bhairab 54.5 MW	IPP	3'18.2	54	35	888240	Engine problem
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	88	1370880	Fuel shortage
Cumilla Area Total				3285	1796	37022695	
92	RPCL 210MW CCPP	IPP	4'35+1'70	202	94	2063040	Gas shortage
93	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8'2.90	22	18	423252	Engine problem
94	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	11350	
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	177	2654400	Engine problem
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	97	1753200	Engine problem
98	Sutiakhal 50 MW Solar PP	IPP	50	50	0	277770	
99	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	19	453120	Engine problem
Mymensingh Area Total				614	405	7636132	
100	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	34	815000	Machine problem
101	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	30	682560	Machine problem
102	Kushara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	28227	Gas shortage
103	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1279200	
105	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	48	1126512	
106	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4'2.90	11	8	171696	Engine problem
107	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	61	138966	
108	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	84	2013120	
109	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
110	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	198	5052060	Machine problem
111	Sylhet 20 MW GTTP	PDB	1'20	20	17	103000	
112	Sylhet 50MW PP (EPL)	NENP	2'72	0	0	0	Contract Expired
113	Shahjahanulla 25 MW PP	SIIPP, REB	3'9.34	25	16	369912	Engine problem
114	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	265	6552500	FGMO
115	Bibiyana-III 400 MW CCPP	PDB	285'1+134'1	400	368	9093000	FGMO
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	8	190620	Engine problem
117	Bibiyana South 400 MW	PDB	400 MW	383	385	9107100	
Sylhet Area Total				2427	1575	37974203	
118	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
119	** Bheramara (HVDC)	Imported power	2'500	1000	663	16846545	
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	95	2095680	Engine problem
121	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	28	455520	Engine problem
122	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation
123	Gopalganj 100 MW Peaking PP	PDB	16'8.98	100	98	1089928	Engine problem
124	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	195	5102208	Gas shortage
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	40	765750	
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Fuel shortage
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	55	1310400	Fuel shortage
128	Madhumati 100 MW PP	NWPGCL	6'18	105	105	1254240	
129	Mongla Orion 100 MW						