

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month April, 2023		Day : Monday				Date : 17.04.23						
Probable Maximum Demand :		16000 MW		Probable Maximum Generation :		15160 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 76.02 ft		Today = 75.96 ft		16.04.23 (Yesterday)		17.04.23 (Today)				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.04.23 (Yesterday)		17.04.23 (Today)		Rule Curve = 84.80 ft.		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	120	40	0	180	325		Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	71	76	75	76	32		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	324	323	300	323			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	396	401	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	91	96	95	95	114		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	193	213	210	215		122	ST Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	292	300	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	15	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	82	92	90	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	20			
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	40	46	46	46			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	24	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	27	26	20	26			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	48	48	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	150	48	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	10	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	262	276	195	276			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	109	145	149	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	267	285	280	285			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	65	60	65			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	83	70	70	70			
29	Nababganj 55 MW PP (Southern power )	HFO (IPP)	3x19.3	55	55	55	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	82	54	82			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	162	54	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	33	51	35	51			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	77	80	60	80			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	69	89	88	89			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	92	90	92			
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>3881</b>	<b>4205</b>	<b>3686</b>	<b>4358</b>	<b>576</b>	<b>497</b>		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	100	0			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	37	6	30			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	51	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	150	210			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	121	229	120	230			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	62	100	50	87			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	62	66	60	66			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	42	60	51	60			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	14	14			
*	Malancha, Clq EPZ (United)	Gas	5x8.73+3x9.34			2	36	5	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	1	46	10	50			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	17	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	99	54	92			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	90	63	90			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	77	56	77			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			42	0	0	0			on test
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>850</b>	<b>1290</b>	<b>989</b>	<b>1342</b>	<b>205</b>	<b>330</b>		
58	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	32	41	40	41			
59	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	201	206	200	206			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	310	335	360	360			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	0	0	0	0		360	Under maint.
62	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0		400	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55		Gas Shortage
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	168	180	180	180			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	48	120	50	120			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	43	42	43			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	185	192	175	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	9	9	9			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	8	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	0	0	0	150			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	0	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	46	103	30	103			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	74	72	90			
**	limpoxt (Tirupre)	India		160	160	168	140	135	153			
<b>Cumilla Zone Total</b>			<b>3159</b>	<b>3151</b>	<b>1418</b>	<b>1765</b>	<b>1457</b>	<b>1977</b>	<b>55</b>	<b>923</b>		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	94	48	94	108		Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	19	19	19			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	97	95	97			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	142	186	150	186			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0			
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	19	19	19	22			
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>357</b>	<b>415</b>	<b>383</b>	<b>418</b>	<b>108</b>	<b>0</b>		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.04.23 (Yesterday)		17.04.23 (Today)		16.04.23 (Yesterday)	17.04.23 (Today)	Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening							
87	Fenchuganj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	34	34	34	34		GT-1 & ST-1 Under maint.				
88	Fenchuganj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	41	30	41		GT-4 Under maint.				
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51						
90	Kushira 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		ST Under maint.				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	60	32	60						
93	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330 Under maint.				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	82	80	82						
95	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	197	194	190	194						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	18	18						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	8	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16		Gas Shortage				
99	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	290	280	290						
100	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	359	347	350	350						
101	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	370	377	380	380						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100 Under project work				
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	42	47	48	49						
<b>Sylhet Zone Total</b>					<b>2472</b>	<b>2427</b>	<b>1525</b>	<b>1576</b>	<b>1525</b>	<b>1583</b>	<b>9</b>	<b>569</b>			
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	185	195	200	200		Gas Shortage				
106	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	11	30	20	35						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	15	56	52	60						
108	Khulna 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0						
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	37	36	36	36						
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	95	15	105	105						
112	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	90	0	100	0	0						
113	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	76	80	80	80						
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	40	40	40						
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617 Under maint.				
**	Bheramara (H/DC) India	Gas/HSD (B/PDB)		1000	1000	756	663	925	925						
<b>Khulna Zone Total</b>					<b>3005</b>	<b>3001</b>	<b>1475</b>	<b>1265</b>	<b>1558</b>	<b>1481</b>	<b>215</b>	<b>617</b>			
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	16	110						
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	26	37	20	37						
118	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	155	168	170	170						
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244						
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150						
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0						
122	Bhola 220MW CCGP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220 Under maint.				
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2265</b>	<b>1458</b>	<b>1709</b>	<b>1467</b>	<b>1711</b>	<b>0</b>	<b>220</b>			
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		Gas Shortage				
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		Gas Shortage				
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	15	7	20	20						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	45	0	45						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	78	80	75	80						
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	40	40						
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	34	34	34						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35						
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	175	174	175	175		Gas Shortage				
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		Gas Shortage				
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		Gas Shortage				
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	21	21	21						
136	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43						
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	95	35	95						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	95	35	95						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0						
<b>Adani Power Jharkhanda Ltd</b>							<b>750</b>	<b>760</b>	<b>755</b>	<b>755</b>					
<b>Rajshahi Zone Total</b>					<b>2129</b>	<b>2129</b>	<b>1610</b>	<b>1852</b>	<b>1652</b>	<b>1860</b>	<b>646</b>	<b>0</b>			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	64	0	0		Coal Shortage				
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		Under Overhauling				
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	200	200	200		Coal Shortage				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	17	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	106	34	95						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	114	0	114						
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	28	0	30	0						
	Teesta Solar Limited	Solar (IPP)				171	0	130	0						
<b>Rangpur Zone Total</b>					<b>830</b>	<b>750</b>	<b>458</b>	<b>501</b>	<b>402</b>	<b>409</b>	<b>95</b>	<b>85</b>			
<b>Sub-total: Plants in operation</b>					<b>22928</b>	<b>22566</b>	<b>13032.0</b>	<b>14578</b>	<b>13119</b>	<b>15139</b>	<b>1909</b>	<b>3241</b>			
<b>(B) Plants under long term maintenance/ contract expired</b>															
149	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilia 108MW PPLCLL	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	21	21	21	21						
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>404</b>	<b>0</b>	<b>21</b>	<b>21</b>	<b>21</b>	<b>21</b>					
<b>Gross Total</b>					<b>23332</b>	<b>22566</b>	<b>13053</b>	<b>14599</b>	<b>13140</b>	<b>15160</b>	<b>1909</b>	<b>3241</b>			
<b>(C) Actual data of 16.04.23 (Yesterday) Sunday :</b>															
01.	Max. Demand at eve. peak (Generation end)	: 16000 MW, at = 21:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	: 15273 MW, at = 21:00 hrs		Zone Demand Supply Load Shed Zone Demand Supply Load Shed											
03.	Highest Generation (Generation end)	: 14845 MW, at = 22:00 hrs		Dhaka 5382 5372 10 Mymensingh 1274 1025 249											
04.	Minimum Generation (Generation end)	: 12010 MW, at = 2:00 hrs		Chattogram 1506 1506 0 Sylhet 600 500 100											
05.	Day-peak Generation (Generation end)	: 13053 MW, at = 12:00 hrs		Khulna 1842 1492 350 Barishal 534 534 0											
06.	Evening-peak Generation (Generation end)	: 14599 MW, at = 21:00 hrs		Rajshahi 1605 1395 210 Rangpur 1012 880 132											
07.	Evening Peak Load-shed (Sub-station end)	: 1291 MW, at = 21:00 hrs		Cumilla 1518 1278 240											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11818 MW, at = 5:00 hrs		Total 15273 13982 1291											
09.	Generation shortfall at evening peak due to :	:		a) Gas/LF limitation : 1609 MW											
	a) Gas/LF limitation	: 1609 MW		b) Coal supply Limitation : 95 MW											
	c) Coal supply Limitation	: 95 MW		c) Coal = 316535452 Taka											
	d) Low water level in Kaptai lake	: 205 MW		d) Oil = 1243798359 Taka											
	e) Plants under shut down/ maintenance	: 3241 MW		Total = 1721154061 Taka											
10.	Total Energy (Generation + India Import)	: 310.43 MKWh		14. Maximum Temperature in Dhaka was : 40.6° C											
	By Gas = 139.893 MKWh	By Oil = 90.752 MKWh		15. Export through East-West interconnections :											
	By Coal = 55.634 MKWh	By Hydro = 0.502 MKWh		At evening peak-hour : 13053 MW, at 21:00 hrs											
	By Solar = 2.694 MKWh			Maximum : 146 MW, at 19:00 hrs											
11.	Total Gas Supplied	: 1101.85 MMCFD		Energy : 0.3465 MKWh											
<b>(D) Forecast of 17.04.23 (Today) Monday :</b>															
01.	Maximum Demand	: 16000 MW (Generation end)		04. Maximum Load-shed : 794 MW At evening peak (Sub-station end)											
02.	Maximum Generation	: 15160 MW (Generation end)		05. Total Generation : 334.58 MKWh											
03.	Reserve / Shortage	: -840 MW (Generation end)		06. Probable Max. Temperature in Dhaka : 41.3° C											

\* Cative Power \*\* Imported Power  
#Remarks: Highest Generation 15304 MW on 13-04-2023 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation