

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month April, 2023					Day : Wednesday					Date : 19.04.23				
Probable Maximum Demand :					15500 MW		Probable Maximum Generation :					15948 MW		
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 75.89 ft		Today = 75.77 ft		Rule Curve = 84.40 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.04.23 (Yesterday)		19.04.23 (Today)		18.04.23 (Yesterday)		19.04.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	120	120	120	120	134	126	Gas Shortage		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	66	74	75	76	34		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	334	330	340	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	396	394	400	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	62	35	64	64	70	105	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	214	216	216	216		119	ST Under maint.		
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	305	325	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	14	55	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	91	64	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	0	19	19					
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	41	46	46	46					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	32	32	32					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	48	48	48					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	146	32	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	264	270	300	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	119	148	149	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	280	295	300	300					
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	70	50	70					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	75	0	75					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	88	54	90					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	162	108	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	54	35	54					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	72	80	90	90					
36	Meghnaghat 100 MW(IEU)	HFO (NENP)	12x8.9	100	100	88	89	80	92					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	92	95	90	95					
Dhaka Zone Total				6004	5847	3740	4267	3895	4356	343	725			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	90	110	110	110					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	39	26	40					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	105	51	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	225	226	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	122	228	120	230					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	50	100					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	49	66	66	66					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	36	63	48	60					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	14	14					
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	15	5	15					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	52	0	52					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	107	68	105					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	88	63	90					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	66	77	55	77					
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			134	54	0	0			on test		
Chattogram Zone Total				2442	2382	1201	1555	1100	1500	205	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	41	41	41					
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	206	204	200	210					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	305	350	350	350					
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Under maint.			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55	Gas Shortage			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	167	155	155	155					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	43	43	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	50	147	53	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	44	40	44					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	193	192	195	195					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	7	9	9					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	0	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	115	129	130	130					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	0	114					
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	109	9	113					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	6	35	35					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	62	93	62	92					
**	limport (Tripura)	India		160	160	140	136	135	153					
Cumilla Zone Total				3159	3151	1473	1892	1536	1965	55	923			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	16	94	33	90	108	Gas Shortage			
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	18	18					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	97	100	100					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	125	164	140	165					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0					
86	Tangail 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	24	25	25	25					
Mymensingh Zone Total				622	614	291	395	368	398	108	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.04.23 (Yesterday)		19.04.23 (Today)		18.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	34	32	33	33		38	GT-1 & ST-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	41	41		50	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	50	51				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	112	112	112		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60				
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	83	84	85				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	199	200	200	200				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.55	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	275	280	290				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	403	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	393	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugonj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	43	45	44	49				
Sylhet Zone Total						2472	2427	1595	1747	1755	1772	9	572
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	190	210	210	220		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	17	24	22	35				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	48	72	66	72				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	160	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	55	55	55				
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	85	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	77	85	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	24	32	40	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	335	335		617	Under maint.	
	Khulna 330 MW CCPP	Gas/HSD (BDFB)				0	175	0	0				
**	Bheramara (HVDG)	India		1000	1000	925	850	943	943				
Khulna Zone Total						3005	3001	1412	1643	1856	1788	220	617
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	16	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	25	35	25	35				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	168	170	170	170				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	1470	1709	1472	1709	0	220
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	20	27	27				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	28	0	32				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	69	80	80	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	42	40	42				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	42	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	31	35	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	173	159	160	160	51		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	176	168	180	180	52		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	19	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	95	35	95				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				585	750	755	755				
Raishahi Zone Total						2129	2129	1656	1994	1839	2030	494	0
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	170	200	74		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	42	92	42	95				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Talsila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	111	0	114				
148	Lalmoinihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	30	0				
	Teesta Solar Limited	Solar (IPP)				170	0	130	0				
Rangpur Zone Total						830	750	448	403	380	409	159	85
Sub-total: Plants in operation						22928	22566	13286.0	15605	14201	15927	1593	3472
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalpottit 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	109	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	21	21	21	21				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	21	21	21	21		
Gross Total						23332	22566	13307	15626	14222	15948	1593	3472
(C) Actual data of 18.04.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	16131	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	15385	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	15626	MW, at =	21:00 hrs	Dhaka	5266	5266	0	Mymensingh	1231	1031	200
04.	Minimum Generation (Generation end)	:	11656	MW, at =	7:00 hrs	Chattogram	1429	1429	0	Sylhet	599	519	80
05.	Day-peak Generation (Generation end)	:	13307	MW, at =	12:00 hrs	Khulna	1986	1986	0	Barishal	489	489	0
06.	Evening-peak Generation (Generation end)	:	15626	MW, at =	21:00 hrs	Rajshahi	1803	1778	25	Rangpur	1015	865	150
07.	Evening Peak Load-shed (Sub-station end)	:	482	MW, at =	21:00 hrs	Cumilla	1568	1541	27				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12354	MW, at =	5:00 hrs					Total	15385	14903	482
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :							
	a) Gas/LF limitation	:	1229	MW			(a) Gas =	172690022	Taka	(c) Coal =	311027386	Taka	
	d) Coal supply Limitation	:	159	MW			(b) Oil =	1436626785	Taka	Total =	1920344193	Taka	
	b) Low water level in Kaptai lake	:	205	MW									
	c) Plants under shut down/ maintenance	:	3472	MW									
10.	Total Energy (Generation + India Import)	:	337.83	MKWh		14. Maximum Temperature in Dhaka was : 37.1° C							
	By Gas =	150.802	MKWh	By Oil =	105.790	15. Export through East-West interconnections :							
	By Coal =	53.486	MKWh	By Hydro =	0.307	At evening peak-hour							
	By Solar=	2.513	MKWh			Maximum							
						Energy							
11.	Total Gas Supplied	:	1174.57	MMCFD		: 0 MKWh							
(D) Forecast of 19.04.23 (Today) Wednesday :													
01.	Maximum Demand	:	15500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15948	MW	(Generation end)	05.	Total Generation	:	335.10	MKWh			
03.	Reserve / Shortage	:	448	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	42.6° C					