					POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT								
					DAIL	KLFOKI				Reporting	g Date :	20-Apr-23	
Till now the maximum	generation is : -	40.4		5648.0				21:0	00 Hrs on	19-Apr-23	A D		
The Summary of Yeste Day Peak Generation	erdays	19-Ар	13415.0 N	Seneration & Demand	Hour :		12:00		Today's Actual Min Ger Min. Gen. at	8:00	& Demand		11566
Evening Peak Generation			15648.0 M		Hour :		21:00		Available Max Generation				16030
E.P. Demand (at gen end)):		16096.0 M	/W	Hour:		21:00		Max Demand (Evening)	:			15500
Maximum Generation	:		15648.0 M	/W	Hour :		21:00		Reserve(Generation end)				530
Total Gen. (MKWH)	:		326.2	PORT / IMPORT THROUGH	System Loa	Factor :	86.85%		Load Shed	:			0
Export from East grid to W	/est arid :- Mavimum		EA	PORT/IMPORT THROUGH	EAST-WEST IN	248	MW	at	20:00		Energy		
Import from West grid to E	East grid :- Maximum						MW	at			Energy		
Actual :	Water	Level of Kaptai Lake at 6:00 A M on 75.69 Ft.(MSL),	2	0-Apr-23		Rule curve :		84.20	Ft.(MSL)				
Actual :		75.09 Ft.(MSL),				Rule curve :		84.20	Ft.(MSL)				
Gas Consumed :		Total =	1149.50 M	IMCFD.			Oil Con	sumed (PD		HSD : FO :			
Cost of the Consumed Fue	el (PDB+Pvt) :		Gas : Coal :		,942,456 ,718,493			Oil	: Tk1,148,853,209		Total : Tk1,6	26 514 157	
		Load Shedding & C		IKST	,7 10,493			Oil	. 181,140,033,209		TOTAL . IKI,	30,314,137	
Area		Yesterday							Today				
Alea		resterday		Estimated D	emand (S/S end)				Estimated Shedding (S/S	end)	Rate	es of Shedding	
		MW			vIW					MW	(On E	stimated Demand)	
Dhaka		0 0:0		4	869					0		0%	
Chittagong Area		0 0:0		1	351					0		0%	
Khulna Area		10 0:0 0 0:0			777 569					0		0% 0%	
Rajshahi Area Cumilla Area		0 0:0 120 0:0			339					0		0%	
Mymensingh Area		198 0:0			101					ő		0%	
Sylhet Area		40 0:0			197					ō		0%	
Barisal Area		0 0:0			401					0		0%	
Rangpur Area Total		60 0:C 428	0		3774					0		0%	
Total		Information of the Generating Units under shut d		ı.	2//4								
		Planned Shut- Down	<i>M</i> 11.				Farand	Shut- Dov					
							5) Raoz 6) Siddh 7) Shaji 8) Siraic	an unit-2 nirganj 210 l bazar 330 N	////				
Outage	Restore	Additional Information of Machine	s, lines, Interruption	/ Forced Load shed etc.			o) Dalla	ilai 307 ivivi					Remark
Time	Time												
08:13 08:14	12:37 12:35	Barishal 230/132kV S/S T-5 LT Scheduled S/D Due to Barishal 230/132kV S/S T-5 HT Scheduled S/D Due to											
08:53	12.35		Red not maintence										
09:06	12:59	Barapukuris-1 was sync. Gopalgan(IV)-Madraipur 132kV Ckt-1 Scheduled S/D from Madaripur 132/33kV end Due to High Temperature Maintenance											
		and from Gopalgani 400/132kVend.											
09:12	14:00	Gopalganj(N)-Madaripur 132kV Ckt-2 Scheduled S/D	from Madaripur 132/	33kV end Due to High Temper	ature Maintenance								
		and from Gopalganj 400/132kVend.											
09:33	10:44 09:38	Ishurdi 132/33kV S/S 132/33 kV T-1 HT Scheduled S/ Barnaulia-Hathazari 132 kV Ckt-1 is restored	D Due to for tighting i	vork									
09:55	11:35	Bheramara-GK 132kV Ckt-1 Scheduled S/D from Bher	amara 230/132k\/ en	4									
10:18	12:06	Bheramara-GK 132kV Ckt-1 Forced S/D from Bheram	ara(GK) 132/33kV en	Due to Line Ckt-1 Line DS B	phase redhot								
10:47		Khulna 330 MW CCPP GT was sync.											
10:54	11:30	Ishurdi 132/33kV S/S 132/33 kV T-2 HT Scheduled S/		intenance									
11:01	11:55	Satkhira 132/33kV S/S Transformer-2 (T-2) HT Tripper	I showing . relays.										
11:01	11:56 11:05	Satkhira 132/33kV S/S Transformer-2 (T-2) LT Tripped Chattak-Sylhet 132 kV Ckt-1 is restored.	showing . relays.										
	11:54	Aminbazar-Meghnaghat 230kV Ckt-1 is restored.											
12:00	11.54	Day Peak Generation = 13 415MW											
12:35	12:58	Kushtia 132/33kV S/S T-1 HT Tripped showing Trip re	ays Due to Winding	Temp high							80.08	//W load interrup.	
12:35	13:00	Kushtia 132/33kV S/S T-1 LT Tripped showing Trip rei	ays Due to Inter Trip	From 132KV TR FDR							80.08	//W load interrup.	
13:33	13:56	Narshingdi 132/33kV S/S T-1 HT Tripped showing RE	.670 relays Due to 5	HV Tripp.							58.01	//W load interrup.	
19:28	18:26 23:49	Narail 132/33kV S/S Capacitor Bank Bay is restored.											
21:00	23:49	Jhenaidah 230/132kV S/S Jhenaidah2-Jashore Ckt-1 I Evening peak Generation:15648 MW Loadshed about	Orced S/D Due to Ins	struction of ALDC									
21:00	1	Khulna 330 MW CCPP GT was shutdown.	420 MW										
22:44	1	Aminbazar 400/132kV Interim transformer 132kV CB v	as opened due to re-	hot at PG clamp of 132kV ia	k bus.								
22:47	I	Khulna 225MW GT was shutdown.											
23:10	1	BIPTC S/S 20DF13 Tripped showing 21R(Distance Re	lay) relays Due to Tri	pped by 21R Impedance									
04:05	l	Ashugonj North 360MW GT was sync.									1		
05:57 05:58	07:59 07:59	Cumilla(S) 132/33kV S/S TR-2 LT Forced S/D Due to	33Kv CT terminal R p	h Red hot.							38.0	//W load interrup.	
05:58 06:32	U/:59	Cumilla(S) 132/33kV S/S TR-2 HT Forced S/D Due to Feni 132/33kV S/S T-1(405T) HT Scheduled S/D Due	to 33ky bus e/down /	T-1) for chow clif 1 has DC	intenance work						38.07	//W load interrup. //W load interrup.	
00.32	I	S/D taken BPDB.	TO DOWN DUS SILIONIU (, or onow out-1 bus DS Ma	manand WUIK.						32.01	roau mierrup.	
07:00	1	Minimum Generation: 11696 MW											
	1	1											
	1											//W load interrup.	
	1										Baroa	aulia	
	1												
	1												
		i											

Sub Divisional Engineer	Executive Engineer	Superintendent Engineer
Network Operation Division	Network Operation Division	Load Despatch Circle