

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		19-Apr-23				Page -2	
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Gas shortage
3	Ghorasal TPP Unit-5	PDB	1'210	190	100	3575250	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	165	3208500	ST under S/D
5	Ghorashal 78.5 MW PP (MAX)	QRPP	2'40	0	0	0	
6	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	74	1708272	Gas shortage
7	Haripur GTTP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	394	9676450	Gas shortage
9	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	333	7812000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	10050000	
11	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	70	1257600	Engine problem
12	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	300	7228189	FGMO
13	Madanganj 102 PP(Summit)	NENP	6'11	102	97	1825017	Engine problem
14	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	50	514047	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	18	178205	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIIPP, REB	8'2.90	22	22	438444	
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	27	1004000	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	85	1251840	Engine problem
20	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	213	5135693	
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	91	1217808	Engine problem
22	Kaipoti 52 MW PP (Sirsha)	IPP	7'7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	655560	
24	Kodda 150 MW PP	BPDB-RPCL	9'17.08	149	145	2940960	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	837899	Fuel shortage
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	887002	
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIIPP, REB	3'3.67+4'8.73	80	46	1047000	Engine problem
29	Maona 33 MW PP(Summit)	SIIPP, REB	4'8.73	33	33	727900	
30	Rupganj 33 MW PP(Summit)	SIIPP, REB	4'8.73	33	30	638200	
31	Gazipur 52 MW PP	RPCL	6'8.9	52	49	1104960	0.00
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	300	3891600	
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	20	2365590	Low Demand
35	Bramhangano 100 MW PP (Aggreko)	IPP	114'9.959	100	50	712646	Low Demand
36	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	790459	Low Demand
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	123	1580544	Engine problem
38	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2515267	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	72	1307520	Fuel shortage
40	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	2328480	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	215715	
42	Kanchan Furibachal Power Generation Ltd.	IPP	18.4'3	55	36	557280	Engine problem
Dhaka area Total				5847	3854	81085897	
43	Chattoogram TPP-1	PDB	1'210	180	120	2600000	Gas shortage
44	Chattoogram TPP-2	PDB	1'210	180	0	0	Gas shortage
45	Racoon 25 MW PP	RPCL	3'8.9	25	25	603093	
46	Teknaf 20MW PP (Solaritech)	IPP	20	20	0	107055	
47	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	39	545760	Fuel shortage
48	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	70	335600	Low Water level
49	Sikalbaha 225MW	PDB	1'150+1'75	225	228	5244468	
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	1443563	
52	Hathazari 100 MW peaking PP	PDB	11'8.9	98	60	1091760	Engine problem
53	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	66	1397887	Engine problem
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	68	1326240	Engine problem
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	100	1520640	
56	Barabkundia 22 MW PP (Regent)	SIIPP, PDB	8'2.90	22	11	255984	Gas shortage
57	Malancha, Ctg. EPZ (United)	IPP	5'8.73+9'3.94	0	26	492480	
58	Chattoogram 108 MW PP (ECPV)	IPP	16'7	108	51	261120	Engine problem
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	24723	
60	Anwara 300 MW PP (United)	IPP	17'17+24	300	277	3221673	Fuel shortage
61	Jodiak Power	IPP	3'18.55+1'3.6	54	54	794796	
62	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	86	1708170	Fuel shortage
63	Juldah unit-2 (Accorn)	IPP	8'13.6	100	75	1328640	
64	Anilima Energy Ltd.	IPP	8'21.2	116	107	2580600	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.5'9	0	54	369672	On test.
Chattoogram area Total				2382	1620	27251924	
66	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
68	Ashuganj TPP Unit- 5	APSCL	1'150	0	0	0	Contract Expired
69	Ashuganj 225 MW CCPP	APSCL	1'142+1'75	221	210	4734000	FGMO
70	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	0	0	FGMO
71	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	300	7876000	FGMO
72	Ashuganj 420 MW CCPP(East)	APSCL	284'1+116'1	400	0	0	Under maint.
73	Ashuganj 50 MW PP	APSCL	14'3.968	45	40	942984	Gas shortage
74	Ashuganj 55 MW PP (Precision)	QRPP	55	0	19'4	0	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	135	3596363	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1121444	
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	140	2233091	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	137394	Engine problem
79	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
80	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	120	3308640	Fuel shortage
81	Feni 22MW PP (Doreen)	SIIPP, PDB	8'2.90	22	17	391932	Engine problem
82	Feni 11 MW PP (Doreen)	SIIPP, REB	4'2.90	11	7	203760	Engine problem
83	** Import (Tripura)	Imported power	0	160	142	3120000	
84	Jangalia 33MW PP (Summit)	SIIPP, PDB	4'8.73	33	31	767800	
85	Jangalia 52 MW PP (Laksharawi)	IPP	6'8.92	52	0	372566	Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIIPP, REB	3'3.67+2'6.97	25	21	481240	Engine problem
87	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	127	1700352	Fuel shortage
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	70	1446660	Fuel shortage
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	111	861000	
90	Bharob 54.5 MW	IPP	3'18.2	54	35	843840	Engine problem
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	83	1652160	Fuel shortage
Cumilla Area Total				3151	1650	35791226	
92	RPCL 210MW CCPP	IPP	4'35+1'70	202	81	1228800	Gas shortage
93	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8'2.90	22	18	339588	Engine problem
94	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
95	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	13550	
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	175	2577600	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	115	1826400	
98	Sutiakhal 50 MW Solar PP	IPP	50	50	0	307440	
99	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	23	560880	
Mymensingh Area Total				614	412	6854258	
100	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	32	780000	Machine problem
101	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	40	904320	Machine problem
102	Kushara 163 MW CCPP (KP)	IPP	1'109+1'54	163	112	2510345	ST under S/D
103	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1243800	
105	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	47	1098936	
106	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4'2.90	11	8	183456	Engine problem
107	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	61	1431648	
108	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	83	1881600	
109	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
110	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	195	5041630	Machine problem
111	Sylhet 20 MW GTTP	PDB	1'20	20	17	277000	
112	Sylhet 50MW PP (EPL)	NENP	2'72	0	0	0	Contract Expired
113	Shahjahanulla 25 MW PP	SIIPP, REB	3'9.34	25	16	373056	Engine problem
114	Bitiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	6567000	Gas shortage
115	Bitiyana-III 400 MW CCPP	PDB	285'1+134'1	400	402	9265000	FGMO
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	223920	
117	Bitiyana South 400 MW	PDB	400 MW	383	388	9210500	
Sylhet Area Total				2427	1734	40992211	
118	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
119	** Bheramara (HVDC)	Imported power	2'500	1000	923	21919272	
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	80	1351680	Engine problem
121	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	28	428160	Engine problem
122	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	180	642260	Fuel conservation
123	Gopalganj 100 MW Peaking PP	PDB	19'6.98	109	75	1257984	Engine problem
124	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	165	4631328	Gas shortage
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	40	619500	
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Fuel shortage
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	35	80640	Fuel shortage