

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month April, 2023				Day : Wednesday				Date : 26.04.23						
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 15469 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.30 ft		Today = 75.25 ft		Rule Curve = 83.00 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.04.23 (Yesterday)		26.04.23 (Today)		25.04.23 (Yesterday)		26.04.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCP Unit-4	Gas (PDB)	1 x 210	210	180	0	100	100	100				Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	55	79	16	80	29			Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	333	300	330					
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCP	Gas (EGCB)	1x273+1x139	412	412	394	401	350	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	40	40	90	100	65	105		Gas Shortage	
12	Siddhirgonj 335 MW CCP	Gas (EGCB)	1 x 217+1x118	335	335	192	190	218	218		145		ST Under maint.	
13	Meghnaghat CCP(Summit)	Gas (IPP)	2x110+1x110	335	335	282	308	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	48	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	18	10	18					
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	26	31	46	46					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	0	32	32					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	16	48	48					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	64	130	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	35	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	0	70					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300					
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	80					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	37	37					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	27	54	90					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	108	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	54					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	50	50					
36	Meghnaghat 100 MW(IEU)	HFO (NENP)	12x8.9	100	100	0	8	16	50					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	30	90	90					
Dhaka Zone Total				6004	5847	1964	2439	3593	4168	199	990			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	0	25	205			Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	39	26	40					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	105	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCP	Gas (PDB)	1 x 150+1 x 75	225	225	222	221	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	121	300	120	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	20	50	100					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	66	84					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	38	45	60					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13					
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			39	40	20	30					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	25	0	51					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	54	17	51					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	63	90					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	10	10	50	70					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	162	162				on test	
Chattogram Zone Total				2442	2382	727	1053	1256	1712	205	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	38	41	41					
59	Ashuganj 225 MW CCP	Gas (APSCL)	1x142+175	221	221	206	207	210	210					
60	Ashuganj 450 MW CCP(South)	Gas (APSCL)	1x360	360	360	300	270	270	270					
61	Ashuganj 450 MW CCP(North)	Gas (APSCL)	1x361	360	360	315	305	300	305					
62	Ashuganj 420 MW CCP(East)	Gas (APSCL)	1x284+1x116	400	400	355	0	0	0		400		Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55			Gas Shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	178	88	88	17			Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	25	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	10	80	150					
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	46	31	45					
68	Chandpur 150 MW CCP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under overhauling	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	17	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	8	9	9					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	21	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	25	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.095	200	200	0	10	0	0					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	17	17	114					
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	19	104	9	104					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	93	94	94					
**	limport (Tripura)	India		160	160	130	136	143	166					
Cumilla Zone Total				3159	3151	1580	1648	1480	1823	72	563			
80	RPCL 210MW CCP	Gas (IPP)	4x35+1x70	210	202	197	203	210	210					
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	115	75	115					
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	70	163	160	170					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	23	23	23					
Myensing Zone Total				622	614	408	520	536	534	0	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.04.23 (Yesterday)		26.04.23 (Today)		25.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	31	31	33	33		39	GT-1 & ST-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		62	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	53	51	51				
90	Kushiyara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	61	61	61				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	81	85	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	20	163	190	200				
96	Sylhet 20 MW GTTP	Gas (PDB)	1x20	20	20	17	18	20	20				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	280	310				
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	240	240	400	400		160	JGDCL RMS Problem	
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	390	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugonj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	42	47	44	44				
Sylhet Zone Total						2472	2427	1241	1456	1626	1665	9	745
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	355	360	250	350	50		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	22	35				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	55	75				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17				
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	32	0	32				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	98	0	100	0				
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	49	85	88				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BDFB)				0	0	0	0				
**	Bheramara (HVDCL)	India		1000	1000	924	837	930	930				
Khulna Zone Total						3005	3001	1417	1295	1459	1577	50	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	16				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	31	25	35				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	168	171	170	170				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	1090	750	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	689	1292	978	1615	0	220
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	65	70	70	70				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	26	26				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	34				
127	Chapinawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	40	80	80				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	8	24	42				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	130	214	200	200				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	201	210	160	210				
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	419	421	414	414				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	95	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	35	70				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				412	507	500	500				
Rajshahi Zone Total						2129	2129	1256	1639	1709	1856	320	0
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	75	75	75	10		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	275	220	220			Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	70	42	95				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Talsila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Teakurgaon 118MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	74	35	115				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	19	0	30	0				
	Teesta Solar Limited	Solar (IPP)				169	0	130	0				
Rangpur Zone Total						830	750	437	494	540	505	10	85
Sub-total: Plants in operation						22928	22566	9719.0	11836	13177	15455	865	2933
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalipoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CLO)	HFO (IPP)	12x8.775+1x3.5	116	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	14	14				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	14	14			
Gross Total						23332	22566	9719	11836	13191	15469	865	2933
(C) Actual data of 25.04.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	11857	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11279	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11836	MW, at =	21:00 hrs	Dhaka	3041	3041	0	Sylhet	1101	1081	20
04.	Minimum Generation (Generation end)	:	7813	MW, at =	6:00 hrs	Chattogram	1199	1199	0	Sylhet	509	509	0
05.	Day-peak Generation (Generation end)	:	9719	MW, at =	12:00 hrs	Khulna	1518	1518	0	Barishal	405	405	0
06.	Evening-peak Generation (Generation end)	:	11836	MW, at =	21:00 hrs	Rajshahi	1428	1428	0	Rangpur	812	812	0
07.	Evening Peak Load-shed (Sub-station end)	:	20	MW, at =	21:00 hrs	Cumilla	1267	1267	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9128	MW, at =	5:00 hrs					Total	11279	11259	20
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 170728543 Taka	(c) Coal = 207459354 Taka				
	a) Gas/LF limitation	:	650	MW				(b) Oil = 313548605 Taka	Total = 691736503 Taka				
	d) Coal supply Limitation	:	10	MW									
	b) Low water level in Kaptai lake	:	205	MW									
	c) Plants under shut down/ maintenance	:	2933	MW									
10.	Total Energy (Generation + India Import)	:	239.67	MKWh		14.	Maximum Temperature in Dhaka was :	35.2° C					
	By Gas = 150.169 MKWH			By Oil = 24.112 MKWh		15.	Export through East-West interconnections :						
	By Coal = 37.140 MKWH			By Hydro = 0.284 MKWh			At evening peak-hour	:	9719	MW, at	21:00 hrs		
	By Solar = 2.977 MKWH						Maximum	:	-10	MW, at	19:00 hrs		
11.	Total Gas Supplied	:	1158.74	MMCFD			Energy	:	0.198	MKWh			
(D) Forecast of 26.04.23 (Today) Wednesday :													
01.	Maximum Demand	:	13000	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15469	MW (Generation end)		05.	Total Generation	:	263.24	MKWh			
03.	Reserve / Shortage	:	2469	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	38.8° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation