

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 26-Apr-23									Page -2
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks		
			Unit No. X Capacity	MW	MW	KWH			
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.		
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	150	2664344			
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4312250			
4	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.		
5	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0			
6	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	76	1436454	Engine problem		
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.		
8	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	399	8681470			
9	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	333	7502000	Machine problem		
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	9661250			
11	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	9	318720	Low Demand		
12	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	281	7076975	FGMO		
13	Madaniganj 102 PP(Summit)	NENP	6'17	102	0	871195	Reserve		
14	Madaniganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	0	0	Fuel shortage		
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired		
16	Narsingdi 22 MW PP (Doreen)	SIIPP, REB	8'2.90	22	13	265032	Engine problem		
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Engine problem		
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	99	1352000	Under maint.		
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	40	296640	Low Demand		
20	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	142	3409020	ST Under maint.		
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	8	84528	Low Demand		
22	Kaipoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage		
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	17	121680	Low Demand		
24	Kodda 150 MW PP	BPDB-RPCL	9'17.06	149	48	746880	Low Demand		
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	17	187490	Low Demand		
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	17	184816	Low Demand		
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0			
28	Summit Power (Madhabdi-Ashulia)	SIIPP REB	33.67+48.73	80	41	792840	Engine problem		
29	Madona 33 MW PP(Summit)	SIIPP REB	4'8.73	33	25	594800	Engine problem		
30	Rugganj 33 MW PP(Summit)	SIIPP, REB	4'8.73	33	0	3300	Engine problem		
31	Gazipur 52 MW PP	RPCL	6'8.9	52	42	451680	Low Demand		
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.		
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	0	37636	Reserve		
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Reserve		
35	Bramhanaga 100 MW PP (Aggreko)	IPP	114'9.959	100	0	0	Reserve		
36	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve		
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	70	521136	Low Demand		
38	Gazipur 100 MW PP	RPCL	6'17.5	105	105	1181702			
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	35	953280	Low Demand		
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	72	501120	Low Demand		
41	Spectro Solar Plant Ltd.	IPP	35	35	0	222338			
42	Kanchan Furibachal Power Generation Ltd.	IPP	18.4'3	55	35	289520	Low Demand		
Dhaka area Total				5847	2704	54648494			
43	Chattoigram TPP-1	PDB	1'210	180	120	290000	Gas shortage		
44	Chattoigram TPP-2	PDB	1'210	180	0	0	Gas shortage		
45	Racoon 25 MW PP	RPCL	3'8.9	25	8	180727	Low Demand		
46	Takani 20MW PP (Solaritech)	IPP	20	20	0	138240			
47	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	18	264000	Fuel shortage		
48	Kapila Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	319680	Low Water level		
49	Sikalbaha 225MW	PDB	1'150+1'75	225	224	5099012			
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.		
51	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	17	281854	Low Demand		
52	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	331920	Reserve		
53	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	84	822471	Engine problem		
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	10	574920	Low Demand		
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	74	1467840	Low Demand		
56	Barabkundia 22 MW PP (Regent)	SIIPP, PDB	8'2.90	22	13	309072	Gas shortage		
57	Malancha, Ch. EPZ Unit-1	IPP	5'8.73+9.34	38	0	890880			
58	Chattoigram 108 MW PP (ECVP)	IPP	16'7	108	0	13440	Reserve		
59	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	33598			
60	Anwara 300 MW PP (United)	IPP	17'17+24	300	210	2064982	Low Demand		
61	Jodiach Power	IPP	3'18.55+1'3.6	54	17	235632	Low Demand		
62	Kanaphuli Power Ltd.	IPP	18.415'6+8.5	110	17	353780	Low Demand		
63	Juldah unit-2 (Accorn)	IPP	8'13.6	100	90	1470720	Low Demand		
64	Anilima Energy Ltd.	IPP	8'21.2	116	34	728991	Fuel shortage		
65	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	163	3658981	On test.		
Chattoigram area Total				2382	1162	22340640			
66	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired		
67	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired		
68	Ashuganj TPP Unit- 5	APSCL	1'150	0	0	0	Contract Expired		
69	Ashuganj 225 MW CCPP	APSCL	1'142+1'75	221	207	5021000	Contract Expired		
70	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	300	7588400	FGMO		
71	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	310	7026000	FGMO		
72	Ashuganj 420 MW CCPP(East)	APSCL	284'1+116'1	400	0	0	Under maint.		
73	Ashuganj 50 MW PP	APSCL	14'3.968	45	40	899640	Engine problem		
74	Ashuganj 55 MW PP (Precision)	QRPP	55	0	0	0	Contract Expired		
75	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	197	3479272			
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	725334			
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	0	215781	Reserve		
78	Titas 50 MW Peaking PP	PDB	6'8.92	52	46	653168			
79	Chandpur 150 MW CCPP	IPP	1'106+1'57	163	0	0	Under maint.		
80	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	34	593280	Fuel shortage		
81	Feni 22MW PP (Doreen)	SIIPP, PDB	8'2.90	22	18	411912	Engine problem		
82	Feni 11 MW PP (Doreen)	SIIPP, REB	4'2.90	11	8	205020	Engine problem		
83	Import (Tripura)	Imported power	0	160	140	3025920			
84	Jangalia 33MW PP (Summit)	SIIPP, PDB	4'8.73	33	33	748100			
85	Jangalia 52 MW PP (Lakshani)	IPP	6'8.92	52	52	1032802			
86	Qumilla 25 MW PP (Summit)	SIIPP, REB	3'3.67+2'6.97	25	21	466780	Engine problem		
87	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	40896	Fuel shortage		
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	106	2005260	Engine problem		
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	114	862680			
90	Bharob 54.5 MW	IPP	3'18.2	54	35	610920	Engine problem		
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	84	1690560	Engine problem		
Qumilla Area Total				3151	1806	37302725			
92	RPCL 210MW CCPP	IPP	4'35+1'70	202	202	4795200			
93	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8'2.90	22	19	379728	Engine problem		
94	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.		
95	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	11850			
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	164	200	2548900	Fuel shortage		
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	108	1771200			
98	Sutiakhali 50 MW Solar PP	IPP	50	50	0	332470			
99	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	411120	Engine problem		
Mymensingh Area Total				614	505	10250368			
100	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	32	76900	Machine problem		
101	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	28	633480	Machine problem		
102	Kushara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Under maint.		
103	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.		
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	998400			
105	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	45	892800			
106	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4'2.90	11	8	184368	Engine problem		
107	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	96	61	1288112			
108	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	80	1696320			
109	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.		
110	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	202	5015220	Machine problem		
111	Sylhet 20 MW GTTP	PDB	1'20	20	18	402000			
112	Sylhet 50MW PP (EPL)	NENP	2'72	0	0	0	Contract Expired		
113	Shahjahanulla 25 MW PP	SIIPP, REB	3'9.34	25	16	360408	Engine problem		
114	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	310	6988000	FGMO		
115	Bibiyana-III 400 MW CCPP	PDB	285'1+134'1	400	408	8859000	FGMO		
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	236680			
117	Bibiyana South 400 MW	PDB	400 MW	383	396	9134100			
Sylhet Area Total				2427	1667	37468888			
118	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage		
119	Bheramara (HVDC)	Imported power	2'500	1000	808	21344000			
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	44	541440	Low Demand		
121	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	0	3220	Reserve		
122	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation		
123	Gopalganj 100 MW Peaking PP	PDB	16'8.98	100	0	40072	Reserve		
124	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	410	8398728	FGMO		
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	51375	Reserve		
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Reserve		
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	17	98400	Low Demand		
128	Madhumati 100 MW PP	NWPGCL	6'18	105	0	175824	Reserve		
129	Mongla Orion 100 MW Solar PP	IPP	100	100					