

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month April, 2023				Day : Saturday				Date : 29.04.23						
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 15228 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.19 ft		Today = 75.16 ft		Rule Curve = 80.40 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.04.23 (Yesterday)		29.04.23 (Today)		28.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCP Unit-4	Gas (PDB)	1 x 210	210	180	0	220	150	150			Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	78	16	76	30		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCP(HPL)	Gas (IPP)	1x235+1x125	360	360	328	334	300	330					
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCP	Gas (EGCB)	1x273+1x139	412	412	403	393	400	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	99	100	90	100		105	1 Unit under maint		
12	Siddhirgonj 335 MW CCP	Gas (EGCB)	1 x 217+1x118	335	335	0	220	220	220		115	ST Under maint.		
13	Meghnaghat CCP(Summit)	Gas (IPP)	2x110+1x110	335	335	285	275	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	48	92					
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	10	10	18					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	36	43	43	43					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	30	32	32					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	41	41	41					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	150	149	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	35	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	15	70	17	70					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300					
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	80					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	17	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	54	70					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	5	126	126	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	8	34	17	35					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	0	8	16	50					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	90	90					
Dhaka Zone Total				6004	5847	1984	3020	3751	4217	135	960			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	1	25	26	35					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
46	Sikalbaha 225 MW CCP	Gas (PDB)	1 x 150+1 x 75	225	225	224	226	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	80	200	120	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	76	38	76					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	66	84					
50	Hathazeri 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	45	60					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	13	13					
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			33	38	15	35					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	50					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	9	51	17	51					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	76	63	90					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	0	78	50	70					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			163	163	162	162			on test		
Chattogram Zone Total				2442	2382	774	1204	1103	1526	205	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	40	41	40	40					
59	Ashuganj 225 MW CCP	Gas (APSCL)	1x142+175	221	221	210	211	210	210					
60	Ashuganj 450 MW CCP(South)	Gas (APSCL)	1x360	360	360	310	300	310	310					
61	Ashuganj 450 MW CCP(North)	Gas (APSCL)	1x361	360	360	310	310	310	310					
62	Ashuganj 420 MW CCP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0		400	Under maint.		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55		Gas Shortage		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	157	118	118	118					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	52	80	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	31	46					
68	Chandpur 150 MW CCP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	150	17	150					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	25	25	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	20	20	20					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.091	200	200	0	0	0	0					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	17	106					
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	7	113	9	113					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	16	17	35	35					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	31	93	94	94					
**	Impoport (Tripura)	India		160	160	88	144	143	165					
Cumilla Zone Total				3159	3151	1295	1711	1579	2020	55	563			
80	RPCL 210MW CCP	Gas (IPP)	4x35+1x70	210	202	157	160	162	162	42		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	16	19					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	88	75	115					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	144	173	160	170					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	40	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	12	12	12					
Mymensingh Zone Total				622	614	443	452	477	478	42	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.04.23 (Yesterday)		29.04.23 (Today)		28.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 & ST-1 Under maint.					
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	29	29	29		61	GT-4 Under maint.					
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51								
90	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	61	61								
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	80	80	85	85								
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	130	133	133	133								
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	16	18	18								
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	285	300	310								
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	369	415	400	400								
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	120	400	400	400								
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
103	Fenchugonj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	43	47	44	45								
Sylhet Zone Total						2472	2427	1214	1556	1555	1566	9	615				
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	350	340	350	350								
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	22	35								
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	55	74								
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0								
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17								
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100								
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	0	100								
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	33	85	98								
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	40								
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0								
	Khulna 330 MW CCPP	Gas/HSD (BDFB)				152	0	0	0								
**	Bheramara (HVDCL)	India		1000	1000	497	493	508	942								
Khulna Zone Total						3005	3001	1094	883	1137	1656	0	0				
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	64								
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	28	25	31								
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	70	70	70	70								
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	890	1112	900	1244								
120	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150								
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0								
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.					
Barishal Zone Total						2265	2265	983	1210	1028	1559	0	220				
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	70	70	70	1		Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage					
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	26	26								
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	34								
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	47	80	80								
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	42								
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42								
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	35	35								
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	174	174	190	190								
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage					
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	184	180	160	200								
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	373	376	380	380								
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22								
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8								
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	34	0	34								
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	95	113								
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	12	113	95	113								
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0								
	Adani Power Jharkhanda Ltd	Coal				508	522	500	500								
Raishahi Zone Total						2129	2129	1278	1666	1725	1889	321	0				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	76	75	75	9		Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	0	0	0			Coal Shortage					
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	95	113								
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
146	Majpara, Talsila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0								
147	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	35	115								
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0								
	Teesta Solar Limited	Solar (IPP)				80	0	130	0								
Rangpur Zone Total						830	750	474	304	373	303	9	85				
Sub-total: Plants in operation						22928	22566	9539.0	12006	12728	15214	776	2773				
(B) Plants under long term maintenance/ contract expired																	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
150	Kalpottit 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	116	0	0	0	0	0								
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	14								
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	14						
Gross Total						23332	22566	9539	12006	12728	15228	776	2773				
(C) Actual data of 28.04.23 (Yesterday) Friday :																	
01.	Max. Demand at eve. peak (Generation end)	:	12100	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	11555	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	12006	MW, at =	21:00 hrs	Dhaka	3594	3594	0	Mymensingh	1159	1094	65				
04.	Minimum Generation (Generation end)	:	7561	MW, at =	6:00 hrs	Chattogram	1251	1251	0	Sylhet	503	503	0				
05.	Day-peak Generation (Generation end)	:	9539	MW, at =	12:00 hrs	Khulna	1317	1317	0	Barishal	266	266	0				
06.	Evening-peak Generation (Generation end)	:	12006	MW, at =	21:00 hrs	Rajshahi	1393	1393	0	Rangpur	840	840	0				
07.	Evening Peak Load-shed (Sub-station end)	:	90	MW, at =	21:00 hrs	Cumilla	1232	1207	25								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9111	MW, at =	5:00 hrs					Total	11555	11465	90				
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :		(a) Gas = 169701788 Taka	(c) Coal = 242345113 Taka								
	a) Gas/LF limitation	:	562	MW				(b) Oil = 317655397 Taka	Total = 729702298 Taka								
	d) Coal supply Limitation	:	9	MW		14. Maximum Temperature in Dhaka was : 34.8° C											
	b) Low water level in Kaptai lake	:	205	MW		15. Export through East-West interconnections :											
	c) Plants under shut down/ maintenance	:	2773	MW		At evening peak-hour : 9539 MW, at 21:00 hrs											
10.	Total Energy (Generation + India Import)	:	233.51	MKWh		Maximum : -150 MW, at 20:00 hrs											
	By Gas = 145.002 MKWh			By Oil = 29.735 MKWh		Energy : 0.1485 MKWh											
	By Coal = 41.518 MKWh			By Hydro = 0.300 MKWh													
	By Solar= 2.664 MKWh																
11.	Total Gas Supplied	:	1164.67	MMCFD													
(D) Forecast of 29.04.23 (Today) Saturday :																	
01.	Maximum Demand	:	12500	MW (Generation end)		04.	Maximum Load-shed	:	0	MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	15228	MW (Generation end)		05.	Total Generation	:	2								
03.	Reserve / Shortage	:	2728	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	35.3° C								