

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		30-Apr-23		Page -2						
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks			
			Unit No. X Capacity	MW	MW	KWH				
1	Ghorasal Repowered CCPP Unit-3 (GT	PDB	1'260	260	0	0	Under maint.			
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	110	3117281	Gas shortage			
3	Ghorasal TPP Unit-5	PDB	1'210	190	170	4158000				
4	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.			
5	Ghorashal 78.5 MW PP (MAX)	QRPP	2'40	0	0	0				
6	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	12	955545	Bad weather			
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.			
8	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	366	9254910	Bad weather			
9	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	255	7450000	Machine problem			
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	370	9565250	Bad weather			
11	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	24	911040	Low Demand			
12	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	286	6980625	FGMO			
13	Madaniganj 102 PP(Summit)	NENP	6'11	102	66	783907	Low Demand			
14	Madaniganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	30	256332	Fuel shortage			
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	60959	Contract Expired			
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	10	234072	Engine problem			
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.			
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	40	1786560	Bad weather			
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	30	541440	Low Demand			
20	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	190	4578675	ST Under maint.			
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	83	674640	Engine problem			
22	Kaipoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage			
23	Karnalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	259560	Low Demand			
24	Kodda 150 MW PP	BPDB-RPCL	9'17.06	149	150	1295520				
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	50	439560				
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	382542				
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	Engine problem			
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	47	1054200				
29	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	631440				
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	32	745700				
31	Gazipur 52 MW PP	RPCL	6'8.9	52	49	451680	0.00			
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.			
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	45	1550618	Low Demand			
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	405336	Reserve			
35	Bramhangon 100 MW PP (Aggreko)	IPP	114'9.959	100	0	0	Reserve			
36	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve			
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	828580				
38	Gazipur 100 MW PP	RPCL	6'17.24	105	105	1500125				
39	Meghnaghat 104 MW PP (OPCL)	IPP	18'5.5	104	45	1057920	Low Demand			
40	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	1127520				
41	Spectra Solar Plant Ltd.	IPP	35	35	0	222690				
42	Kanchan Furibachal Power Generation Ltd.	IPP	18.4'3	55	34	573120	Fuel shortage			
Dhaka area Total				5847	3023	63880266				
43	Chattoogram TPP-1	PDB	1'210	180	120	2800000	Gas shortage			
44	Chattoogram TPP-2	PDB	1'210	180	0	0	Gas shortage			
45	Racozan 25 MW PP	RPCL	3'8.9	25	25	331865				
46	Teknaf 20MW PP (Solartech)	IPP	20	20	0	139455				
47	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	38	333120	Engine problem			
48	Kapita Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	308000	Low Water level			
49	Sikalbaha 225MW	PDB	1'150+1'75	223	223	5256283				
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.			
51	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	51	531090	Low Demand			
52	Haldazari 100 MW peaking PP	PDB	11'8.9	98	64	635088	Engine problem			
53	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	84	1284345	Engine problem			
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	56	1107480	Low Demand			
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	76	943680	Engine problem			
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	10	233952	Engine problem			
57	Malancha, Ctr. EPZ (United)	IPP	5'8.73+3'9.34	0	21	491040				
58	Chattoogram 108 MW PP (ECPV)	IPP	16'7	108	31	241920	Fuel shortage			
59	Kapita 7 MW Solar PP	PDB	7.4 MW	7	0	31078				
60	Anwara 300 MW PP (United)	IPP	17'17.24	300	190	3138873	Low Demand			
61	Jodiac Power	IPP	3'18.55+1'3.6	54	54	974827				
62	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	54	1270430	Fuel shortage			
63	Juldah unit-2 (Accorn)	IPP	8'13.6	100	88	869760				
64	Anilima Energy Ltd.	IPP	8'21.2	116	34	840545	Fuel shortage			
65	Minshahi 150 MW	BPDB-RPCL	18.5'9	0	54	2278581	On test.			
Chattoogram area Total				2382	1280	24039432				
66	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired			
67	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired			
68	Ashuganj TPP Unit- 5	APSCL	1'150	0	0	0	Contract Expired			
69	Ashuganj 225 MW CCPP	APSCL	1'142+1'75	221	200	4883000	FGMO			
70	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	300	7790000	FGMO			
71	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	300	7259000	FGMO			
72	Ashuganj 420 MW CCPP(East)	APSCL	284'1+116'1	400	0	0	Under maint.			
73	Ashuganj 50 MW PP	APSCL	14'3.968	45	39	949536				
74	Ashuganj 55 MW PP (Precision)	QRPP	55	0	0	0	Contract Expired			
75	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	78	3161454	Bad weather			
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1160468				
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	140	1226109	Engine problem			
78	Titas 50 MW Peaking PP	PDB	6'8.92	52	38	463568	Low Demand			
79	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.			
80	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	120	1627680	Low Demand			
81	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	409068	Engine problem			
82	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	7	167400	33 kV feeder fault.			
83	Import (Tripura)	Imported power	0	160	140	3052800				
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	803000				
85	Jangalia 52 MW PP (Lakshani)	IPP	6'8.92	52	32	1050994				
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	20	482720	Engine problem			
87	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Reserve			
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	36	899460	Low Demand			
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	78	541800	Low Demand			
90	Bhairab 54.5 MW	IPP	3'18.2	54	35	595800	Low Demand			
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	115	1586880				
Cumilla Area Total				3151	1800	38110737				
92	RPCL 210MW CCPP	IPP	4'35+1'70	202	47	1024320	Gas shortage			
93	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	11	240372	33 kV feeder fault.			
94	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.			
95	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	14900				
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	173	1958400	Engine problem			
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	108	1455600	Engine problem			
98	Sutiakhal 50 MW Solar PP	IPP	50	50	0	368140				
99	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	148800	Engine problem			
Mymensingh Area Total				614	351	5210532				
100	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	0	0	Machine problem			
101	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	29	662520	Machine problem			
102	Kushibara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Under maint.			
103	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.			
104	Fenchuganj 51 MW PP (Barakattullah)	RPP	19'2.90	51	53	1201200				
105	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	48	1094328				
106	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	8	183392				
107	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	60	1420800				
108	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	79	1776960				
109	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.			
110	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	130	2837140	Machine problem			
111	Sylhet 20 MW GTTP	PDB	1'20	20	17	399000				
112	Sylhet 50MW PP (EPL)	NENP	2'72	0	0	0	Contract Expired			
113	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	370344	Engine problem			
114	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	280	6654000	FGMO			
115	Bibiyana-III 400 MW CCPP	PDB	285'1+134'1	400	410	9034000	FGMO			
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	238140				
117	Bibiyana South 400 MW	PDB	400 MW	383	400	9202600				
Sylhet Area Total				2427	1540	35074424				
118	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage			
119	Bheramara (HVDC)	Imported power	2'500	1000	913	13936727				
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	16	563520	Low Demand			
121	Fandipur 50 MW Peaking PP	PDB	8'6.89	54	38	215520	Engine problem			
122	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation			
123	Gopalganj 100 MW Peaking PP	PDB	16'8.98	109	0	313648	Reserve			
124	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	170	5767488	Gas shortage			
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	164250	Reserve			
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Reserve			
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	17	113760	Fuel shortage			
128	Madhumati 100 MW PP	NWPGCL	6'18	105	15	637488	Low Demand			
129	Mongla Orion 100 MW Solar PP	IPP	100	100	0	532080				