

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		1-May-23		Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	200	3642344	
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4315500	
4	Ghorasal 365 MW CCPP Unit-7	QRPP	1'243+1'122	365	0	0	Under maint.
5	Ghorashal 78.5 MW PP (Regent)	IPP	34'3.35	108	81	953454	
6	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
7	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	394	8654850	
8	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	320	7328000	Machine problem
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	450	9319500	
10	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	0	388800	Reserve
11	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	276	6907025	FGMO
12	Madanganj 102 PP(Summit)	NENP	6'17	102	0	102866	Reserve
13	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	0	55153	Reserve
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	331488	Engine problem
16	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
17	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	40	1252000	Gas shortage
18	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	0	94080	Reserve
19	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	180	4368747	ST Under maint.
20	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	0	80784	Reserve
21	Kaipoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	17	132300	Low Demand
23	Kodda 150 MW PP	BPDB-RPCL	9'17.06	149	0	558240	Reserve
24	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	0	92581	Reserve
25	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	0	72793	Reserve
26	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	51	1111440	Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	613200	
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	0	596900	gas line problem.
30	Gazipur 52 MW PP	RPCL	6'8.9	52	51	339605	0.00
31	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	0	130473	Reserve
33	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Reserve
34	Bramhangon 100 MW PP (Aggreko)	IPP	114'9.959	100	0	0	Reserve
35	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	70	844848	Low Demand
37	Gazipur 100 MW PP	RPCL	6'17.5	105	105	1033546	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	17	826560	Low Demand
39	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	17	282240	Low Demand
40	Spectra Solar Plant Ltd.	IPP	35	0	0	200639	
41	Kanchan Furibachal Power Generation Ltd.	IPP	18.4'3	55	34	461880	Fuel shortage
Dhaka area Total				5847	2527	55091856	
42	Chattoogram TPP-1	PDB	1'210	180	120	2900000	Gas shortage
43	Chattoogram TPP-2	PDB	1'210	180	0	0	Gas shortage
44	Raozan 25 MW PP	RPCL	3'8.9	25	0	135639	Reserve
45	Teknaf 20MW PP (Solaritech)	IPP	20	20	0	128115	
46	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	39	332640	Engine problem
47	Kapila Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	300000	Low Water level
48	Sikalbaha 225MW	PDB	1'150+1'75	223	223	5278169	
49	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	51	433236	Low Demand
51	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	295728	Reserve
52	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	84	1104370	Engine problem
53	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	22	543720	Low Demand
54	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	76	802560	Engine problem
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	11	250416	Engine problem
56	Malancha, Ctg. EPZ (United)	IPP	5'8.73+3'9.34	0	42	974880	
57	Chattoogram 108 MW PP (ECPV)	IPP	16'7	108	31	185280	Fuel shortage
58	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	30961	
59	Anwara 300 MW PP (United)	IPP	17'17+24	300	245	3222676	Low Demand
60	Jodiach Power	IPP	3'18.55+1'3.6	54	0	257202	Reserve
61	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	51	1231960	Fuel shortage
62	Juldah unit-2 (Accorn)	IPP	8'13.6	100	63	738240	
63	Anilima Energy Ltd.	IPP	8'21.2	116	34	840545	Fuel shortage
64	Minshahi 150 MW	BPDB-RPCL	18.5'9	0	17	943418	On test.
Chattoogram area Total				2382	1134	20935822	
65	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
66	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit- 5	APSCL	1'150	0	0	0	Contract Expired
68	Ashuganj 225 MW CCPP	APSCL	1'142+1'75	221	210	4945000	FGMO
69	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	290	7452500	FGMO
70	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	280	6813000	FGMO
71	Ashuganj 420 MW CCPP(East)	APSCL	284'1+116'1	400	0	0	Under maint.
72	Ashuganj 50 MW PP	APSCL	14'3.968	45	42	957672	
73	Ashuganj 55 MW PP (Precision)	QRPP	55	0	0	0	Contract Expired
74	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	45	1137454	Gas shortage
75	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1036998	
76	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	10	205745	Low Demand
77	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	526176	Reserve
78	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
79	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	155	1874400	Fuel shortage
80	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	418198	Engine problem
81	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	0	156600	
82	Import (Tripura)	Imported power	0	160	156	3132480	
83	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	798900	
84	Jangalia 52 MW PP (Lakshnavi)	IPP	6'8.92	52	16	743424	Low Demand
85	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	20	469000	Engine problem
86	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Reserve
87	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	884640	Fuel shortage
88	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	55	399840	Fuel shortage
89	Bhairab 54.5 MW	IPP	3'18.2	54	35	751320	Engine problem
90	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	115	1661760	
Cumilla Area Total				3151	1531	34365007	
91	RPCL 210MW CCPP	IPP	4'35+1'70	202	154	2228160	Gas shortage
92	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	17	173955	
93	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
94	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	12250	
95	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	100	1533600	Low Demand
96	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	108	1740000	Engine problem
97	Sutiakhal 50 MW Solar PP	IPP	50	50	0	339670	
98	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	210480	Engine problem
Mymensingh Area Total				614	391	6238115	
99	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	29	348000	Machine problem
100	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	28	631800	Machine problem
101	Kushthara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Under maint.
102	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
103	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1110600	
104	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	42	1006992	
105	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	8	192384	
106	Shahjibazar GTPP Unit- 3 & 9	PDB	2'35	66	59	1348608	
107	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	75	1742400	
108	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
109	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	143	2986360	Machine problem
110	Sylhet 20 MW GTTP	PDB	1'20	20	18	397000	
111	Sylhet 50MW PP (EPL)	NENP	2'72	0	0	0	Contract Expired
112	Shahjanuilla 25 MW PP	SIPP, REB	3'9.34	25	16	369904	Engine problem
113	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	6882500	FGMO
114	Bibiyana-III 400 MW CCPP	PDB	285'1+134'1	400	416	8542000	FGMO
115	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	249840	
116	Bibiyana South 400 MW	PDB	400 MW	383	400	9102000	
Sylhet Area Total				2427	1567	34909388	
117	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
118	Bheramara (HVDC)	Imported power	2'500	1000	905	22032727	
119	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	0	50880	Reserve
120	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Reserve
121	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation
122	Gopalganj 100 MW Peaking PP	PDB	16'8.98	100	0	0	Reserve
123	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	200	5325258	Gas shortage
124	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Reserve
125	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Reserve
126	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	0	9552	Fuel shortage
127	Madhumati 100 MW PP	NWPGCL	6'18	105	0	0	Reserve
128	Mongla Orion 100 MW Solar PP	IPP	100	100	0	491040	
129	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
130	Rampal 1320						