

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month May, 2023				Day : Tuesday				Date : 02.05.23						
Probable Maximum Demand : 14800 MW				Probable Maximum Generation : 15278 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.13 ft		Today = 75.12 ft		02.05.23		Rule Curve = 81.81 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.05.23 (Yesterday)		02.05.23 (Today)		01.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCP Unit-4	Gas (PDB)	1 x 210	210	180	190	200	180	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	52	81	32	80	27		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCP(HPL)	Gas (IPP)	1x235+1x125	360	360	336	320	300	320					
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCP	Gas (EGCB)	1x273+1x139	412	412	378	394	360	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	38	40	50	80		105	1 Unit under maint		
12	Siddhirgonj 335 MW CCP	Gas (EGCB)	1 x 217+1x118	335	335	217	180	180	200		155	ST Under maint.		
13	Meghnaghat CCP(Summit)	Gas (IPP)	2x110+1x110	335	335	282	276	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	48	83					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	18					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	43	51	43	47					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	0	32	32					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	51	41	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	149	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	26	70	35	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300					
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	80					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	37	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	54	70					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	72	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	70	70					
36	Meghnaghat 100 MW(IEU)	HFO (NENP)	12x8.9	100	100	8	0	33	70					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	90	90					
Dhaka Zone Total				6004	5847	2307	2527	3649	4308	132	1000			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	39	26	38					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
46	Sikalbaha 225 MW CCP	Gas (PDB)	1 x 150+1 x 75	225	225	222	223	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	155	245	120	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	76	25	76					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	66	84					
50	Hathazeri 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	45	60					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	11	10	10					
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			42	42	15	30					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	31	0	50					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	35	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	51	51	54					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	63	25	80					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	33	22	55	55					
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			34	17	162	162			on test		
Chattogram Zone Total				2442	2382	841	1134	1106	1533	205	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	42	40	40					
59	Ashuganj 225 MW CCP	Gas (APSCL)	1x142+175	221	221	182	210	210	210					
60	Ashuganj 450 MW CCP(South)	Gas (APSCL)	1x360	360	360	280	280	320	320					
61	Ashuganj 450 MW CCP(North)	Gas (APSCL)	1x361	360	360	290	290	350	350					
62	Ashuganj 420 MW CCP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0		400	Under maint.		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55		Gas Shortage		
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	45	45	45	45					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	10	150	150					
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	39	38					
68	Chandpur 150 MW CCP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	155	100	150					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	0	7	7					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	16	0	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.091	200	200	0	0	0	0					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	115					
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	55	9	55					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	31	35	35	35					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	115	94	115					
**	Impport (Tripura)	India		160	160	120	156	143	165					
Cumilla Zone Total				3159	3151	1312	1531	1664	1969	55	563			
80	RPCL 210MW CCP	Gas (IPP)	4x35+1x70	210	202	81	154	50	80	48		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	19	19					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	108	100	110					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	100	150	160					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0					
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	6	12	12	12					
Mymensingh Zone Total				622	614	281	391	383	381	48	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.05.23 (Yesterday)		02.05.23 (Today)		01.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	9	29	29	29		41	GT-1 & ST-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	28	29	29		62	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
90	Kushiyara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	59	61	62				
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	80	75	85	85				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	20	143	210	210				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.55	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	270	300	310				
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	316	416	400	400				
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	400	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugonj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	38	42	46	50				
Sylhet Zone Total						2472	2427	1334	1567	1663	1678	9	587
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	240	200	220	250	210		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17				
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	104	0	0	100				
113	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	0	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (PDB)				0	0	0	0				
**	Bheramara (HVDG)	India		1000	1000	910	905	921	921				
Khulna Zone Total						3005	3001	1254	1105	1343	1534	210	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	64				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	28	25	30				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	180	187	180	183				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	1244	1200	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	773	1459	1438	1671	0	220
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	26	26				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	34				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	80	80				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	35	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	130	150	150	160	60		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	148	140	150	72		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	313	309	300	350	105		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	90	95	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	80	50	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				408	408	500	500				
Raishahi Zone Total						2129	2129	1010	1215	1470	1716	628	0
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200			Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	34	34	84				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Talsila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	36	55	115				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	27	0	30	0				
	Teesta Solar Limited	Solar (IPP)				158	0	130	0				
Rangpur Zone Total						830	750	466	345	532	474	10	85
Sub-total: Plants in operation						22928	22566	9578.0	11274	13248	15264	1297	2785
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalpottii 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	116	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	14				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	14			
Gross Total						23332	22566	9578	11274	13248	15278	1297	2785
(C) Actual data of 01.05.23 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	11274	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10860	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11274	MW, at =	21:00 hrs	Dhaka	3605	3605	0	Mymensingh	1000	1000	0
04.	Minimum Generation (Generation end)	:	8365	MW, at =	8:00 hrs	Chattoagram	1190	1190	0	Sylhet	510	510	0
05.	Day-peak Generation (Generation end)	:	9578	MW, at =	12:00 hrs	Khulna	1179	1179	0	Barishal	366	366	0
06.	Evening-peak Generation (Generation end)	:	11274	MW, at =	21:00 hrs	Rajshahi	1067	1067	0	Rangpur	726	726	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs	Cumilla	1218	1218	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9212	MW, at =	5:00 hrs					Total	10860	10860	0
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :							
	a) Gas/LF limitation	:	1082	MW		(a) Gas =	169127869	Taka		(c) Coal =	232774104	Taka	
	d) Coal supply Limitation	:	10	MW		(b) Oil =	363414059	Taka		Total =	765316033	Taka	
	b) Low water level in Kaptai lake	:	205	MW									
	c) Plants under shut down/ maintenance	:	2785	MW									
10.	Total Energy (Generation + India Import)	:	240.28	MKWh		14. Maximum Temperature in Dhaka was :	34.1° C						
	By Gas =	145.687	MKWh	By Oil =	28.473	MKWh	15. Export through East-West interconnections :						
	By Coal =	38.327	MKWh	By Hydro =	0.300	MKWh	At evening peak-hour	: 9578 MW, at 21:00 hrs					
	By Solar=	2.328	MKWh				Maximum	: 470 MW, at 19:30 hrs					
							Energy	: 0.264 MKWh					
11.	Total Gas Supplied	:	1133.66	MMCFD									
(D) Forecast of 02.05.23 (Today) Tuesday :													
01.	Maximum Demand	:	14800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15278	MW	(Generation end)	05.	Total Generation	:	315.43	MKWh			
03.	Reserve / Shortage	:	478	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	34.4° C					