

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month May, 2023				Day : Sunday				Date : 07.05.23						
Probable Maximum Demand : 14600 MW				Probable Maximum Generation : 14635 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.94 ft		Today = 74.83 ft		Rule Curve = 80.86 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.05.23 (Yesterday)		07.05.23 (Today)		06.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work			
2	a) Ghorasal Repowered CCP Unit-4	Gas (PDB)	1 x 210	210	180	130	110	110	110					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	67	22	20	22	86	Gas Shortage			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage			
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCP(HPL)	Gas (IPP)	1x235+1x125	360	360	328	334	330	330					
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling			
10	Haripur 412 MW CCP	Gas (EGCB)	1x273+1x139	412	412	403	406	400	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	63	60	60	60	105	1 Unit under maint			
12	Siddhirgonj 335 MW CCP	Gas (EGCB)	1 x 217+1x118	335	335	209	200	200	200	135	ST Under maint.			
13	Meghnaghat CCP(Summit)	Gas (IPP)	2x110+1x110	335	335	299	280	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	40	40	40	92				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	19	15	19					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	23	49	46	51					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	30	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	49	16	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	88	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	150	130	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	262	145	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	34	149	115	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	80	300	300					
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	70	100					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	70	80					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	34	51	54	54					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	108	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	34	34	34					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	74	30	30	30					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	51	72	30	72					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	81	97	90	97					
Dhaka Zone Total				6004	5847	3052	3692	3629	4114	191	980			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level			
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	9	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	39	6	39					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	23	51	17	51					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.			
46	Sikalbaha 225 MW CCP	Gas (PDB)	1 x 150+1 x 75	225	225	219	224	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	123	300	120	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	38	50					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	84	84					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	50	74	35	74					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	8	8					
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	28	5	15					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	39	0	40					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	34	17					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	48	54	54	54					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	38	50					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	22	44	22	44					
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test			
Chattogram Zone Total				2442	2382	760	1286	898	1238	205	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	42	41	42					
59	Ashuganj 225 MW CCP	Gas (APSCL)	1x142+175	221	221	179	208	200	210					
60	Ashuganj 450 MW CCP(South)	Gas (APSCL)	1x360	360	360	325	300	300	300					
61	Ashuganj 450 MW CCP(North)	Gas (APSCL)	1x361	360	360	330	310	300	310					
62	Ashuganj 420 MW CCP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55	Gas Shortage			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	26	45	45	45	150	Gas Shortage			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	40	43					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	22	127	130	150					
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	34	20	34					
68	Chandpur 150 MW CCP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	155	55	80					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	7	7					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.091	200	200	0	0	0	0					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	114	114	17	114					
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	68	30	55					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	95	94	95					
**	Impoport (Tripura)	India		160	160	160	152	129	152					
Cumilla Zone Total				3159	3151	1549	1839	1548	1777	205	563			
80	RPCL 210MW CCP	Gas (IPP)	4x35+1x70	210	202	30	86	60	80	116	Gas Shortage			
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	16	17					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	108	90	98					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	124	164	150	155					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	18	12	12					
Mymensingh Zone Total				622	614	311	393	380	362	116	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.05.23 (Yesterday)		07.05.23 (Today)		06.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	29	29	29		61	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		19x2.90	51	51	47	50	50	50			
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	56	56	60				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	83	82	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	204	202	202	210				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	17	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	285	300	300				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	380	368	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	364	370	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	44	47	44	50				
Sylhet Zone Total						2472	2427	1565	1584	1660	1680	9	572
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	145	135	150	150	275		Gas Shortage	
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	43				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	76	0	76				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	48	0	48				
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	105	50	105				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0				
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	32	98	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	24	40	0	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				20	0	0	0				
**	Bheramara (H/VDC)	India		1000	1000	911	802	929	929				
Khulna Zone Total						3005	3001	1248	1347	1314	1489	275	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	64				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	32	20	32				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	173	181	180	181				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1182	1244	1244	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	150	50	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barisal Zone Total						2265	2265	1376	1623	1510	1671	0	220
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	31	0	31				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	83	80	83				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	24	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	34	34	34				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	169	164	160	164	46		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	147	142	140	142	78		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	176	164	200	200	250		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	14	43	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	50	113	35	75				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	35	70				
140	Aminura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	0	0	28	21	21				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				757	750	750	750				
Rajshahi Zone Total						2179	2129	1409	1774	1557	1741	765	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	73	75	75	12		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260			Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	80	113	35	113				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Talukda 3 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	113	35	115				
149	Lalmoinhat 30 MW Solar (Intiraco)	Solar (IPP)	1*30	30	30	37	0	30	0				
	Teesta Solar Limited	Solar (IPP)				203	0	130	0				
Rangpur Zone Total						830	750	777	559	573	563	12	85
Sub-total: Plants in operation						22978	22566	12047.0	14097	13069	14635	1778	2750
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)		12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)		7x7.90	51	0	0	0	0	0			
152	Bosila 108MW PP(CLC)	HFO (IPP)		12x8.775+1x3.5	118	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)		8x13.45	100	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired						354	0	0	0	0			
Gross Total						23332	22566	12047	14097	13069	14635	1778	2750
(C) Actual data of 06.05.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	14163	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13556	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14097	MW, at =	21:00 hrs	Dhaka	4834	4819	15	Mymensingh	1104	1056	48
04.	Minimum Generation (Generation end)	:	10043	MW, at =	6:00 hrs	Chattogram	1367	1367	0	Sylhet	537	537	0
05.	Day-peak Generation (Generation end)	:	12047	MW, at =	12:00 hrs	Khulna	1673	1673	0	Barisal	389	389	0
06.	Evening-peak Generation (Generation end)	:	14097	MW, at =	21:00 hrs	Rajshahi	1395	1395	0	Rangpur	866	866	0
07.	Evening Peak Load-shed (Sub-station end)	:	63	MW, at =	21:00 hrs	Cumilla	1392	1392	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10825	MW, at =	5:00 hrs					Total	13556	13493	63
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 168457951 Taka	(c) Coal = 317896075 Taka				
	a) Gas/LF limitation	:	1561	MW			(b) Oil = 842640212 Taka	Total = 1328994237 Taka					
	d) Coal supply Limitation	:	12	MW									
	b) Low water level in Kaptai lake	:	205	MW									
	c) Plants under shut down/ maintenance	:	2750	MW									
10.	Total Energy (Generation + India Import)	:	288.36	MKWh		14.	Maximum Temperature in Dhaka was :	37.0° C					
	By Gas = 146.274 MKWh	By Oil =	57.818 MKWh			15.	Export through East-West interconnections :						
	By Coal = 55.764 MKWh	By Hydro =	0.292 MKWh				At evening peak-hour	:	12047	MW, at	21:00 hrs		
	By Solar= 3.300 MKWh						Maximum	:	280	MW, at	19:30 hrs		
							Energy	:	0	MKWh			
11.	Total Gas Supplied	:	1124.07	MMCFD									
(D) Forecast of 07.05.23 (Today) Sunday :													
01.	Maximum Demand	:	14600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14635	MW	(Generation end)	05.	Total Generation	:	298.65	MKWh			
03.	Reserve / Shortage	:	35	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	40.1° C				
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00													
(Md. Helatur Rahman) Deputy Secretary, Generation													