

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month May, 2023				Day : Wednesday				Date : 10.05.23				
Probable Maximum Demand :				15600 MW		Probable Maximum Generation :				14761 MW		
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.59 ft		Today = 74.47 ft		Rule Curve = 80.29 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.05.23 (Yesterday)		10.05.23 (Today)		09.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	235	334	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	394	399	412	412			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	1 Unit under maint	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	202	200	200	200	135	ST Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	292	293	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	92	40	92			
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	43	45	46	51			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	30	39	16	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	146	100	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	17	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	190	278	145	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	128	144	35	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	303	302	300	300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	76	80	70	100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	80	70	80			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	0	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	0	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	53	54	54			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	17	72	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	34	34			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	72	75	34	75			
36	Meghnaghat 100 MW(IEU)	HFO (NENP)	12x8.9	100	100	68	49	70	70			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	97	97	97			
Dhaka Zone Total			6004	5847	3658	3721	3508	4130	191	980		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	27	27	25	25	203	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	120	120			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	8	44	6	39			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	30	87	51	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	212	220	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	82	300	85	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	38	25	50			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	63	84	84	84			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	42	48	56	60			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	8	8			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	26	5	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	0	50			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	74	54	54			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	38	38	38			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	22	33	22	44			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			108	163	163	163		on test	
Chattogram Zone Total			2442	2382	890	1386	1051	1427	203	330		
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	33	33	41	42			
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	198	203	200	200			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	320	305	310	340			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	310	310	310			
62	Ashuganj 420 MW CCPP(East)	GAS (APSCCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55	Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	177	175	180	180	20	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	40	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	18	137	20	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	36	36	34			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	69	34	85			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	7	7			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	35	52	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.091	200	200	0	0	0	0			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	55	57	55	55			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	17	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	95	94	94	94			
**	Impoport (Tripura)	India		160	160	160	154	150	166			
Cumilla Zone Total			3159	3151	1622	1762	1617	1864	75	563		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	28	68	44	70	134	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	18	16	17			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	78	98	50	98			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	75	95	57	98			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
86	Tangail 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	254	291	231	295	134	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.05.23 (Yesterday)		10.05.23 (Today)		09.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	43	43	43	27	GT-1 & ST-1 Under maint.	
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	29	29	62	GT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	53	50	50			
90	Kushnara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	54	ST Under maint.	
91	Hobgajj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10			
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	49	56	56	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	80	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	201	204	210	210			
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.55	10	10	10	10	10	10			
98	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	8	16	16	16	9	Gas Shortage	
99	Bibiara-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	280	300	300			
100	Bibiara-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	391	369	400	400			
101	Bibiara South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	354	385	400	400			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	41	48	44	50			
Sylhet Zone Total					2472	2427	1513	1597	1669	1679	9	573
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	11	37	19	43			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	75	20	76			
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0			
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	55	17	53			
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	105	105	105			
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	75	0	100	0			
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	60	94	85	98			
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	32	40	32	40			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				200	0	0	0			
**	Bheramara (HVDc)	India		1000	1000	911	814	932	932			
Khulna Zone Total					3005	3001	1397	1220	1310	1347	410	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	64	16	16	64			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	36	22	32			
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	170	175	180	181			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1200	1244	1244	1244			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0			
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220	Under maint.	
Barisal Zone Total					2265	2285	1474	1621	1479	1671	0	220
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	21	28	28	28			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	0	0	31			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	72	78	80	83			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	24	40			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	34	34			
131	Sirajganj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	159	180	160	164	30	Gas Shortage	
132	Sirajganj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajganj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	133	153	140	142	67	Gas Shortage	
134	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	227	345	300	345	69	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	11	20	22	22			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	34	8	43			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	55	35	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
140	Aminura 30 MW PP (Sinhaj)	HFO (NENP)	7x7.79	50	0	21	21	21	21			
141	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
	Adani Power Jharkhanda Ltd	Coal				742	592	750	750			
Rajshahi Zone Total					2179	2129	1521	1681	1693	1858	557	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	250	250	250		Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	34	34	50			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Talaila 3 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
148	Teikrugon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	95	114	115	115			
149	Lahonihet 30 MW Solar (Intiraco)	Solar (IPP)	1'30	30	30	33	0	30	0			
	Teesta Solar Limited	Solar (IPP)				197	0	130	0			
Rangpur Zone Total					830	750	641	473	642	490	10	85
Sub-total: Plants in operation					22978	22566	12970.0	13752	13200	14761	1589	2751
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Kaipoti 52 MW PP (Sinhaj)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Scalia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					354	0	0	0	0			
Gross Total					23332	22566	12970	13752	13200	14761	1589	2751
(C) Actual data of 09.05.23 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)	:	15300	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	14672	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	13908	MW, at =	22:00 hrs	Dhaka	5232	5060	172	Mymensingh	1165	907
04.	Minimum Generation (Generation end)	:	11741	MW, at =	6:00 hrs	Chittogram	1448	1248	200	Sylhet	625	532
05.	Day-peak Generation (Generation end)	:	12970	MW, at =	12:00 hrs	Khulna	1783	1491	292	Barisal	478	478
06.	Evening-peak Generation (Generation end)	:	13752	MW, at =	21:00 hrs	Rajshahi	1520	1370	150	Rangpur	953	861
07.	Evening Peak Load-shed (Sub-station end)	:	1478	MW, at =	21:00 hrs	Cumilla	1468	1247	221			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11392	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :						
	a) Gas/LF limitation	:	1376	MW			(a) Gas =	167659063	Taka	(c) Coal =	321969342	Taka
	d) Coal supply Limitation	:	10	MW			(b) Oil =	999616857	Taka	Total =	1489245262	Taka
	b) Low water level in Kaptai lake	:	203	MW								
	c) Plants under shut down maintenance	:	2751	MW								
10.	Total Energy (Generation + India Import)	:	305.33	MKWh		14.	Maximum Temperature in Dhaka was : 39.8° C					
	By Gas =	146.547	MKWh	By Oil =	73.922	15.	Export through East-West interconnections :					
	By Coal =	56.038	MKWh	By Hydro =	0.324		At evening peak-hour	:	12970	MW, at	21:00 hrs	
	By Solar =	3.177	MKWh				Maximum	:	500	MW, at	19:30 hrs	
							Energy	:	0	MKWh		
11.	Total Gas Supplied	:	1113.40	MMCFD								
(D) Forecast of 10.05.23 (Today) Wednesday :												
01.	Maximum Demand	:	15600	MW	(Generation end)	04.	Maximum Load-shed : 793 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	14761	MW	(Generation end)	05.	Total Generation : 342.48 MKWh					
03.	Reserve / Shortage	:	-839	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 39.4° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation