

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month May, 2023				Day : Thursday				Date : 11.05.23				
Probable Maximum Demand : 15500 MW				Probable Maximum Generation : 14660 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.47 ft	Today = 74.35 ft		11.05.23 (Today)		Rule Curve = 80.10 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.05.23 (Yesterday)		11.05.23 (Today)		10.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)			
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	318	340	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	406	412	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	1 Unit under maint	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	200	200	200	200	135	ST Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	292	303	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	83	32	83			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	0	22	22			
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	47	50	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	32	8	42			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	147	100	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	268	100	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	138	143	35	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	289	167	300	300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	76	80	70	80			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	80	70	80			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	58	53	54	54			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	17	72	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	34	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	58	50	50	50			
36	Meghnaghat 100 MW(IEU)	HFO (NENP)	12x8.9	100	100	58	37	50	50			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	97	97	97	97			
Dhaka Zone Total			6004	5847	3587	3627	3447	4030	191	980		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	44	6	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	51	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	214	223	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	297	85	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	63	85	84	85			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	53	54	56	60			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	10	10	10			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	13	5	10			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	0	30			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	74	92	54	54			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	24	25	38	38			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	15	51	17	17			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			54	0	34	163		on test	
Chattogram Zone Total			2442	2382	904	1258	919	1353	205	330		
58	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	30	41	41	41			
59	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	197	198	200	200			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	315	315	310	320			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	320	300	300	300			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55	Gas Shortage	
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	195	197	180	180			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	11	150	20	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	35	35	35			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	68	34	68			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	14	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	7	7			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	26	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	50	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.095	200	200	0	0	0	0			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	0	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	46	95	55	55			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	17	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	56	72	94	94			
**	Impoget (Tripura)	India		160	160	160	160	150	166			
Cumilla Zone Total			3159	3151	1578	1929	1609	1931	55	563		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	27	48	45	50	154	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	15	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	77	98	50	98			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	75	96	57	98			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0			
86	Tangail 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	258	272	231	276	154	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.05.23 (Yesterday)		11.05.23 (Today)		10.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43	27	GT-1 & ST-1 Under maint.	
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	30	30	30	60	GT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	53	51	51			
90	Kushihara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	54	ST Under maint.	
91	Hobgajj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	2	10	10			
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	58	58	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	83	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	202	201	201	201			
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	17	17			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.55	10	10	9	9	10	10			
98	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	16	15	15	15	10	Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	280	280	300			
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	384	369	400	400			
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	370	400	400	400			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	46	49	44	44			
Sylhet Zone Total					2472	2427	1589	1610	1643	1665	10	571
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	19	27	20	43			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	45	82	60	82			
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0			
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	55	17	55			
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105			
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	99	0	100	0			
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	75	65	85	98			
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	24	40	32	40			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				222	200	0	0			
**	Bheramara (H/VDC)	India		1000	1000	917	813	935	935			
Khulna Zone Total					3005	3001	1523	1387	1354	1358	410	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	110	16	110	16			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	36	22	32			
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	170	178	180	181			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1200	1244	1244	1244			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	137	17	150			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0			
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220	Under maint.	
Barisal Zone Total					2265	2285	1520	1611	1573	1623	0	220
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	21	28	28	28			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	15	31			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	69	77	80	83			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	24	40			
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	8	42	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	34	34			
131	Sirajganj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	184	180	180	180	30	Gas Shortage	
132	Sirajganj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajganj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	152	148	143	148	72	Gas Shortage	
134	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	343	390	350	390	24	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	11	21	22	22			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	6	52	8	52			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	55	35	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
140	Aminura 30 MW PP (Sinhaj)	HFO (NENP)	7x7.79	50	0	21	21	21	21			
141	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
	Adani Power Jharkhand Ltd	Coal				729	788	750	750			
Rajshahi Zone Total					2179	2129	1728	1905	1781	1934	417	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	74	75	75	11	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	33	56	34	50			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Talaila 5 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	108	56	115	115			
149	Lalmohorhet 30 MW Solar (Intresco)	Solar (IPP)	1'30	30	30	33	0	30	0			
	Teesla Solar Limited	Solar (IPP)				171	0	130	0			
Rangpur Zone Total					830	750	677	436	642	490	11	85
Sub-total: Plants in operation					22978	22566	13364.0	14035	13199	14660	1453	2849
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Kaipoti 52 MW PP (Sinhaj)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Scalia 108MW PP(CJ)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	18	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					354	0	18	0	0	0		
Gross Total					23332	22566	13382	14035	13199	14660	1453	2849
(C) Actual data of 10.05.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	14500 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13805 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14035 MW, at =	21:00 hrs	Dhaka	5964	5041	23	Mymensingh	901	792	109
04.	Minimum Generation (Generation end)	:	11392 MW, at =	7:00 hrs	Chattogram	1384	1320	64	Sylhet	358	358	0
05.	Day-peak Generation (Generation end)	:	13382 MW, at =	12:00 hrs	Khulna	1712	1712	0	Barisal	493	493	0
06.	Evening-peak Generation (Generation end)	:	14035 MW, at =	21:00 hrs	Rajshahi	1502	1472	30	Rangpur	934	884	50
07.	Evening Peak Load-shed (Sub-station end)	:	444 MW, at =	21:00 hrs	Cumilla	1457	1289	168				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11368 MW, at =	5:00 hrs					Total	13805	13361	444
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 169038254 Taka	(c) Coal = 323510643 Taka				
	a) Gas/LF limitation	:	1237 MW			(b) Oil = 981967107 Taka	Total = 1474516004 Taka					
	d) Coal supply Limitation	:	11 MW		14.	Maximum Temperature in Dhaka was :	39.0° C					
	b) Low water level in Kaptai lake	:	205 MW		15.	Export through East-West interconnections :						
	c) Plants under shut down maintenance	:	2849 MW			At evening peak-hour	:	13382 MW, at	21:00 hrs			
10.	Total Energy (Generation + India Import)	:	287.83 MCKWh			Maximum	:	500 MW, at	19:30 hrs			
	By Gas = 147.949 MCKWh	By Oil =	72.046 MCKWh			Energy	:	0 MCKWh				
	By Coal = 39.009 MCKWh	By Hydro =	0.328 MCKWh									
	By Solar= 3.205 MCKWh											
11.	Total Gas Supplied	:	1117.55 MMCFD									
(D) Forecast of 11.05.23 (Today) Thursday :												
01.	Maximum Demand	:	15500 MW	(Generation end)	04.	Maximum Load-shed	:	774 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14660 MW	(Generation end)	05.	Total Generation	:	317.88 MCKWh				
03.	Reserve / Shortage	:	-840 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	39.0° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation