

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Friday				Date : 12.05.23				
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 14400 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.35 ft Today = 74.23 ft				Rule Curve = 79.91 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.05.23 (Yesterday)		12.05.23 (Today)		11.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	252	276	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	330	380	380			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	390	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	1 Unit under maint	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	180	90	170	170		ST Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	280	213	160	160			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	15	15	30			
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	83	40	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	0	22	22			
17	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.87+1x6.73	80	80	48	50	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	19	14	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	41	8	52			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	150	100	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	17	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	280	100	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	114	35	149			
26	Keraniganj 300 MW PP (HPR)	HSD (IPP)	25x61.4	300	300	301	295	300	300			
27	Branthargan 100 MW PP (Aggreko)	HSD (IPP)	23x40.85+91x.969	100	100	80	80	70	80			
28	Aurabati 109MW PP (Aggreko)	HSD (IPP)	23x40.85+91x.969	100	100	75	79	70	80			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	54	54			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	17	54	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	34	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	53	60	55	55			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	40	57	50	50			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	65	65	97	97			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0			
Dhaka Zone Total			6104	5867	3393	3336	3170	3803	251	845		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	44	6	44			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	69	51	51			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	214	223	225	225			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	88	279	88	300			
49	Julda 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	30	68	67	67			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	30	54	48	56			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	10	10	10			
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			3	20	20	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	29	0	30			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	66	105	92	92			
56	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
57	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	51	17	51			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	144	34	163			
Chattogram Zone Total			2605	2545	826	1350	937	1363	205	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	36	41	41	41			
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	197	211	200	200			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	310	305	300	300			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	330	310	330	330			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	185	189	180	180			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	18	152	20	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x6.92	52	52	37	41	35	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	70	34	68			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	7	7			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	24	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	50	50	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	0	114			
77	Chowmuhan 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	57	95	26	55			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	90	54	54	94			
**	Import (Tripura)	India		160	160	156	140	129	152			
Cumilla Zone Total			2904	2896	1637	1919	1539	1927	0	563		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	28	86	30	80	116	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	18	15	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	77	99	57	98			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	76	93	57	98			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	10	12	12	12			
Mymensingh Zone Total			622	614	255	308	223	306	116	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.05.23 (Yesterday)		12.05.23 (Today)		11.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Day	Evening			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	43	43	43		27	GT-1 & ST-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	30	30		62	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51					
90	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	10	10					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	48	59	58	60					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	83	84	84					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	204	207	201	201					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	17	17					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	15	9		Gas Shortage		
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	280	300					
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	379	364	400	400					
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	377	400	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	43	46	44	44					
Sylhet Zone Total						2472	2427	1574	1612	1643	1665	9	573	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
106	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	9	26	20	43					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	25	80	60	82					
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	17	35	17	35					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	85	105	105	105					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	101	0	100	0					
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	61	68	49	98					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	24	32	32	40					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0					
**	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0					
Bheramara (HVDC)						1000	1000	917	804	939	939			
Khulna Zone Total						2905	2901	1239	1150	1322	1342	410	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	110	16	0	16					
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	25	34	22	32					
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	170	89	74	140					
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244					
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150					
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0					
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.		
Barishal Zone Total						2265	2265	1566	1533	1357	1582	0	220	
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	28	28	28					
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	21	28	15	31					
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	39	82	80	83					
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	24	40					
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	27	34	34					
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	183	173	170	170	37		Gas Shortage		
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	135	142	140	140	78		Gas Shortage		
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	341	401	370	390					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22					
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50					
139	Amnura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	21	21	21	21					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0					
141	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	754	710	850	800					
Rajshahi Zone Total						2927	2905	1732	1837	1880	1922	406	100	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	75	75	75	10		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	260	250	250			Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	34	50					
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	72	35	115					
149	Lalmohitha 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0					
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	182	0	130	0					
Rangpur Zone Total						1030	950	614	456	562	490	10	85	
Sub-total: Plants in operation						23834	23370	12836.0	13501	12633	14400	1407	2716	
(B) Plants under long term maintenance/ contract expired														
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
152	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
153	Bosilia 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
154	Asphuganj 45 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						399	0	0	0	0	0	0	0	
Gross Total						24143	23370	12836	13501	12633	14400	1407	2716	
(C) Actual data of 11.05.23 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	14300	MW,	at =	21:00	hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	13607	MW,	at =	21:00	hrs	Zone	Demand	Supply	Load Shed	Demand	Supply	
03.	Highest Generation (Generation end)	:	13501	MW,	at =	21:00	hrs	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	11368	MW,	at =	7:00	hrs	Dhaka	5136	5076	60	Myemensingh	657	
05.	Day-peak Generation (Generation end)	:	12836	MW,	at =	12:00	hrs	Chattogram	1383	1249	134	Sylhet	387	
06.	Evening-peak Generation (Generation end)	:	13501	MW,	at =	21:00	hrs	Khulna	1879	1658	221	Barishal	477	
07.	Evening Peak Load-shed (Sub-station end)	:	763	MW,	at =	21:00	hrs	Rajshahi	1355	1257	98	Rangpur	879	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10860	MW,	at =	5:00	hrs	Cumilla	1454	1204	250			
09.	Generation shortfall at evening peak due to :	:										Total	13607	
	a) Gas/LF limitation	:	1192	MW									12844	
	c) Coal supply Limitation	:	10	MW									763	
	b) Low water level in Kaptai lake	:	205	MW										
	c) Plants under shut down/ maintenance	:	2716	MW										
10.	Total Energy (Generation + India Import)	:	295.78	MKWh				13.	Fuel cost :	(a) Gas = 164880183 Taka	(c) Coal = 326496512 Taka			
	By Gas = 143.884 MKWh			By Oil = 65.884 MKWh					(b) Oil = 927266821 Taka	Total = 1418643516 Taka				
	By Coal = 57.444 MKWh			By Hydro = 0.323 MKWh										
	By Solar= 3.056 MKWh													
11.	Total Gas Supplied	:	1081.59	MMCFD				14.	Maximum Temperature in Dhaka was :	38.4° C				
(D) Forecast of 12.05.23 (Today) Friday :														
01.	Maximum Demand	:	14000	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14400	MW	(Generation end)			05.	Total Generation	:	306.71	MKWh		
03.	Reserve / Shortage	:	400	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	38.4° C			