

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Saturday				Date : 13.05.23					
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 13062 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.23 ft		Today = 74.04 ft		Rule Curve = 79.72 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	12.05.23 (Yesterday)		13.05.23 (Today)		12.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	319	317	200	200				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	370	125	125				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	404	330	330				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	1 Unit under maint		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	150	150	0	0		ST Under maint.		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	142	150	0	0				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	92	32	92				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.87+1x6.73	80	80	43	51	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	20	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	48	8	52				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	80	88	88	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	150	100	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	296	100	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	34	132	35	149				
26	Keraniganj 300 MW PP (HPR)	HSD (IPP)	25x61.4	300	300	0	107	300	300				
27	Branthargan 100 MW PP (Aggreko)	HSD (IPP)	23x40.85+91x1.969	100	100	0	70	70	80				
28	Aurabati 100MW PP (Aggreko)	HSD (IPP)	23x40.85+91x1.969	100	100	0	80	70	80				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	53	54	54				
32	Manikgonj 162MW PP(MPCL)	HFO (IPP)	9x18	162	162	54	162	54	162				
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	17	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	56	56	35	40				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	50	50	50	50				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	48	96	34	51				
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	3	0	0				
Dhaka Zone Total													
			6104	5867	2550	3513	2277	2972	251	845			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	27	27	25	25	203	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	0	0				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	44	6	44				
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	105				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	227	0	0				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	95	295	88	300				
49	Julda 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	64	79	84	84				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	45	57	54	57				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			23	25	0	0				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	0	30				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	92	54	54				
56	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
57	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	22	22	22	22				
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	51	17	51				
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	163	0	163				
Chattogram Zone Total			2605	2545	887	1346	494	1037	203	330			
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	36	36	37	40				
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	199	209	200	200				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	325	305	300	300				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	340	310	310	310				
64	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	185	197	180	180				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	18	140	20	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	30	35	35				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	35	68	34	68				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	7	7				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	0	0	0				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	0	0				
77	Chowmuhan 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	36	95	26	55				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	94	54	94				
**	Import (Tripura)	India		160	160	146	140	129	152				
Cumilla Zone Total			2904	2896	1579	1886	1481	1740	0	563			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	97	35	90	105	Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	15	18				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	89	48	98				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	61	87	48	98				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	33	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total			622	614	214	302	210	316	105	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.05.23 (Yesterday)		13.05.23 (Today)		12.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	30	30			62	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	50	51	51					
90	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	10	10					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	57	60	60					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	79	84	84					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	204	201	201	201					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	0	17					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	15	9			Gas Shortage	
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	275	280	300					
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	403	400	400					
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	400	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	46	49	44	44					
Sylhet Zone Total						2472	2427	1612	1633	1628	1665	9	573	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410			Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	29	20	43					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	30	85	60	82					
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	17	55	17	55					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	105	85	105					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	52	0	100	0					
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	80	49	98					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	24	24	8	40					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0					
115	Khulna 330 MW CCPP	Gas/HSD (BPDB)				150	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	921	669	940	940					
Khulna Zone Total						2905	2901	1276	1047	1279	1363	410	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16					
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	32	22	32					
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	83	172	175	175					
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1170	1244	1244	1244					
119	Potukhaili 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150					
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	94	300	300					
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0			220	Under maint.	
Barishal Zone Total						2265	2265	1293	1708	1758	1917	0	220	
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	21	28	28					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	15	31					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	57	81	80	83					
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	24	40					
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	42	42	42					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	34	34					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	150	182	170	170	28			Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220			Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	143	154	150	150	66			Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	421	380	380					
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50					
140	Amnura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	21	21	21					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0					
142	Adani Power Jharkhand Ltd	Coal (Import)	1x748	748	748	851	737	430	430					
Rajshahi Zone Total						2927	2905	1730	1875	1480	1552	385	100	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75			10	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260				Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	34	50					
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
148	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	37	112	35	115					
150	Lalmohitha 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	26	0	30	0					
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	184	0	130	0					
Rangpur Zone Total						1030	950	623	496	572	500	10	85	
Sub-total: Plants in operation						23834	23370	11764.0	13806	11179	13062	1373	2716	
(B) Plants under long term maintenance/ contract expired														
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
152	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
153	Bosilia 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
154	Asphuganj 45 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						399	0	0	0	0	0	0	0	
Gross Total						24143	23370	11764	13806	11179	13062	1373	2716	
(C) Actual data of 12.05.23 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	14130	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13483	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	13806	MW, at =	20:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	10784	MW, at =	9:00 hrs	Dhaka	4720	4720	0	Myensingh	1055	970	85	
05.	Day-peak Generation (Generation end)	:	11764	MW, at =	12:00 hrs	Chattogram	1296	1296	0	Sylhet	548	538	10	
06.	Evening-peak Generation (Generation end)	:	13806	MW, at =	20:00 hrs	Khulna	1675	1605	70	Barisal	450	450	0	
07.	Evening Peak Load-shed (Sub-station end)	:	312	MW, at =	20:00 hrs	Rajshahi	1422	1422	0	Rangpur	895	895	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9941	MW, at =	5:00 hrs	Cumilla	1423		147					
09.	Generation shortfall at evening peak due to :	:								Total	13483	13171	312	
a)	Gas/LF limitation	:	1160	MW		13. Fuel cost :		(a) Gas = 162797699 Taka		(c) Coal = 325327627 Taka				
c)	Coal supply Limitation	:	10	MW				(b) Oil = 826434605 Taka		Total = 1314559931 Taka				
b)	Low water level in Kaptai lake	:	203	MW		14. Maximum Temperature in Dhaka was :		37.3° C						
c)	Plants under shut down/ maintenance	:	2716	MW		15. Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	288.63	MKWh		At evening peak-hour		:	11764	MW, at	20:00 hrs			
	By Gas =	141.476	MKWh	By Oil =	60.344	MKWh	Maximum		:	220	MW, at	20:00 hrs		
	By Coal =	59.723	MKWh	By Hydro =	0.336	MKWh	Energy		:	0	MKWh			
	By Solar=	2.749	MKWh											
11.	Total Gas Supplied	:	1048.46	MMCFD										
(D) Forecast of 13.05.23 (Today) Saturday :														
01.	Maximum Demand	:	14000	MW	(Generation end)	04. Maximum Load-shed		:	860	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	13062	MW	(Generation end)	05. Total Generation		:	292.68	MKWh				
03.	Reserve / Shortage	:	-938	MW	(Generation end)	06. Probable Max. Temperature in Dhaka :		37.3° C						