

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Sunday				Date : 14.05.23					
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 12563 MW				Rule Curve = 79.53 ft.					
Water Level of Kaptai Lake at 06:00 AM				Today = 73.92 ft.				13.05.23 (Yesterday)					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.05.23 (Yesterday)		14.05.23 (Today)		13.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
Description/ Remarks													Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	60		Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Under maint.		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	86		Gas Shortage		
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	213	131	0					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	130	85	85					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	370	263	220	149		Gas Shortage		
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0		105	1 Unit under maint		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	335		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	92	40					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	19	22					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.57+1x8.73	80	80	48	49	50					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	12	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	49	16					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	146	100					
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0		35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	277	97		300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	34	133	116		116			
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	210	306	300		300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	86	80	70		80			
28	Aurhatti 108MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	82	75		80			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17		35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35		55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	52	54		54			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	135	54		162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	30		0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17		34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	37	42	35		40			
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	9	26	26		26			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	20	17	17		17			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0		0			
Dhaka Zone Total				6104	5867	2139	2613	1967	2494	1070	845		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	25		25	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0		180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0			Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5		0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25		25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20		0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	40	6		44			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	28	85	17		105			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0		150	Under maint.		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0		0			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	262	88		300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25		25			
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	84	84	84		84			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	53	55	54		57			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	0	10		10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0		0			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	0		30			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17		17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	105	54		54			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25		25			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22		22			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17		51			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	163	36		163			
Chattogram Zone Total				2605	2545	501	985	530	1037	380	330		
60	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	28	40	40		40			
61	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	204	203	200		200			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	305	315	300		300			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	310	310	310		310			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0		0	Under maint.		
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	185	189	180		180			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43		43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	145	20		150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	38	35		35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0		163	Under overhauling		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	68	34		68			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18		18			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	6	7		7			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	7	0	33		33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0		0			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	20		20			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0		0			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	24	96	26		96			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35		35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	95	54		94			
**	Import (Tirupura)	India		160	160	142	118	129		152			
Cumilla Zone Total				2904	2896	1461	1739	1484	1781	0	563		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	47	84	35		90	Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	18		18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	89	48		85			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	49	87	48		85			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6		0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50		0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12		12			
Mymensingh Zone Total				622	614	225	291	213	290	118	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.05.23 (Yesterday)		14.05.23 (Today)		13.05.23 (Yesterday)		(Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	GT-1 & ST-1 Under maint.		
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	29	30	30			61	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51						
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			54	ST Under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	3	3	3						
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	61	60	60						
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	77	84	84						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	203	202	201	201						
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	17	17	17						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9			Gas Shortage		
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	290	280	300						
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	390	400	400						
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	375	400	400						
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	46	49	44	44						
Sylhet Zone Total						2472	2427	1562	1615	1639	1659	9	572		
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410			Gas Shortage		
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	14	31	20	43						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	45	80	60	82						
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	17	55	17	55						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	105	85	105						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	47	81	49	98						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	32	8	40						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0						
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	923	819	940	940						
Khulna Zone Total						2905	2901	1186	1203	1279	1363	410	0		
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16						
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	31	22	32						
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	178	178	175	175						
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1050	1244	1244	1244						
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150						
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	307	300	300						
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0			220	Under maint.		
Barishal Zone Total						2265	2265	1515	1926	1758	1917	0	220		
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Under maint.		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	21	28	28	28						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	34	34	15	31						
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	58	80	80	83						
127	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	24	40						
128	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42						
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	34	34	34						
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	179	164	170	170	46			Gas Shortage		
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220			Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	139	139	150	150	81			Gas Shortage		
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	383	351	380	380						
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	20	22	22						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50						
139	Ammura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	21	21	21						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	482	404	400	400						
Raishahi Zone Total						2927	2905	1532	1478	1450	1522	418	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10			Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260				Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	34	50						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	37	115	35	115						
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	184	0	130	0						
Rangpur Zone Total						1030	950	628	499	572	500	10	85		
Sub-total: Plants in operation						23634	23370	10749.0	12349	10892	12563	2415	2715		
(B) Plants under long term maintenance/ contract expired															
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
152	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
153	Aspiganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						339	0	0	0	0	0	0	0		
Gross Total						24143	23370	10749	12349	10892	12563	2415	2715		
(C) Actual data of 13.05.23 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	14400	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):									
02.	Max. Demand at eve. peak (Sub-station end)	:	13631	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	12349	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	9766	MW, at =	9:00 hrs	Dhaka	5141	4291	850	Mymensingh	1122	932	190		
05.	Day-peak Generation (Generation end)	:	10749	MW, at =	12:00 hrs	Chattogram	990	939	51	Sylhet	568	449	119		
06.	Evening-peak Generation (Generation end)	:	12349	MW, at =	21:00 hrs	Khulna	1762	1698	64	Barishal	430	430	0		
07.	Evening Peak Load-shed (Sub-station end)	:	1959	MW, at =	21:00 hrs	Rajshahi	1389	1199	190	Rangpur	918	723	195		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9616	MW, at =	5:00 hrs	Cumilla	1311	1011	300						
09.	Generation shortfall at evening peak due to :	:				Total							13631	11672	1959
	a) Gas/LF limitation	:	2205	MW		13. Fuel cost :									
	c) Coal supply Limitation	:	10	MW		(a) Gas =	135730399	Taka	(c) Coal =	317389350	Taka				
	b) Low water level in Kaptai lake	:	200	MW		(b) Oil =	894406558	Taka	Total =	1347526307	Taka				
	c) Plants under shut down/ maintenance	:	2715	MW		14. Maximum Temperature in Dhaka was :									
10.	Total Energy (Generation + India Import)	:	264.89	MKWh		15. Export through East-West interconnections :									
	By Gas =	119.881	MKWh	By Oil =	61.644	At evening peak-hour :									
	By Coal =	55.537	MKWh	By Hydro =	0.394	Maximum :									
	By Solar =	2.706	MKWh			Energy :									
11.	Total Gas Supplied	:	878.64	MMCFD		0									
(D) Forecast of 14.05.23 (Today) Sunday :															
01.	Maximum Demand	:	12500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	12563	MW	(Generation end)	05.	Total Generation	:	268.13	MKWh					
03.	Reserve / Shortage	:	63	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.5° C						