			POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT								
Till now the maximum	generation is :		15648			21:0	0 Hrs on	19-Apr-23	teporting Date :	15-May-23	
The Summary of Yeste	erday's		14-May-23 Gene	ration & Demand		21.0	Today's Actual Min	Gen. & Probab	le Gen. & Dem	and	
Day Peak Generation	:		9774.0 MW	Hour :	12:0		Min. Gen. at		3:00		894
Evening Peak Generation			11025.0 MW	Hour :	21:0		Available Max Gener				1242
E.P. Demand (at gen end) Maximum Generation	1:		12732.0 MW 11025.0 MW	Hour : Hour :	21:0 21:0		Max Demand (Evenir Reserve(Generation				1200 42
Total Gen. (MKWH)	:		240.7		oad Factor : 90.9		Load Shed	·			196
				T/IMPORT THROUGH EAST-WEST							
Export from East grid to W	est grid :- Maximum				290 MW		22:00		Energy		
mport from West grid to E	East grid :- Maximum	Kaptai Lake at 6:00 A M on	15-Ma	-	MW	/ at	-		Energy		
Actual :	water Level of	73.87 Ft.(MSL)	13-Wi	sy-23	Rule curve :	79.34	Ft.( MSL )				
Gas Consumed :		Total =	788.20 MMC	ED.	Oil	Consumed (PD	R) ·				
ous consumos.		Total	700.20 111110		O	oundamod (i b	υ,.	HSD :			
								FO :			
Cost of the Consumed Fu	el (PDR+Pvt) ·		Gas :	Tk116,830,447							
Cost of the Consumed I to	er (i DD-i vt) .		Coal :	Tk310,429,138		Oil	: Tk853,512,205		Total :	Tk1,280,771,790	
				, , , , ,			,.			, ,	
		Load Sheddi	ng & Other Information								
Area		Yesterday					Todav				
7 4 5 5 6		•		Estimated Demand (S/S en	d)		Estimated Shedding	(S/S end)		Rates of Shedding	
		MW		MW				MW		(On Estimated Demand)	
Dhaka		710	0:00	4211					550	13%	
Chittagong Area Khulna Area		0	0:00 0:00	1155 1617					200 290	17% 18%	
Rajshahi Area		356	0:00	1405					261	19%	
Cumilla Area		119	0:00	1156					210	18%	
Mymensingh Area		173	0:00	860					161	19%	
Sylhet Area Barisal Area		0	0:00 0:00	482 402					85 60	18% 15%	
Rangpur Area		272	0:00	785					148	19%	
Total		1630		12073				1	965		
		Information of the Generating Units	under shut down.								
		Planned Shut- Down			For	ced Shut-Dov	m				
					1) E	Barapukuria ST:					
						Shorasal-3,7					
						Shula Nuton Bid					
						Baghabari-71,10 Raozan unit-2	U MVV				
					6) 5	Siddhirgani 210	ww				
						Shajibazar 330 M					
					8) 8	Sirajganj- 2					
Outage	Restore	Additional Information	of Machines, lines, Interrup	tion / Forced Load shed etc.							Rema
Time	Time										
09:29		Haripur 360MW GT SD due to gas shorta	age.								
09:40		Haripur 360MW ST SD due to gas shorta	ige.								
10:30 11:37	13:19	Haripur 412MW ST SD due to gas shorta BIPTC S/S 20DF31 Forced S/D Due to C	ige.								
12:45	16:10	Khulna (C) S/S North-WestCkt-1 Forced	S/D Due to Maintenance Work								
12:46	16:10	Khulna (C) S/S North- West Ckt-2 Force									
13:00		Bibiyana South ST tripped.									
13:43		Bibiyana South GT tripped.									
15:55		Ashuganj South 360MW tripped at 15:55 Bibiyana South GT was sync.	hrs. due to gas booster trip.							360 MW Power interrupt.	
		Haripur Power CCPP 360MW GT was sy	mc.								
18:01 20:26		Haripur Power CCPP 360MW GT was sy	mc.								
18:01 20:26 20:26		Haripur Power CCPP 360MW ST was sy	nc.								
18:01 20:26 20:26 22:50											
18:01 20:26 20:26 22:50 00:30		Bibiyana South 400 MW ST was sync.								I	
18:01 20:26 20:26 22:50 00:30 00:50		Bibiyana South 400 MW ST was sync. Haripur 412MW CCPP was shutdown du	e to gas shortage.								
18:01 20:26 20:26 22:50 00:30 00:50 01:14		Bibiyana South 400 MW ST was sync. Haripur 412MW CCPP was shutdown du Kushiara 163MW was shutdown due to g	as shortage.	e to 33by bue DS red hot maint						120 MW Load interrumt	
18:01 20:26 20:26 22:50 00:30 00:50 01:14 06:29		Bibiyana South 400 MW ST was sync. Haripur 412MW CCPP was shutdown du Kushiara 163MW was shutdown due to g Mymensingh 132/33kV S/S Transformer-	as shortage. 1 (404T) LT Scheduled S/D Du		n utility					120 MW Load interrupt.	
18:01 20:26 20:26 22:50 00:30 00:50 01:14		Bibiyana South 400 MW ST was sync. Haripur 412MW CCPP was shutdown du Kushiara 163MW was shutdown due to g	as shortage. 1 (404T) LT Scheduled S/D Du T Scheduled S/D Due to 33KV Bu	bar maintenance work of different distribution						120 MW Load interrupt. 24 MW Load interrupt. 24 MW Load interrupt.	
18:01 20:26 20:26 22:50 00:30 00:50 01:14 06:29 07:04		Biblyana South 400 MW ST was sync. Haripur 412MW CCPP was shutdown du Kushiara 163MW was shutdown due to g Mymensingh 132/33kV S/S Transformer- Mahasthangarh 132/33kV S/S 406T MTR1 L	as shortage. 1 (404T) LT Scheduled S/D Du T Scheduled S/D Due to 33KV Bu	bar maintenance work of different distribution						24 MW Load interrupt.	
18:01 20:26 20:26 22:50 00:30 00:50 01:14 06:29 07:04		Biblyana South 400 MW ST was sync. Haripur 412MW CCPP was shutdown du Kushiara 163MW was shutdown due to g Mymensingh 132/33kV S/S Transformer- Mahasthangarh 132/33kV S/S 406T MTR1 L	as shortage. 1 (404T) LT Scheduled S/D Du T Scheduled S/D Due to 33KV Bu	bar maintenance work of different distribution						24 MW Load interrupt.	
18:01 20:26 20:26 22:50 00:30 00:50 01:14 06:29 07:04		Biblyana South 400 MW ST was sync. Haripur 412MW CCPP was shutdown du Kushiara 163MW was shutdown due to g Mymensingh 132/33kV S/S Transformer- Mahasthangarh 132/33kV S/S 406T MTR1 L	as shortage. 1 (404T) LT Scheduled S/D Du T Scheduled S/D Due to 33KV Bu	bar maintenance work of different distribution						24 MW Load interrupt.	

Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle

Sub Divisional Engineer Network Operation Division