

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month May, 2023				Day : Monday				Date : 15.05.23				
Probable Maximum Demand : 12000 MW				Probable Maximum Generation : 12421 MW				Rule Curve = 79.34 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.92 ft				Today = 73.87 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.05.23 (Yesterday)		15.05.23 (Today)		14.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	120	120	80	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	51	280	300	309	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	90	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	136	51	0	0	361	Gas Shortage	
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	1 Unit under maint	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	50	16	50			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	22	22			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	50	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	22	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	50	16	52			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	148	100	148			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	196	80	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	114	135	135	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	202	301	300	300			
27	Branhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	80	70	80			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	40	75	75	80			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	17	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	72	17	162			
33	Manikgonj 35MW Solar PP (In Spectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	35	26	24	24			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	21	8	25			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	14	17	17			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0			
Dhaka Zone Total				6104	5867	1602	2169	2020	2600	1858	845	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	25	25	25	205	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	8	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	25	6	44			
45	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	34	70	34	105			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	87	227	88	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	84	0	84	84			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	47	55	54	57			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	30			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	51	92	92			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	25	25			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	10	22	22			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	163	36	163			
Chattogram Zone Total				2605	2545	477	717	585	1041	385	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	32	40	40	40			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	203	211	200	200			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	305	0	0	360		Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	315	310	355	360			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	187	189	180	180			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	18	140	20	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	30	35	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	34	34	68			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	18	18			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	7	7			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	0	20	20			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	90	55	96			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	11	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	54	94	54	94			
**	Import (Tirupura)	India		160	160	140	126	129	165			
Cumilla Zone Total				2904	2896	1385	1342	1258	1544	360	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	29	100	70	100	102	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	18	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	85	48	85			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	84	48	85			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	32	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	12	12			
Mymensing Zone Total				622	614	182	294	248	300	102	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.05.23 (Yesterday)		15.05.23 (Today)		14.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		27	GT-1 & GT-1 Under maint.	
88	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	29	30		61	GT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	112	0		54	ST Under maint.	
91	Hobgajj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	3	3				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	60				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	80	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	203	205	210	210				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
98	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	16	17		Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	315	280				
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	376	414	400				
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	381	50	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	45	49	44	44				
Sylhet Zone Total					2472	2427	1606	1450	1648	1668	17	572
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	410		Gas Shortage	
106	Fairdip 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	13	27	20	43			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	38	41	60	82			
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	105	105	105			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	73	0	100	0			
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	47	80	49	98			
113	Nospura 40 MW PP (Khajepahan Ali)	HFO (NENP)	5*8.5	40	40	8	32	8	40			
114	Maliree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0			
114	Khulna 330 MW CCPP	Gas-HSD (BPDF)				0	0	0	0			
**	Bheramara (H/DC)	India		1000	1000	921	875	931	931			
Khulna Zone Total					2905	2901	1132	1177	1290	1316	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	23	22	32			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	183	181	184	184			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1030	1244	1244	1244			
119	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	125	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	152	307	300	300			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas-HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220	Under maint.	
Barishal Zone Total					2265	2265	1400	1896	1767	1926	0	220
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	28	28	28			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	19	35	15	35			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	74	82	80	83			
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	24	40			
128	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	42	34	42	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	34	34	34			
130	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	162	164	170	170	46	Gas Shortage	
131	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	145	152	150	150	68	Gas Shortage	
133	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	290	335	380	380	79	Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	21	22	22			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	21	21	21			
140	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	400	392	400	400			
Rajshahi Zone Total					2927	2905	1361	1459	1450	1526	484	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	270	275	260	260		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	28	56	34	50			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	35	115			
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	181	0	130	0			
Rangpur Zone Total					1030	950	629	521	572	500	10	85
Sub-total: Plants in operation					23834	23370	9774.0	11025	10838	12421	3626	2715
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.776+1x3.5	108	0	0	0	0	0			
153	Ashuganj 55 MW PP (Pracison)	Gas (BEP)	15*7	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24143	23370	9774	11025	10838	12421	3626	2715
(C) Actual data of 14.05.23 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	12732 MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12096 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11025 MW, at =	21:00 hrs	Dhaka	4594	3884	710	Mymensingh	968	795	173
04.	Minimum Generation (Generation end)	:	9616 MW, at =	8:00 hrs	Chattogram	737	737	0	Sylhet	415	415	0
05.	Day-peak Generation (Generation end)	:	9774 MW, at =	12:00 hrs	Khulna	1515	1515	0	Barishal	332	332	0
06.	Evening-peak Generation (Generation end)	:	11025 MW, at =	21:00 hrs	Rajshahi	1489	1133	356	Rangpur	934	662	272
07.	Evening Peak Load-shed (Sub-station end)	:	1630 MW, at =	21:00 hrs	Cumilla	1111	992	119				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8943 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:										
a) Gas/LF limitation	:	3411 MW										
d) Coal supply Limitation	:	10 MW										
b) Low water level in Kaptai lake	:	205 MW										
c) Plants under shut down/ maintenance	:	2715 MW										
10.	Total Energy (Generation + India Import)	:	240.68 MWh									
	By Gas =	102.205 MWh	By Oil =	57.820 MWh								
	By Coal =	52.922 MWh	By Hydro =	0.325 MWh								
	By Solar =	2.576 MWh										
11.	Total Gas Supplied	:	788.20 MMCFD									
(D) Forecast of 15.05.23 (Today) Monday :												
01.	Maximum Demand	:	12000 MW	(Generation end)	04.	Maximum Load-shed	:	1965 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	12421 MW	(Generation end)	05.	Total Generation	:	261.97 MWh				
03.	Reserve / Shortage	:	421 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	33.0° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation