

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Thursday				Date : 18.05.23											
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 13254 MW				Rule Curve = 78.96 ft.											
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.79 ft.				Today = 73.74 ft.											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.05.23 (Yesterday)		18.05.23 (Today)		17.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance								
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :										
									Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)									
					Day	Evening	Day	Evening	Description/ Remarks										
Probable start-up date																			
(A) Plants in operation:																			
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work								
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage								
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180										
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.								
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage								
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage								
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0										
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	342	313	340	340	47	Gas Shortage								
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450										
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling								
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	392	401	380	380	11	Gas Shortage								
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	103	0	0	105	1 Unit under maint								
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage								
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	52	320	320	283	Gas Shortage								
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	5	15	0	55										
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	50	24	50										
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	15	19	19										
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	40	42	48	48										
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33										
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	33	20	20										
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	50	16	48										
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	88	88	88										
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	150	100	150										
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35										
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	195	45	195										
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	86	132	149	149										
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	0	0	300	300										
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	40	40										
28	Aurhatti 108MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	40	50										
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	35	55										
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55										
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	50	17	53										
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	72	162										
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	30	0	0										
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34										
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	7	18	16	17										
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	8	8	8	8										
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	5	79	17	85										
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	4	0	0	0										
Dhaka Zone Total				6104	5867	1998	2826	2959	3539	949	845								
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	50	205	Low water level								
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage								
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.								
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0										
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	25	25										
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	19	0	20	0	0										
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	44	6	40										
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	87	17	87										
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.								
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	71	151	145	150										
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	86	275	88	300										
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25										
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	82	84	67	84										
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	34	66	54	58										
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	6	10	11										
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	17	5	10										
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	0	30										
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17										
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	106	54	105										
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25										
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	92	22	100	22										
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17										
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	78	35	163										
Chattogram Zone Total				2605	2545	649	1100	740	1219	385	330								
60	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	39	40	40	40										
61	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	178	180	200	200										
62	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360	Gas Shortage								
63	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	310	310	350	350										
64	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400	Under maint.								
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	120	148	120	125										
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	25	43	43	43										
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	16	150	20	150										
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	36	35	35										
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under overhauling								
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17										
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	14	18	18										
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	6	5	7										
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	25	25	25										
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	0	52										
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	18	21	21										
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	70	114	114										
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	26	95	26	113										
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35										
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	108	54	115										
**	Import (Tijura)	India		160	160	108	144	129	152										
Cumilla Zone Total				2904	2896	947	1491	1252	1612	360	563								
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	43	52	42	80	150	Gas Shortage								
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	18	17	17										
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	88	47	88										
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	84	48	85										
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0										
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	55	0	50	0	0										
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	5	12	12	12										
Mymensingh Zone Total				622	614	199	254	218	282	150	0								

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.05.23 (Yesterday)		18.05.23 (Today)		17.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	0	29	60	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	50	50	51	51			
90	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	3	8			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	63	61	61			
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	77	84	84			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	207	207	210	210			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	18			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	8	8	9	Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	290	300			
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	367	400	400			
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	378	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	40	50	44	50			
Sylhet Zone Total												
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	43			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	70			
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Kussha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	0	17	17	17			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	85	105			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	105	0	100	0			
112	Khulna 115 MW PP (KCPCL-2)	HFO (NENP)	7x17	115	115	0	16	66	83			
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	24	40			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	318	370	330	330			
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				181	0	0	0			
**	Bheramara (HVDC)	India	1000	1000	911	910	925	925				
Khulna Zone Total												
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	25	22	35			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	180	163	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	1020	1244	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	153	152	150	150			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220	Under maint.	
Barishal Zone Total												
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	28	28			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	13	15	35			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	80	80			
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	24	40			
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	28	34			
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	152	160	170	170	50	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	158	0	0	62	Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	401	313	400	400	101	Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	20	20			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	30	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	57	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	50			
139	Antura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	28	21	21			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	397	400	0	0			
Rajshahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	73	75	75	12	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	260	260	260		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	78	34	107			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	109	115	115			
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	166	0	130	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PP(ULCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Aspugan 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0	0		
Sub-total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 17.05.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	11950 MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11369 MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11950 MW, at =	19:30 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	8469 MW, at =	9:00 hrs	Dhaka	4429	4429	0	Mymensingh	905	905	0
05.	Day-peak Generation (Generation end)	:	9376 MW, at =	12:00 hrs	Chattogram	1119	1119	0	Sylhet	455	455	0
06.	Evening-peak Generation (Generation end)	:	11950 MW, at =	19:30 hrs	Khulna	964	964	0	Barishal	362	362	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs	Rajshahi	1296	1296	0	Rangpur	788	788	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	4959 MW, at =	5:00 hrs	Cumilla	1052	1052	0				
09.	Generation shortfall at evening peak due to :	:							Total	11369	11369	0
	a) Gas/LF limitation	:	2562 MW		13.	Fuel cost :	(a) Gas = 132976150 Taka	(c) Coal = 215656425 Taka				
	d) Coal supply Limitation	:	12 MW				(b) Oil = 596811067 Taka	Total = 945443642 Taka				
	b) Low water level in Kaptai lake	:	205 MW									
	c) Plants under shut down/ maintenance	:	2714 MW									
10.	Total Energy (Generation + India Import)	:	237.51 MKWh		14.	Maximum Temperature in Dhaka was :	31.1° C					
	By Gas = 117.796 MKWh	By Oil = 43.753 MKWh			15.	Export through East-West interconnections :						
	By Coal = 49.503 MKWh	By Hydro = 0.304 MKWh				At evening peak-hour	:	9376 MW, at 19:30 hrs				
	By Solar= 2.330 MKWh					Maximum	:	432 MW, at 23:00 hrs				
11.	Total Gas Supplied	:	860.58 MMCFD			Energy	:	0 MKWh				
(D) Forecast of 18.05.23 (Today) Thursday :												
01.	Maximum Demand	:	12500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	13254 MW (Generation end)		05.	Total Generation	:	248.44 MKWh				
03.	Reserve / Shortage	:	754 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.1° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation