

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Friday				Date : 19.05.23				
Probable Maximum Demand : 12000 MW				Probable Maximum Generation : 14052 MW				Rule Curve = 78.96 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.74 ft Today = 73.70 ft				Rule Curve = 78.96 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.05.23 (Yesterday)		19.05.23 (Today)		18.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)			
										Day		Evening
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	100	120	80		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	105		Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	346	348	350	12		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	392	398	400	14		Gas Shortage	
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	335		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	317	270	320	65		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	0	25			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	41	24	50			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	10	19	19			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	28	49	47	47			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	31	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	49	16	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	100	82	100	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	195	45	195			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	116	114	17	149			
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	290	0	300	300			
27	Baramganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	40	0	40	40			
28	Aurhatti 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	40	0	40	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	53			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	108	72	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	19	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	17	9	40			
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	8	9	8	8			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	85	17	85			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0			
Dhaka Zone Total				6104	5867	2850	2899	2854	3566	929	740	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	44	6	40			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	87	17	87			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0		150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	211	220	220			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	290	88	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	38	38	38			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	84	67	84			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	20	66	54	58			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	7	0	10	11			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	7	15	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	0	30			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	92	54	105			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	38	25	25			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	100	33	22	33			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	62	35	163			
Chattogram Zone Total				2605	2545	508	1166	760	1298	385	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	34	35	40	40			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	207	212	200	200			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	250	360	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	350	310	350	350			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	130	167	130	150			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	21	150	20	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	38	35	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	5	5	7			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	12	21	21			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	67	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	95	26	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	102	54	115			
**	Import (Tirupura)	India		160	160	118	138	129	152			
Cumilla Zone Total				2904	2896	1147	1477	1262	1887	360	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	49	42	80	153	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	15	17	17			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	88	18	88			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	88	68	85			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	234	252	209	282	153	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.05.23 (Yesterday)		19.05.23 (Today)		18.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	90	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	48	50	51	51			
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	80	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	50	135	135	135			
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	0	17	18			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16	9	Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	250	290	300			
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	404	367	400	400			
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	330	315	400	400			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	48	48	48	48			
Sylhet Zone Total												
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	20	43			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	70			
108	Khulna 225 MW CAPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Kushtia 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	0	17	17	17			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	85	105			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	35	0	100	0			
112	Khulna 115 MW PP (KCPCL-2)	HFO (NENP)	7x17	115	115	0	66	66	83			
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	24	40			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	328	326	330	330			
115	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0			
**	Bheramara (HVDC)	India	1000	1000	907	905	928	928				
Khulna Zone Total												
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	23	22	35			
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	137	106	130	130			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	1060	700	1244			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	152	182	150	150			
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220	Under maint.	
Barishal Zone Total												
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	28	28			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	15	35			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	54	54	80	80			
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	24	40			
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	8	42	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	22	28	28	34			
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	178	177	170	170	33	Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	170	170	220	Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	416	418	400	400			
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	20	20			
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8			
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	30	52			
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	55	35	55			
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
141	Antara 30 MW PP (Srinia)	HFO (NENP)	7x7.79	50	28	28	14	21	21			
142	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	0	400	400	400			
Raishahi Zone Total												
143	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	74	75	75	11	Coal Shortage	
144	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
145	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260		Coal Shortage	
146	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	33	81	34	107			
148	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
149	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0			
150	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	115	115			
151	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	24	0	30	0			
152	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	58	0	130	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
153	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
154	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
155	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
156	Aspugan 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0	0		
Sub-total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 18.05.23 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	:	11823 MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11271 MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11823 MW, at =	19:30 hrs	Dhaka	4519	4519	0	Mymensingh	938	938	0
04.	Minimum Generation (Generation end)	:	4959 MW, at =	6:00 hrs	Chattogram	1034	1034	0	Sylhet	444	444	0
05.	Day-peak Generation (Generation end)	:	9855 MW, at =	12:00 hrs	Khulna	953	953	0	Barishal	335	335	0
06.	Evening-peak Generation (Generation end)	:	11823 MW, at =	19:30 hrs	Rajshahi	1238	1238	0	Rangpur	765	765	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs	Cumilla	1046	1046	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8700 MW, at =	5:00 hrs					Total	11271	11271	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 125694737 Taka (b) Oil = 606801022 Taka		(c) Coal = 246647341 Taka Total = 979143100 Taka			
a)	Gas/LF limitation	:	2585 MW		14.	Maximum Temperature in Dhaka was :	32.1° C					
b)	Low water level in Kaptai lake	:	205 MW		15.	Export through East-West interconnections :						
c)	Plants under shut down/ maintenance	:	2639 MW			At evening peak-hour	:	9855 MW, at	19:30 hrs			
10.	Total Energy (Generation + India Import)	:	226.30 MKWh			Maximum	:	460 MW, at	6:00 hrs			
	By Gas = 112.206 MKWh					Energy	:	0 MKWh				
	By Coal = 45.324 MKWh											
	By Solar = 1.962 MKWh											
11.	Total Gas Supplied	:	871.67 MMCFD									
(D) Forecast of 19.05.23 (Today) Friday :												
01.	Maximum Demand	:	12000 MW	(Generation end)	04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14052 MW	(Generation end)	05.	Total Generation	:	229.69 MKWh				
03.	Reserve / Shortage	:	2052 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.1° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation