

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Saturday				Date : 20.05.23				
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 13841 MW				Rule Curve = 78.39 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.70 ft Today = 73.66 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.05.23 (Yesterday)		20.05.23 (Today)		19.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	170	120	120			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	100	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	301	310	330	59	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	410	402	400	400			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	304	268	290	300	67	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	22	0	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	41	16	42			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	19	19			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	36	47	47	47			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	30	30			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	31	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	48	16	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	115	100	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	195	45	195			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	2	129	17	149			
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	140	0	300	300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	40	50			
28	Aurhatti 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	0	40	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	53			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	108			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	14	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	42	42	40	40			
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	9	8	8	8			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	65	17	85			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0			
Dhaka Zone Total				6104	5867	2477	2865	2775	3484	884	375	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	6	44			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	87	17	87			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	213	221	220	220			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	88	296	88	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	38	38	38			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	58	68	68	68			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	56	64	64	64			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	27	5	10			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	0	30			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	91	72	72			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	38	25	25			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	102	35	163			
Chattogram Zone Total				2605	2545	689	1212	779	1237	385	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	38	40	40			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	203	208	200	200			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	105	330	330	255	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	345	285	350	350			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	170	167	108	108			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	5	5			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	142	20	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	37	35	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	14	18	18			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	7	7	7			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	51	0	51			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	72	0	0			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	98	28	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	54	115			
**	Import (Tirupura)	India		160	160	118	144	129	152			
Cumilla Zone Total				2904	2896	1225	1613	1403	1753	255	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	62	45	80	140	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	15	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	84	18	88			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	83	68	85			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	21	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	182	259	210	283	140	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.05.23 (Yesterday)		20.05.23 (Today)		19.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date						
												Day	Evening	Day	Evening		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.					
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	20	20	20		70	GT-4 Under maint.					
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	42	45	50								
90	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	60	40	60								
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	80	81	84	84								
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	135	135	135	135								
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	17	17								
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage					
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	270	290	300								
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	377	400	400								
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	330	330	330	330								
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	45	50	50	50								
Sylhet Zone Total						2472	2427	1434	1463	1491	1526	9	581				
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage					
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	20	43							
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60	70							
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0	0							
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	17	17	17	17	17							
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	105	85	105	105							
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0								
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	19	81	66	83								
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	8	40								
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	330	320	330	330								
115	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0								
**	Bheramara (HVDC)	India		1000	1000	911	910	930	930								
Khulna Zone Total						2905	2901	1371	1473	1616	1618	410	0				
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16								
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	29	22	35								
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	122	129	130	130								
119	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	660	1190	700	1244								
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	100	17	150								
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	163	230	150	230								
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.					
Barishal Zone Total						2265	2265	967	1694	1019	1805	0	220				
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.					
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	28	28	28								
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	6	28	15	35								
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	18	82	50	80								
127	Katakhat 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	24	40								
128	Katakhat 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	42	42								
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	18	29	28	34								
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	174	172	170	170								
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	156	175	170	170								
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage					
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	415	370	400	380								
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22								
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	34	0	43								
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55								
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50								
139	Amnara 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	21	21	21								
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0								
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	405	404	400	400								
Raishahi Zone Total						2927	2905	1458	1552	1454	1578	291	100				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10		Coal Shortage					
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260			Coal Shortage					
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	33	60	34	107								
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0								
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	115	115	115								
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	14	0	30	0								
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	55	0	130	0								
Rangpur Zone Total						1030	950	475	510	652	557	10	85				
Sub-total: Plants in operation						23834	23370	10278.0	12641	11399	13841	2384	2254				
(B) Plants under long term maintenance/ contract expired																	
151	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilia 108MW PP(ULCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Aspugan 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0								
Sub-total: Plants under long term maintenance/ contract expired						339	0	0	0	0	0	0	0				
Gross Total						24143	23370	10278	12641	11399	13841	2384	2254				
(C) Actual data of 19.05.23 (Yesterday) Friday :																	
01.	Max. Demand at eve. peak (Generation end)	:	12641	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	12231	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	12641	MW, at =	20:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW				
04.	Minimum Generation (Generation end)	:	8700	MW, at =	7:00 hrs	Dhaka	4354	4354	0	Mymensingh	966	966	0				
05.	Day-peak Generation (Generation end)	:	10278	MW, at =	12:00 hrs	Chattogram	1235	1235	0	Sylhet	409	409	0				
06.	Evening-peak Generation (Generation end)	:	12641	MW, at =	20:00 hrs	Khulna	1554	1554	0	Barishal	424	424	0				
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	20:00 hrs	Rajshahi	1295	1295	0	Rangpur	705	705	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8609	MW, at =	5:00 hrs	Cumilla	1289	1289	0								
09.	Generation shortfall at evening peak due to :	:										Total	12231	12231	0		
a)	Gas/LF limitation	:	2169	MW								(a) Gas =	138409133	Taka	(c) Coal =	251669803	Taka
c)	Coal supply Limitation	:	10	MW								b) Oil =	684581073	Taka	Total =	1074860009	Taka
b)	Low water level in Kaptai lake	:	205	MW													
c)	Plants under shut down/ maintenance	:	2254	MW													
10.	Total Energy (Generation + India Import)	:	250.81	MKWh													
	By Gas =	122.316	MKWh	By Oil =	48.834												
	By Coal =	53.038	MKWh	By Hydro =	0.303												
	By Solar =	1.847	MKWh														
11.	Total Gas Supplied	:	951.68	MMCFD													
(D) Forecast of 20.05.23 (Today) Saturday :																	
01.	Maximum Demand	:	13000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	13841	MW	(Generation end)	05.	Total Generation	:	257.93	MKWh							
03.	Reserve / Shortage	:	841	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.4° C								

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation