

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Tuesday				Date : 23.05.23				
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 15081 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.54 ft Today = 73.42 ft				Rule Curve = 77.80 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.05.23 (Yesterday)		23.05.23 (Today)		22.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
												Day
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	40	52	52	52	56	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	325	326	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	397	410	410			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	97	96	100	100	114	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	198	195	220	220	140	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	307	305	310	310			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	18	0	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	33	8	42			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	0	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	45	43	47	47			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	32	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	49	8	49			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	65	88	70	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	149	64	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	48	196	45	195			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	133	135	135			
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	145	12	300	300			
27	Bramhanganj 100 MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	20	25	40	50			
28	Aurhatti 100MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	58	25	40	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	40	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	53			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	17	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	10	41	8	40			
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	9	34	8	33			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	37	85	17	102			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	11	0	12			
Dhaka Zone Total				6104	5867	3002	3443	3219	3905	415	375	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	65	80	60	80	100	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	44	44			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	30	85	34	85			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	226	226	226			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	280	88	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	38	38	38			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	48	51	68	68			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	50	64	54	70			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	21	5	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	11	0	12			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	74	54	72	54			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	50	90	50			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	126	18	163			
Chattogram Zone Total				2605	2545	795	1247	932	1337	305	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	35	35	35			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	195	181	200	200			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	315	305	300	300			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	305	330	330			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	185	138	179	179			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	140	20	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	40	43	43			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	1	51	8	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	18	20	20			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	0	17			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	29	97	27	95			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	19	72	18	72			
**	Importo (Tripura)	India		160	160	150	144	129	152			
Cumilla Zone Total				2904	2896	1419	1775	1444	1780	0	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	102	40	90	100	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	18	18	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	18	85			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	87	68	85			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	186	304	208	290	100	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.05.23 (Yesterday)		23.05.23 (Today)		22.05.23 (Yesterday)		(Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks		Probable start-up date			
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)						
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	GT-1 & ST-1 Under maint.				
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	38	40	40			52	GT-4 Under maint.				
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50								
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112			54	ST Under maint.				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	62	59	60								
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	78	78	84								
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	57	135	130	130								
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17								
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	12	16	16	13			Gas Shortage				
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	300	300	300								
100	Bibi yana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	383	368	400	400								
101	Bibi yana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	330	350	330	330								
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work				
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	50	50	50	50								
Sylhet Zone Total						2472	2427	1554	1636	1646	1653	13	563				
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	400	400	410			Gas Shortage				
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	22	43								
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	60	80								
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17								
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	85	85	105								
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	100	0								
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	16	86	32	98								
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	16	24	24	32								
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	340	326	330	330								
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0								
**	Bheramara (HVDC)	India		1000	1000	921	795	940	810								
Khulna Zone Total						2905	2901	1388	1388	2010	1915	410	0				
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16								
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	33	22	35								
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	145	171	150	160								
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	910	1244	1244	1244								
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	64	17	150								
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	221	307	220	307								
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0			220	Under maint.				
Barishal Zone Total						2265	2265	1315	1835	1669	1912	0	220				
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Under maint.				
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	28	28								
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	7	35	35								
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	83	60	80								
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	40	40								
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42								
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	30								
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	162	157	150	150								
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	212	212	210	210								
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220			Gas Shortage				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	418	426	350	380								
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22								
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8								
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	50	75	35	55								
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50								
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	21	21	21								
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0								
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	609	611	605	605								
Rajshahi Zone Total						2927	2905	1519	1791	1677	1764	291	100				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	74	75	75	11			Coal Shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling				
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260				Coal Shortage				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	32	70	55	75								
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0								
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	54	114	50	115								
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	25	0	30	0								
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	122	0	130	0								
Rangpur Zone Total						1030	950	572	518	608	525	11	85				
Sub-total: Plants in operation						23834	23370	11750.0	13937	13413	15081	1545	2236				
(B) Plants under long term maintenance/ contract expired																	
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilia 108MW PP(ULCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Aspiganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0								
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0				
Gross Total						24143	23370	11750	13937	13413	15081	1545	2236				
(C) Actual data of 22.05.23 (Yesterday) Monday :																	
01.	Max. Demand at eve. peak (Generation end)	:	14251	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	13676	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	13937	MW, at =	21:00 hrs		MW	MW	MW		MW	MW	MW				
04.	Minimum Generation (Generation end)	:	8863	MW, at =	6:00 hrs	Dhaka	4837	4837	0	Mymensingh	1065	1030	35				
05.	Day-peak Generation (Generation end)	:	11750	MW, at =	12:00 hrs	Chattogram	1404	1349	55	Sylhet	501	501	0				
06.	Evening-peak Generation (Generation end)	:	13937	MW, at =	21:00 hrs	Khulna	1773	1748	25	Barishal	466	441	25				
07.	Evening Peak Load-shed (Sub-station end)	:	300	MW, at =	21:00 hrs	Rajshahi	1370	1370	0	Rangpur	855	855	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11299	MW, at =	5:00 hrs	Cumilla	1405	1245	160								
09.	Generation shortfall at evening peak due to :	:										Total	13676	13376	300		
	a) Gas/LF limitation	:	1329	MW								(a) Gas =	163961990	Taka	(c) Coal =	254687676	Taka
	c) Coal supply Limitation	:	11	MW								b) Oil =	575820267	Taka	Total =	994569933	Taka
	b) Low water level in Kaptai lake	:	205	MW													
	c) Plants under shut down/ maintenance	:	2236	MW													
10.	Total Energy (Generation + India Import)	:	272.46	MKWh													
	By Gas =	143.287	MKWh	By Oil =	41.954												
	By Coal =	59.422	MKWh	By Hydro =	0.302												
	By Solar =	2.793	MKWh														
11.	Total Gas Supplied	:	1176.22	MMCFD													
(D) Forecast of 23.05.23 (Today) Tuesday :																	
01.	Maximum Demand	:	14500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	15081	MW	(Generation end)	05.	Total Generation	:	283.46	MKWh							
03.	Reserve / Shortage	:	581	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.6° C								

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation