

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Thursday				Date : 25.05.23				
Probable Maximum Demand : 13500 MW				Probable Maximum Generation : 14866 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.30 ft Today = 73.18 ft				Rule Curve = 77.40 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.05.23 (Yesterday)		25.05.23 (Today)		24.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :			
									Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	306	350	350			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	401	410	410			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	102	101	100	100	109	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	220	210	220	220	125	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	290	247	310	310			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	0	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	24	8	24			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	15	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	43	46	47	47			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	50	25	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	70	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	98	150	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	50	148	45	195			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	127	50	149			
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x6.14	300	300	0	0	300	300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	68	0	40	100			
28	Aurhatti 108MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	40	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	126	35	126			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	42	8	40			
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	8	34	8	33			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	96	85	102	102			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0			
Dhaka Zone Total				6104	5867	2769	3146	3270	3888	447	375	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	90	90	90	90	90	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	16	8	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	34	44	44			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	90	51	34	68			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	207	226	226			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	273	85	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	60	50	90			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	41	68	68	68			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	59	66	56	56			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			9	5	5	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	11	0	12			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	35	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	74	54	74	54			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	76	70	90			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	55	67	55	55			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	72	18	163			
Chattogram Zone Total				2605	2545	942	1244	994	1447	295	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	43	43	43			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	182	180	200	200			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	305	305	320	320			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	305	290	330	330			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	138	137	160	160	58	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	123	12	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	40	39	43	43			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	16	15	15			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	8	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	43	8	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	0	20	20			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	47	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	29	75	27	95			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	35	115			
**	Import (Tijura)	India		160	160	112	142	129	152			
Cumilla Zone Total				2904	2896	1372	1656	1576	1929	58	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	23	68	40	90	134	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	18	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	85	18	85			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	67	87	68	85			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	192	271	208	290	134	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.05.23 (Yesterday)		25.05.23 (Today)		24.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	50	50				
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	57	59	60				
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	132	128	150	220				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	17	17	17				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	14	16	16	11		Gas Shortage	
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0				
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	80	402	400	400				
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	55	330	370				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	47	50	50				
Sylhet Zone Total						2472	2427	669	1064	1372	1483		
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0		11	561	
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	30	405	400	400				
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	22	43				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	60	80				
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	0	17	17	17				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	85	105				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0				
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	49	32	98				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	24	32				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	326	325	330	330				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				308	363	0	0				
**	Bheramara (HVDC)	India	1000	1000	893	905	932	932					
Khulna Zone Total						2905	2901	1625	2157	2002	2037	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	17	22	35				
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	165	178	150	160				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	640	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	152	224	220	307				
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total						2265	2265	899	1092	1047	1290	0	
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	28	28				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	35				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	24	80	80				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	40	40				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	42	42				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	30				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	98	150	150	112		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	193	211	220	220				
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	424	354	350	380	60		Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	20	22	22				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	92	35	70				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	57				
139	Amnura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	14	21	21				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	0	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	492	657	748	748				
Raishahi Zone Total						2927	2905	1109	1560	1850	1939	463	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	73	75	75	12		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	200	260	260			Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	73	35	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	110	50	115				
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	12	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	204	0	130	0				
Rangpur Zone Total						1030	950	457	456	588	563	12	
Sub-total: Plants in operation						23834	23370	10034.0	12646	12907	14866	1420	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Aspiganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						339	0	0	0	0	0	0	
Gross Total						24143	23370	10034	12646	12907	14866	1420	
(C) Actual data of 24.05.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	12700	MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12098	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	
03.	Highest Generation (Generation end)	:	12646	MW, at =	19:30 hrs	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	8101	MW, at =	6:00 hrs	Dhaka	4718	4718	0	Mymensingh	936	884	
05.	Day-peak Generation (Generation end)	:	10034	MW, at =	12:00 hrs	Chattogram	1065	1065	0	Sylhet	511	511	
06.	Evening-peak Generation (Generation end)	:	12646	MW, at =	19:30 hrs	Khulna	1418	1418	0	Barishal	308	308	
07.	Evening Peak Load-shed (Sub-station end)	:	52	MW, at =	19:30 hrs	Rajshahi	1269	1269	0	Rangpur	871	871	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8925	MW, at =	5:00 hrs	Cumilla	1002	1002	0				
09.	Generation shortfall at evening peak due to :	:				Total						12098	
	a) Gas/LF limitation	:	1203	MW		Total						12046	
	c) Coal supply Limitation	:	12	MW		Total						12060	
	b) Low water level in Kaptai lake	:	205	MW		Total						12046	
	c) Plants under shut down/ maintenance	:	2234	MW		Total						12046	
10.	Total Energy (Generation + India Import)	:	245.78	MKWh		Total						12046	
	By Gas =	136.397	MKWh	By Oil =	35.243	Total						12046	
	By Coal =	46.635	MKWh	By Hydro =	0.301	Total						12046	
	By Solar =	3.019	MKWh			Total						12046	
11.	Total Gas Supplied	:	1103.03	MMCFD		Total						12046	
(D) Forecast of 25.05.23 (Today) Thursday :													
01.	Maximum Demand	:	13500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14866	MW	(Generation end)	05.	Total Generation	:	262.38	MKWh			
03.	Reserve / Shortage	:	1366	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.2° C				