

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 3564667, 3551095

Month May, 2023		Day: Friday		Date: 26.05.23									
Probable Maximum Demand : 12000 MW		Probable Maximum Generation : 15362 MW											
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 73.18 ft		Today = 73.12 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	25.05.23 (Yesterday)		26.05.23 (Today)		Rule Curve = 77.20 ft.		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gen. shortfall for : r Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening					
<b>(A) Plants in operation:</b>													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0				
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210 1 x 210	210 210	180 190	110 180	106 180	110 180	110 180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	331	332	350	350				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0				
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	409	402	410	410				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	98	37	100	100	173	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	210	210	220	220	125	Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	281	268	310	310				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	24	24				
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	48	45	50				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	32	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	42	25	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	88	70	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	115	147	150	150				
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	138	45	195				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	127	50	149				
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	256x1.4	300	300	102	0	300	300				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	25	40	100				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	42	25	40	50				
29	Nababganj 55 MW PP (Southern power )	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	126	35	126				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	34				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	25	8	45				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	33	9	32				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	95	102	102				
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	12	0	0				
<b>Dhaka Zone Total</b>			<b>6104</b>	<b>5867</b>	<b>2902</b>	<b>3236</b>	<b>3279</b>	<b>3905</b>	<b>511</b>	<b>375</b>			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level		
40	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210 1 x 210	210 210	180 180	95 0	103 0	100 0	100 0	77	Gas Shortage Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	39	44	44				
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	34	68				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
47	Sikalbaha 25 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	222	226	226				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	87	278	85	300				
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	75	50	75				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	49	68	68				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	64	56	64				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10				
*	Malancha, Clg EPZ (United)	Gas	5x8.73+3x9.34			3	30	20	40				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	16	0	16				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	35	17	35				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	61	54	54				
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	64	90	70	90				
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	55	78	55	78				
58	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34				
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	72	18	163				
**	SS Power Unit-1	Coal (IPP)				0	255	300	450				
<b>Chattogram Zone Total</b>			<b>2605</b>	<b>2545</b>	<b>853</b>	<b>1602</b>	<b>1299</b>	<b>1965</b>	<b>282</b>	<b>330</b>			
60	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	35	38	43	43				
61	Ashuganj 225 MW CCPP	Gas (AFSCL)	1x142+175	221	221	205	209	200	200				
62	Ashuganj 450 MW CCPP(South)	Gas (AFSCL)	1x360	360	360	320	305	320	320				
63	Ashuganj 450 MW CCPP(North)	Gas (AFSCL)	1x361	360	360	305	305	330	330				
64	Ashuganj 420 MW CCPP(East)	Gas (AFSCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.		
65	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	172	192	78	192				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	105	12	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	39	43	43				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	15	17	17				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	16	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	8	52				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	20	21				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	70	88	114	114				
77	Chowmuhanj 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	92	27	95				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	28	17	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	35	115				
**	Impoort (Tipture)	India		160	160	152	142	129	152				
<b>Cumilla Zone Total</b>			<b>2904</b>	<b>2896</b>	<b>1501</b>	<b>1632</b>	<b>1497</b>	<b>1983</b>	<b>0</b>	<b>563</b>			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	83	52	90	119	Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
82	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	75	18	75				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	87	68	88				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	55	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>207</b>	<b>276</b>	<b>221</b>	<b>284</b>	<b>119</b>	<b>0</b>			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.05.23 (Yesterday)		26.05.23 (Today)		25.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date	
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.		
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	47	47	50	50					
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.		
91	Hobignaj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	56	59	60					
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	84	84					
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	20	106	200	210					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	15	16	16	16	9		Gas Shortage		
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0					
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	398	390	400	400					
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	380	360	380					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	44	50	50	50					
<b>Sylhet Zone Total</b>														
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	240	350	350					
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	23	22	43					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	60	80					
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Kushtia 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	67	85	105					
111	Mongla Oron 100 MW Solar PP	Solar (IPP)		100	100	85	0	100	0					
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	87	32	98					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	24	40	8	40					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	324	320	330	330					
**	Khulna 330 MW CAPP	Gas/HSD (BPDB)				304	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	913	914	921	921					
<b>Khulna Zone Total</b>														
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16					
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	13	30	22	35					
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	172	165	155	165					
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	620	622	622					
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	150					
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	271	220	307					
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.		
<b>Barishal Zone Total</b>														
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	0		100	Under maint.		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	21	25	25					
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	35					
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	72	80	80					
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	40	40					
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	30	35					
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	130	150	150	150		60	Gas Shortage		
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	220	137	150	150		83	Gas Shortage		
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage		
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	254	346	350	380		68	Gas Shortage		
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	21	21					
135	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	35	113					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50					
139	Amritara 30 MW PP (Srinia)	HFO (NENP)	7x7.79	50	28	0	0	21	21					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	6	0	6	0					
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	647	740	748	748					
<b>Rajshahi Zone Total</b>														
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	74	75	75		11	Coal Shortage		
b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	230	260	260			Coal Shortage		
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	107	35	107					
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	114	50	115					
148	Lalmohat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	19	0	30	0					
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	162	0	130	0					
<b>Rangpur Zone Total</b>														
<b>Sub-total: Plants in operation</b>														
<b>(B) Plants under long term maintenance/ contract expired</b>														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
152	Bosilia 108MW PPI(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
153	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0					
<b>Sub-total: Plants under long term maintenance/ contract expired</b>														
<b>Gross Total</b>														
<b>(C) Actual data of 25.05.23 (Yesterday) Thursday :</b>														
01.	Max. Demand at eve. peak (Generation end)	:	13563	MW, at =	20:00	hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end):							
02.	Max. Demand at eve. peak (Sub-station end)	:	12914	MW, at =	20:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13507	MW, at =	20:00	hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	8925	MW, at =	6:00	hrs	Dhaka	4667	4667	0	Mymensingh	1063	1010	53
05.	Day-peak Generation (Generation end)	:	11747	MW, at =	12:00	hrs	Chattogram	1305	1305	0	Sylhet	557	557	0
06.	Evening-peak Generation (Generation end)	:	13507	MW, at =	20:00	hrs	Khulna	1365	1365	0	Barishal	394	394	0
07.	Evening Peak Load-shed (Sub-station end)	:	53	MW, at =	20:00	hrs	Rajshahi	1393	1393	0	Rangpur	870	870	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8035	MW, at =	5:00	hrs	Cumilla	1300	1300	0				
09.	Generation shortfall at evening peak due to :	:					Total		12914		12861		53	
a)	Gas/LF limitation	:	1218	MW			Fuel cost :		(a) Gas = 167469300	Taka	(c) Coal = 196619201	Taka		
d)	Coal supply Limitation	:	11	MW					(b) Oil = 457507760	Taka	Total = 821596261		Taka	
b)	Low water level in Kaptai lake	:	205	MW										
c)	Plants under shut down/ maintenance	:	2234	MW										
10.	Total Energy (Generation + India Import)	:	266.73	MKWh										
	By Gas =	145.513	MKWh	By Oil =	35.469	MKWh								
	By Coal =	56.879	MKWh	By Hydro =	0.311	MKWh								
	By Solar=	3.113	MKWh											
11.	Total Gas Supplied	:	1068.40	MMCFD										
<b>(D) Forecast of 26.05.23 (Today) Friday :</b>														
01.	Maximum Demand	:	12000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15362	MW	(Generation end)		05.	Total Generation	:	236.97	MKWh			
03.	Reserve / Shortage	:	3362	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.6° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation