

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Sunday				Date : 28.05.23				
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 14324 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.07 ft		Today = 73.01 ft		28.05.23		Rule Curve = 76.80 ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	27.05.23 (Yesterday)		28.05.23 (Today)		27.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	119	120	120			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	323	319	340	320			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	398	400	390			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	97	38	100	100	172	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	210	140	210	210	195	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	304	285	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	20	15	0	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	24	8	25			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	22	17	17			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	25	42	42	42			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	50	8	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	98	64	150			
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.89	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	135	45	145			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	33	149	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	80			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	17	54			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	34	8	40			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	34	9	33			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	85	34	85	85			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0			
Dhaka Zone Total			6104	5867	2673	2975	3140	3710	558	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	110	100	100	70	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	8	40	18	40			
45	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	227	225	225			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	278	87	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	50	90			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	68			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	48	66	50	50			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			3	24	4	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	10	0	16			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	90	38	90			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	44	79	45	80			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	72	18	144			
**	SS Power Unit-1	Coal (IPP)				0	0	0	0			
Chattogram Zone Total			2605	2545	845	1343	876	1439	275	330		
60	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	36	42	43	43			
61	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	187	211	200	200			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	305	305	300	320			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	320	310	300	320			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	187	168	168	168			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	120	13	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	35	40	40			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	16	17	17	17			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	16	16			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	0	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	16	16			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	61	100	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	95	27	95			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	91	18	115			
**	Import (Tripura)	India		160	160	164	144	129	152			
Cumilla Zone Total			2904	2896	1433	1789	1499	1930	0	563		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	84	99	40	90	103	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	18	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	75	18	75			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	87	68	88			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
85	Sutiakhat 50 MW Solar PP	Solar (IPP)	1x50	50	50	4	0	50	0			
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensing Zone Total			622	614	206	292	208	283	103	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.05.23 (Yesterday)		28.05.23 (Today)		27.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.			
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	50	50						
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	58	60	60						
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	82	84	84						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	202	200	202						
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	17	17						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage			
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	280	300	300						
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	367	400	400						
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	383	370	400	400						
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	50	50	50	50						
Sylhet Zone Total						2472	2427	1410	1688	1793	1795	9	561		
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	220	175	150	150						
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	22	40						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	91	60	80						
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	0	17	17	17						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	85	85	105						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	35	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	32	98						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	8	40						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	334	327	330	330						
**	Bheramara 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0						
Bheramara (HVDC)						1000	1000	905	904	931	931				
Khulna Zone Total						2905	2901	1599	1653	1735	1791	0	0		
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16						
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	28	22	30						
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	171	171	175	175						
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	380	600	600						
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	11	54	17	54						
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	309	260	307						
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.			
Barishal Zone Total						2265	2265	775	958	1090	1182	0	220		
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	0	100		Under maint.			
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	21	25	25						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	35	35						
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	26	92	80	90						
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	40	40						
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	25	42	42						
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	30	35						
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage			
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	132	123	120	120	97		Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	17	121	120	120	99		Gas Shortage			
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	288	230	230	126		Gas Shortage			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	21	22						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	55	35	55						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	50	50						
139	Amshura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	21	21	21						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	714	754	748	748						
Raishahi Zone Total						2927	2905	1455	1667	1611	1649	603	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	73	75	73	73	10		Coal Shortage			
b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	0	85		Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	220	250	250			Coal Shortage			
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	107	107						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	20	112	74	115						
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	22	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	48	0	130	0						
Rangpur Zone Total						1030	950	384	456	672	545	10	85		
Sub-total: Plants in operation						23834	23370	10780.0	12821	12624	14324	1558	2234		
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
152	Bosilia 108MW PP(ULCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
153	Aspiganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0		
Gross Total						24143	23370	10780	12821	12624	14324	1558	2234		
(C) Actual data of 27.05.23 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	12821 MW, at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	12294 MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	:	12821 MW, at =	20:00 hrs		MW	MW	MW		MW	MW	MW			
04.	Minimum Generation (Generation end)	:	9541 MW, at =	6:00 hrs	Dhaka	4404	4404	0	Mymensingh	985	985	0			
05.	Day-peak Generation (Generation end)	:	10780 MW, at =	12:00 hrs	Chattoagram	1351	1351	0	Sylhet	495	495	0			
06.	Evening-peak Generation (Generation end)	:	12821 MW, at =	20:00 hrs	Khulna	1495	1495	0	Barisal	360	360	0			
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	20:00 hrs	Rajshahi	1273	1273	0	Rangpur	817	817	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9649 MW, at =	5:00 hrs	Cumilla	1114	1114	0							
09.	Generation shortfall at evening peak due to :	:			Total								12294	12294	0
a) Gas/LF limitation	:	1343 MW			13.	Fuel cost :	a) Gas =	171126259 Taka	(c) Coal =	99951031 Taka					
c) Coal supply Limitation	:	10 MW		b) Oil =			532077406 Taka	Total =	803154696 Taka						
b) Low water level in Kaptai lake	:	205 MW			14.	Maximum Temperature in Dhaka was :							33.1° C		
c) Plants under shut down/ maintenance	:	2234 MW			15.	Export through East-West interconnections :									
10.	Total Energy (Generation + India Import)	:	260.82 MKWh			At evening peak-hour							10780 MW, at	20:00 hrs	
	By Gas =	147.863 MKWh	By Oil =	39.972 MKWh		Maximum							440 MW, at	19:30 hrs	
	By Coal =	45.610 MKWh	By Hydro =	0.305 MKWh		Energy							0 MKWh		
	By Solar =	2.095 MKWh													
11.	Total Gas Supplied	:	1072.02 MMCFD												
(D) Forecast of 28.05.23 (Today) Sunday :															
01.	Maximum Demand	:	13800 MW (Generation end)	04.	Maximum Load-shed									0 MW At evening peak (Sub-station end)	
02.	Maximum Generation	:	14324 MW (Generation end)	05.	Total Generation									280.74 MKWh	
03.	Reserve / Shortage	:	524 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :									33.1° C	

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation