

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023				Day : Tuesday				Date : 30.05.23					
Probable Maximum Demand :				14900 MW		Probable Maximum Generation :				14937 MW			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 72.95 ft		Today = 72.87 ft				Rule Curve = 76.40 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	29.05.23 (Yesterday)		30.05.23 (Today)		29.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	190	190				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86	Gas Shortage		
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	327	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	398	400	400				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	93	95	100	100	115	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	208	200	210	210	135	Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	300	305	300	300				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	20	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	8	16				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	45	42	42				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	31	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	47	8	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	82	88	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	150	64	150				
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	277	50	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	149	17	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	285	300	300	300				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	60	45	0	0				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	86	95	50	100				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	17	54				
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	10	17	8	16				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	16	8	32				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	82	85	85	85				
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	12	10	0	12				
Dhaka Zone Total				6104	5867	3148	3780	3114	3808	441	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	44	18	40				
45	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	220	225	225				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	284	87	300				
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	90	50	90				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	49	51	51	68				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	64	50	64				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10				
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	20	4	20				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	16				
54	Sikalbaha 54 MW PP (Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54				
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	90	38	90				
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	45	66	45	80				
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34				
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	163	18	163				
**	SS Power Unit-1	Coal (IPP)				0	0	0	0				
Chattogram Zone Total				2605	2545	788	1398	876	1472	285	330		
60	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	34	39	43	43				
61	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	199	202	210	210				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	330	330	310	320				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	340	330	310	320				
64	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400	Under maint.		
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'116	195	195	167	167	168	168				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	139	13	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	38	40	40				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	120	34	120				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	16	16				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	16	52				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	21	21				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	114	100	114				
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	29	105	27	105				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	116	18	115				
**	Impoqit (Tripura)	India		160	160	132	156	129	152				
Cumilla Zone Total				2904	2896	1531	2065	1585	2076	0	563		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	85	45	90	117	Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	19	19	19				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	18	85				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	88				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	12	12	12				
Mymensingh Zone Total				622	614	192	289	214	294	117	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.05.23 (Yesterday)		30.05.23 (Today)		29.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)						
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43		27	GT-1 & ST-1 Under maint.					
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	40	40	40		50	GT-4 Under maint.					
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50								
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11								
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	50	60	60								
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	81	84	84								
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	199	200	202								
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	17								
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10								
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	300	300	300								
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	395	400	400								
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	373	363	400	400								
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0								
Sylhet Zone Total						2472	2427	1684	1664	1726	1745	9	561				
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	155	150	180	200	260		Gas Shortage					
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	28	22	40								
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	11	88	60	80								
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	35	17	55								
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	89	105	105	105								
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0								
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	67	62	32	83								
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	8	40								
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	319	325	330	330								
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0								
**	Bheramara (HVDC)	India		1000	1000	908	898	930	930								
Khulna Zone Total						2905	2901	1650	1707	1784	1863	260	0				
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16								
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	33	22	30								
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	168	172	175	175								
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	622	580	622								
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150								
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	307								
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.					
Barishal Zone Total						2265	2265	705	1143	960	1300	0	220				
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.					
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	21	21	25	25								
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	35								
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	87	80	90								
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	40	40								
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34								
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	35	35								
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	144	143	160	160	67		Gas Shortage					
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage					
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	141	154	150	150	66		Gas Shortage					
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	261	260	300	300	154		Gas Shortage					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	20	21	22								
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8								
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55								
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50								
139	Ammura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28								
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0								
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	766	858	852	852								
Rajshahi Zone Total						2927	2905	1604	1801	1844	1892	578	100				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	73	75	73	73	10		Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250			Coal Shortage					
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	28	49	35	49								
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0								
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	74	115								
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0								
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	204	0	130	0								
Rangpur Zone Total						1030	950	632	489	600	487	10	85				
Sub-total: Plants in operation						23834	23370	11934.0	14336	12703	14937	1700	2234				
(B) Plants under long term maintenance/ contract expired																	
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilia 108MW PP (ULCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Aspiganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0								
Sub-total: Plants under long term maintenance/ contract expired						339	0	0	0	0	0	0	0				
Gross Total						24143	23370	11934	14336	12703	14937	1700	2234				
(C) Actual data of 29.05.23 (Yesterday) Monday :																	
01.	Max. Demand at eve. peak (Generation end)	:	14950	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	14203	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	14336	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW				
04.	Minimum Generation (Generation end)	:	10960	MW, at =	6:00 hrs	Dhaka	4993	4933	60	Mymensingh	1085	1000	85				
05.	Day-peak Generation (Generation end)	:	11934	MW, at =	12:00 hrs	Chattogram	1473	1473	0	Sylhet	603	593	10				
06.	Evening-peak Generation (Generation end)	:	14336	MW, at =	21:00 hrs	Khulna	1779	1601	178	Barishal	442	442	0				
07.	Evening Peak Load-shed (Sub-station end)	:	586	MW, at =	21:00 hrs	Rajshahi	1460	1322	138	Rangpur	965	865	100				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11306	MW, at =	5:00 hrs	Cumilla	1403	1388	15								
09.	Generation shortfall at evening peak due to :	:				Total											
	a) Gas/LF limitation	:	1485	MW		13. Fuel cost :				(c) Coal =							
	d) Coal supply Limitation	:	10	MW		(a) Gas = 177001058 Taka				156392744 Taka							
	b) Low water level in Kaptai lake	:	205	MW		(b) Oil = 814881993 Taka				Total = 1148275795 Taka							
	c) Plants under shut down/ maintenance	:	2234	MW		14. Maximum Temperature in Dhaka was : 36.3° C											
10.	Total Energy (Generation + India Import)	:	292.39	MKWh		15. Export through East-West interconnections :											
	By Gas =	154.390	MKWh	By Oil =	57.807	At evening peak-hour :											
	By Coal =	51.115	MKWh	By Hydro =	0.307	Maximum :											
	By Solar =	3.502	MKWh			Energy :											
11.	Total Gas Supplied	:	1182.00	MMCFD		At evening peak-hour :											
(D) Forecast of 30.05.23 (Today) Tuesday :																	
01.	Maximum Demand	:	14900	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	14937	MW	(Generation end)	05.	Total Generation	:	303.89	MKWh							
03.	Reserve / Shortage	:	37	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	36.3° C								