

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month June, 2023					Day : Thursday				Date : 01.06.23				
Probable Maximum Demand : 15500 MW					Probable Maximum Generation : 14756 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 72.79 ft		Today = 72.71 ft		Rule Curve = 76.00 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.05.23 (Yesterday)		01.06.23 (Today)		31.05.23 (Yesterday)		01.06.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	328	320	320	320				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	400	401	400	400				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	150	191	180	190				
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	170	170	160	170	165		Gas Shortage	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	299	256	300	300				
14	Madanganj-55 MW PP (Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	0	30	15	25				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	8	16				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22				
17	Summit Power,Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	35	45	42	45				
18	Maona 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	70	70	70				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	150	64	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	293	296	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	149	17	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	155	300	300	300				
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	94	96	50	100				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	17	54				
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	15	16	8	16				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	17	8	17				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	76	82	80	82				
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0				
Dhaka Zone Total					6104	5867	3178	3720	3347	3783	356	375	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0				
42	Raczen 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	17	44	18	44				
45	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	227	225	225				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	281	87	280				
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	90	50	90				
50	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	47	51	51	51				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	37	63	50	64				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	25	5	25				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54				
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	90	38	90				
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	66	45	66				
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34				
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	163	18	163				
	SS Power Unit-1	Coal (IPP)				0	0	0	0				
	Cox's Bazar Wind PP	(Wind) (IPP)				1	0	0	0				
Chattogram Zone Total					2605	2545	806	1406	877	1414	285	330	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	36	40	40				
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	193	204	210	210				
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	310	305	310	320				
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	320	310	310	320				
64	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400		Under maint.	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+11*6	195	195	185	185	175	185				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	129	13	130				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	46	40	46				
69	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	24	34	34	34				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	15	16	16				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	34	16	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	21	21	21				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	49	98	98	98				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	95	27	95				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	97	18	97				
**	Import (Tirupura)	India		160	160	172	108	129	152				
Cumilla Zone Total					2904	2896	1558	1847	1587	1937	0	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	99	80	100	103		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	75	18	80				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	88				
84	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	50	0	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total					622	614	213	293	249	299	103	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.05.23 (Yesterday)		01.06.23 (Today)		31.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43	27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	40	40	51	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	55	60	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	81	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	190	182	182	182			
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	16	16	17	Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	305	300	305			
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	376	368	400	400			
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	345	390	400	400			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	48	44	48			
Sylhet Zone Total					2472	2427	1669	1699	1752	1761	17	562
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	355	275	150	250	135	Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	20	30	22	35			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	31	82	60	80			
108	Khulna 225 MW CAPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Kushtia 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	85	105	105	105			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	98	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	46	63	62	63			
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	8	40			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	323	321	330	330			
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0			
**	Bheramara (HVDC)	India	1000	1000	912	794	930	930				
Khulna Zone Total					2905	2901	1887	1727	1784	1850	135	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	32	23	35			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	169	172	175	175			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	450	622	622	622			
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150			
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220	Under maint.	
Barishal Zone Total					2265	2265	826	1142	1003	1148	0	220
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	25	30			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	51	90	80	90			
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	38	40	40			
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	35	35			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	203	162	160	160			
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	206	157	150	160	63	Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	414	350	414			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	19	22	22			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	16	0	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	55	35	55			
139	Antura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	6	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	910	910	902	910			
Rajshahi Zone Total					2927	2905	1612	2044	1910	2088	354	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	72	71	72	13	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	240	230	240		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	26	63	35	49			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	115	74	115			
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	23	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	161	0	130	0			
Rangpur Zone Total					1030	950	577	490	578	476	13	85
Sub-total: Plants in operation					23634	23370	12326.0	14368	13087	14756	1263	2235
(B) Plants under long term maintenance/ contract expired												
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PP(ULCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Aspiganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					339	0	0	0	0	0	0	0
Gross Total					24143	23370	12326	14368	13087	14756	1263	2235
(C) Actual data of 31.05.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	15600	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	14750	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	14368	MW, at =	21:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	11312	MW, at =	7:00 hrs	Dhaka	5320	5050	270	Mymensingh	1189	1008
05.	Day-peak Generation (Generation end)	:	12326	MW, at =	12:00 hrs	Chattogram	1313	1189	124	Sylhet	645	508
06.	Evening-peak Generation (Generation end)	:	14368	MW, at =	21:00 hrs	Khulna	1873	1713	160	Barishal	482	439
07.	Evening Peak Load-shed (Sub-station end)	:	1177	MW, at =	21:00 hrs	Rajshahi	1519	1519	0	Rangpur	976	934
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11619	MW, at =	5:00 hrs	Cumilla	1432	1242	190			
09.	Generation shortfall at evening peak due to :	:								Total	14750	13573
	a) Gas/LF limitation	:	1045	MW						(c) Coal =	173826755	Taka
	d) Coal supply Limitation	:	13	MW						Total =	1200206831	Taka
	b) Low water level in Kaptai lake	:	205	MW								
	c) Plants under shut down/ maintenance	:	2235	MW								
10.	Total Energy (Generation + India Import)	:	303.45	MKWh								
	By Gas =	159.743	MKWh	By Oil =	59.686	MKWh						
	By Coal =	55.497	MKWh	By Hydro =	0.303	MKWh						
	By Solar =	3.086	MKWh									
11.	Total Gas Supplied	:	1226.35	MMCFD								
(D) Forecast of 01.06.23 (Today) Thursday :												
01.	Maximum Demand	:	15500	MW	(Generation end)	04.	Maximum Load-shed	:	704	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14756	MW	(Generation end)	05.	Total Generation	:	327.36	MKWh		
03.	Reserve / Shortage	:	-744	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	37.8° C			

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation