

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month June, 2023					Day : Friday					Date : 02.06.23				
Probable Maximum Demand : 14800 MW					Probable Maximum Generation : 14441 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 72.71 ft		Today = 72.64 ft		Rule Curve = 76.00 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.06.23 (Yesterday)		02.06.23 (Today)		01.06.23 (Yesterday)		02.06.23 (Today)			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date			
(A) Plants in operation:														
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorashtal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	42	41	42	66		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	320	324	320	320					
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	401	402	400	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	191	194	190	195					
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	170	160	0	0	175		Gas Shortage		
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	282	291	300	300					
14	Madanganj-55 MW PP (Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	15	0	0	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	8	16					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22					
17	Summit Power,Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	43	46	42	45					
18	Maona 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rupganj 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	31	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	48	8	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	88	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	150	64	150					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	62	145	47	145					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	16	149	17	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	300	300	300	300					
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	92	93	50	100					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	17	54					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	17	16	32					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	17	8	17					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	28	80	85	85					
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0					
Dhaka Zone Total					6104	5867	3095	3637	2983	3530	346	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0					
42	Raczen 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	23	44	6	44					
45	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	220	222	225	225					
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	282	69	280					
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	90	38	90					
50	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	50	51	51					
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	30	71	50	64					
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	5	10	10					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	26	20	25					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	90	38	90					
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	66	45	66					
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	17	34					
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	163	18	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				0	1	0	0					
Chattogram Zone Total					2605	2545	790	1416	833	1414	285	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	37	40	40					
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	200	202	200	200					
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	305	305	310	320					
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	310	305	310	320					
64	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0		400	Under maint.		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+11*6	195	195	187	185	190	185					
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	130	6	150					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	35	40	46					
69	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under overhauling		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	34	50	100					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	17	17					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	45	50	8	0					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	80	52	98					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	115	9	95					
78	Bhairabi 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	97	18	97					
**	Import (Tirupura)	India		160	160	150	146	129	152					
Cumilla Zone Total					2904	2896	1538	1889	1530	1971	0	563		
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	67	99	40	100	103		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	19	19					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	84	18	84					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	69	88	68	88					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	4	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total					622	614	233	302	209	303	103	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.06.23 (Yesterday)		02.06.23 (Today)		01.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)					
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.				
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	40	40	40		50	GT-4 Under maint.				
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50							
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11							
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	55	60	60							
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	78	84	84							
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	182	188	190	190							
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0							
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
98	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16	9		Gas Shortage				
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	295	300	305							
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	367	400	400							
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	375	400	400	400							
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	48	46	44	48							
Sylhet Zone Total						2472	2427	1665	1705	1760	1769	9	561			
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	130	155	150	150	255		Gas Shortage				
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	13	19	22	35							
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	30	71	60	80							
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0							
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17							
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105							
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0							
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	62	78	83	83							
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	40	16	40							
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	325	324	320	320							
115	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0							
**	Bheramara (HVDC)	India		1000	1000	901	812	927	927							
Khulna Zone Total						2905	2901	1690	1621	1800	1757	255	0			
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	16							
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	34	23	35							
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	168	172	170	170							
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	622	300	622							
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150							
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150							
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.				
Barishal Zone Total						2265	2265	997	1160	676	1143	0	220			
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage				
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.				
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	25	30							
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	11	0	0							
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	46	84	80	90							
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	35	40	40							
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	25	25	25							
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	29	35	35	35							
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	159	163	160	160							
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage				
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	142	152	150	150	68		Gas Shortage				
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	235	345	370	370	69		Gas Shortage				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	12	19	22	22							
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8							
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	52							
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55							
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50							
141	Ammura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	21	28							
142	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0							
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	955	1023	950	950							
Rajshahi Zone Total						2927	2905	1724	2104	1962	2065	428	100			
143	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	72	73	75	75	12		Coal Shortage				
144	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling				
145	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	230	250			Coal Shortage				
146	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
147	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	33	63	35	49							
148	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
149	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0							
150	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	114	34	115							
151	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0							
152	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	187	0	130	0							
Rangpur Zone Total						1030	950	617	500	542	489	12	85			
Sub-total: Plants in operation						23834	23370	12349.0	14334	12295	14441	1438	2234			
(B) Plants under long term maintenance/ contract expired																
153	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
154	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
155	Bosilia 108MW PP(PCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
156	Aspogan 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0							
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0			
Gross Total						24143	23370	12349	14334	12295	14441	1438	2234			
(C) Actual data of 01.06.23 (Yesterday) Thursday :																
01.	Max. Demand at eve. peak (Generation end)	:	15700 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	14950 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	14334 MW, at =	21:00 hrs	04.	5473	5203	270	Mymensingh	1181	1011	170				
04.	Minimum Generation (Generation end)	:	11619 MW, at =	6:00 hrs	05.	1397	1397	0	Sylhet	569	539	30				
05.	Day-peak Generation (Generation end)	:	12349 MW, at =	12:00 hrs	06.	Khulna	1868	1608	260	Barisal	497	442	55			
06.	Evening-peak Generation (Generation end)	:	14334 MW, at =	21:00 hrs	07.	Rajshahi	1558	1408	150	Rangpur	977	857	120			
07.	Evening Peak Load-shed (Sub-station end)	:	1305 MW, at =	21:00 hrs	08.	Cumilla	1430	1180	250							
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11281 MW, at =	5:00 hrs	09.	Total								14950	13645	1305
09.	Generation shortfall at evening peak due to :	:														
a) Gas/LF limitation						:	1221 MW									
c) Coal supply Limitation						:	12 MW									
b) Low water level in Kaptai lake						:	205 MW									
c) Plants under shut down/ maintenance						:	2234 MW									
10. Total Energy (Generation + India Import)						:	299.69 MKWh									
By Gas = 156.912 MKWh						By Oil =	57.148 MKWh									
By Coal = 57.458 MKWh						By Hydro =	0.312 MKWh									
By Solar= 3.027 MKWh																
11. Total Gas Supplied						:	1229.02 MMCFD									
(D) Forecast of 02.06.23 (Today) Friday :																
01.	Maximum Demand	:	14800 MW	(Generation end)	04.	Maximum Load-shed								335 MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14441 MW	(Generation end)	05.	Total Generation								309.44 MKWh		
03.	Reserve / Shortage	:	-359 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :								37.4° C		